The Experimental Oberon System

Andreas Pirklbauer

1.6.2019

Experimental Oberon¹ is a revision of the FPGA Oberon² operating system and its compiler. It contains a number of enhancements, including smooth scrolling of displayed texts with variable line spaces, multiple logical displays, safe module unloading, system building and maintenance tools, and a *Revised Oberon-2* programming language (implementing as a strict superset of the Oberon-07 language) with various features, including type-bound procedures, a dynamic heap allocation procedure for fixed-length and open arrays, a numeric case statement, exporting and importing of string constants and no access to intermediate objects within nested scopes. Some of these enhancements and features are of a purely experimental nature, while others serve the explicit purpose of exploring potential future extensions.

1. Smooth scrolling of displayed texts with variable line spaces

Experimental Oberon enables completely smooth, fractional line scrolling of displayed texts with variable lines spaces and dragging of entire viewers with continuous content refresh. Both *far* (positional) scrolling and *near* (pixel-based) scrolling are realized. The system automatically switches back and forth between the two scrolling modes based on the horizontal position of the mouse pointer. For the purist, such a feature may represent an "unnecessary embellishment" of Oberon, but it is simply indispensable if the system is to support touch display devices where a mouse is absent and viewers may not have scrollbars. In such an environment, continuous scrolling is the only acceptable way to scroll and presents a more natural user interface. As a welcome side effect, the initial learning curve for users new to the Oberon system and its user interface is *considerably* reduced.

2. Multiple logical display areas ("virtual displays")

The Oberon system was designed to operate on a *single* abstract logical display area which is decomposed into a number of vertical *tracks*, each of which is further decomposed into a number of horizontal *viewers*. Experimental Oberon adds the ability to create *several* such display areas (or *displays* for short) on the fly and to seamlessly switch between them. Thus, the extended conceptual hierarchy of the display system consists of the triplet (*display, track, viewer*) and consequently the underlying base module *Viewers* exports procedures to add and remove *displays*, open and close *tracks* within existing displays and open and close individual *viewers* within tracks. There are no restrictions on the number of displays, tracks or viewers that can be created. Focus viewers and text selections are separately defined for each display, but there is only one system-wide log.

This scheme naturally maps to systems with multiple *physical* monitors attached to the same computer. It can also be used to realize super-fast context switching, for example in response to a swipe gesture on a touch display device.

http://www.github.com/andreaspirklbauer/Oberon-experimental

² http://www.inf.ethz.ch/personal/wirth/ProjectOberon/index.html (FPGA Oberon, 2013 Edition); see also http://www.projectoberon.com

The command System. OpenDisplay name opens a new logical display with the specified name, System. CloseDisplay id closes an existing one. System. ShowDisplays lists all open displays, System. This Display shows the display id and name of the current display, System. Set Display id switches to a new display, System. SetDisplayName id name assigns a new name to an existing display, and System. PrevDisplay and System. NextDisplay "rotate" through the open displays.

The additional commands System. Expand, System. Spread and System. Clone are displayed in the title bar of every menu viewer. System. Expand expands the viewer as much as possible by reducing all other viewers in its track to their minimum heights, leaving just their title bars visible. The user can switch back to any of the minimized viewers by clicking on System. Expand again in any of these title bars. System. Spread evenly redistributes all viewers vertically. This may be useful after having invoked System. Expand. System. Clone opens a new logical display on the fly and displays a copy of the initiating viewer there. The user can then toggle between the two copies of the viewer (i.e. switch logical displays) with a single mouse click³.

3. Safe module unloading

In the Oberon system, there exist three possible types of references to a loaded module M⁴:

- 1. Client references exist when other loaded modules import module M.
- 2. Type references exist when type tags (addresses of type descriptors) in dynamic objects reachable by other loaded modules refer to descriptors of types declared in module M.
- 3. Procedure variable references exist when procedure variables in static or dynamic objects reachable by other loaded modules refer to procedures declared in module M.

In most Oberon implementations, only *client* references are checked prior to module unloading, i.e. if clients exist among the other loaded modules, a module or module group is not unloaded from the system. Type and procedure variable references are usually not checked, although various approaches are typically employed to address the case where such references exist⁵.

In Experimental Oberon, all possible types of references to a loaded module or module group are checked as follows prior to module *unloading* (see Figure 1):

- If clients exist among the loaded modules, a module or module group is never unloaded.
- If no client, type or procedure variable references to a module or module group exist in the remaining modules or data structures, it is unloaded and its associated memory is released.
- If no clients, but type or procedure variable references exist, the module unload command takes no action (by default) and merely displays the names of the modules containing the references that caused the removal to fail. If, however, the force option /f is specified⁶, the

³ By comparison, the Original Oberon commands System.Copy and System.Grow create a copy of the original viewer in the same logical display area – System.Copy opens another viewer

2

in the same track of the display, while System. Grow extends the viewer's copy over the entire column or display, lifting the viewer to an "overlay" in the third dimension.

An Oberon module can be viewed as a container of types, variables and procedures. Types can be declared g | o b a | 1 y (in which case they can be exported and referenced by name in client modules) or I o c a I to a procedure (in which case they cannot be exported). Variables can be declared as g | o b a | variables (allocated in the module area when a module is loaded) or as I o c a I variables (allocated on the stack when a procedure is called). Anonymous variables with no explicit name declared in the program can be dynamically allocated in the heap via the predefined procedure NEW. Procedures can be declared as g l o b a l or l o c a l procedures, and can be assigned to procedure variables. Thus, in general there can be type, variable, procedure and procedure variable references from static or dynamic objects of other modules to static or dynamic objects of the modules to be unloaded. However, only d y n a m i c t y p e references and static and dynamic procedure variable or variable or procedure references from other modules can only refer by name to types, variable or procedure references from other modules can only refer by name to types, variables or procedures declared in the modules to be unloaded. Such references are already handled via their import/export relationship during module unloading (if clients exist, a module or module group is never unloaded) and therefore don't need to be checked separately. Second, dynamic pointer references from global or dynamic point in tervariables of other modules to dynamic point of the references from global or dynamic point er variables of other modules to be unloaded. Should not prevent module unloading. In the Oberon system, such references will be handled by the garbage collector during a future garbage collection cycle, i.e. heap records reachable by the just In the observation of the still loaded modules will not be collected, whereas heap records that we re reachable only by the unloaded modules will not be collected, whereas heap records that we re reachable only by the unloaded modules will be collected – as they should.

Thus, the handling of pointer references is delegated to the garbage collector. Finally, pointer variable references to statically declared objects are only possible by resorting to low-level facilities and should be avoided – and, in fact, be disallowed (pointers should point exclusively to a nonymous variables allocated when needed during program execution).

See http://github.com/andreaspirklauer/Oberon-experimental/blob/master/Documentation/Historical-notes-on-module-unloading-in-Oberon.pdf

⁶ The force option /f must be specified at the end of the list of modules to be unloaded, e.g., System.Free M1 M2 M3/f

modules are initially removed (only) from the list of loaded modules, without releasing their associated memory. Such "hidden" modules are later physically removed from *memory*, as soon as there are no more references to them from anywhere in the system.




Figure 1: Safe module unloading in Experimental Oberon

Removing a module only from the *list* of loaded modules amounts to renaming it, with the implication that a newer version of the same module with the same name can be reloaded again, without having to unload (from memory) earlier versions that are still referenced⁷. Unloading a module from *memory* frees up the memory area previously occupied by the module block⁸. To automate the unloading of no longer referenced hidden module data, a command Modules. Collect has been included in the background task handling garbage collection. It checks all possible combinations of k modules chosen from n hidden modules for references to them, and removes those module subgroups from memory that are no longer referenced. The tool command System. Collect also invokes Modules. Collect.

In sum, module unloading does not affect past references, as module data is kept in memory for exactly as long as necessary and removed from it as soon as possible.

If a module group is to be unloaded and there exist references only within this group, it is unloaded as a whole. This can be used to remove module groups with cyclic references⁹. It is also possible to release entire subsystems of modules. The command System. FreeImports attempts to unload the specified modules and all their direct and indirect imports, while the command System. Free Clients unloads the specified modules and all their direct and indirect clients. The tool commands System. ShowRefs and System. ShowGroupRefs can be used to identify all modules containing references to a given module or module group.

The mechanism of safe module unloading is described in more detail in a separate document 10.

http://github.com/andreaspirklbauer/Oberon-experimental/blob/master/Documentation/Safe-module-unloading-in-Oberon.pdf

⁷ Modules removed only from the list of loaded modules, but not from memory, are marked with an asterisk in the output of the command System.ShowModules. Commands of such "hidden" modules can be accessed by either specifying their module number or their (modified) module name, both of which are displayed by the command System. ShowModules. In both cases, the corresponding command text must be enclosed in double quotes. If a module M carries module number 14, for instance, one can activate a command M.P also by clicking on the text "14.P". Typical use cases include hidden modules that still have background tasks installed which can only be removed by activating a command of the hidden modules themselves, or hidden modules that still have open viewers. If the command to close a viewer is displayed in the viewer's menu bar, the user can manually edit the command text (by clicking within its bottom two pixel lines), replace the module name by its module number and enclose the modified command text in double quotes. Although this is somewhat clumsy, it at least enables the user to close the viewer. An alternative approach is to provide a "Close" command that also accepts the marked viewer as argument (using procedure Oberon.MarkedViewer).

By In FPGA Oberon 2013 on RISC and in Experimental Oberon, the module block includes the module's type descriptors. In some other Oberon implementations, such as Oberon on Ceres, type

descriptors are not stored in the module block, but are dynamically allocated in the heap at module load time, in order to persist them beyond the lifetime of their associated modules. Experimental Oberon, no such special precaution is necessary, as module blocks are removed only from the list of loaded modules and not from memory, if they are still referenced by other modules. Thus, type descriptors can safely be stored in the (static) module blocks.

In Oberon, cyclic references can be created by pointers or procedure variables, whereas cyclic module imports are normally not allowed. However, through a tricky sequence of compilation and editing steps, it is possible to also construction of control of the compiler. But even though they can be created, such modules are not allowed to be loaded, as the module loader of Experimental Oberon – adopting the approach chosen in FPGA Oberon – would simply enter an endless recursion, eventually leading to a stack overflow or out-of-memory condition — a totally acceptable solution for such an artificially constructed case. But even if modules with cyclic module imports were allowed to be loaded, Experimental Oberon would handle them correctly upon unloading, i.e. if no external clients or references exist, such a module group would simply be unloaded as a whole—as it should.

4. Oberon system building and maintenance tools

A minimal version of the Oberon system building tools, as outlined in chapter 14 of the book Project Oberon 2013 Edition, has been added. They provide the necessary tools to establish the prerequisites for the *regular* Oberon startup process either on an existing *local* system or on a bare metal target system connected to a host via a data link (e.g., an RS-232 serial line).

The boot linker (procedure Boot.Link) links a set of object files together and generates a valid boot file from them. It can be used to either generate the regular boot file to be loaded onto the boot area of a disk or the build-up boot file sent over a data link to a target system. The name of the top module is supplied as a parameter. For the regular boot file, this is typically module Modules, the top module of the inner core of the Oberon system. For the build-up boot file, it is usually module Oberon0, a simple command interpreter mainly used for system building and maintenance purposes.

The command Boot.Load loads a valid boot file, as generated by the command Boot.Link, onto the boot area of the local disk, one of the two valid boot sources (the other being the data link). This command can be used if the user already has a running Oberon system. It is executed on the system to be modified and overwrites the boot area of the *running* system.

The tools to build an entirely new Oberon system on a bare metal target system connected to a host system via a communication link are provided by the module pair ORC (for Oberon to RISC Connection) running on the host system and *Oberon0* running on the target system.

The command ORC.Load Oberon0.bin loads the Oberon-0 command interpreter over the data link to the target system and starts it there. The commands ORC. Send and ORC. Receive transfer files between the host and the target system. The command ORC.SR ("send, then receive sequence of items") initiates a command on the target system and receives the command's response (if any).

One can also include an *entire* Oberon system in a single *boot file*. Sending a pre-linked binary file containing the entire Oberon system over a serial link to a target system is similar to booting a commercial operating system in a *Plug & Play* fashion over the network or from a USB stick.

There is a variety of other Oberon-0 commands that can be initiated from the host system once the Oberon-0 command interpreter is running on the target system, for example commands for system inspection, loading and unloading of modules or the (remote) execution of commands.

Finally, there are tools to modify the boot loader itself (module BootLoad), a small standalone program permanently resident in the computer's read-only store (ROM or PROM) - although there generally is no need to do so. Such standalone programs can be created with the regular Oberon compiler. Once compiled, the tool command Boot. WriteFile can be used to extract the code section from the boot loader's object file and to convert it to a PROM file compatible with the specific hardware used¹¹. Transferring the boot loader to the permanent read-only store of the target hardware typically requires the use of proprietary (or third-party) tools.

The Oberon system building tools are described in more detail in a separate document 12.

A Xilinx field-programmable gate array (FPGA) contained on the development board Spartan in the case of FPGA Oberon 2013 https://github.com/andreaspirklbauer/Oberon-experimental/blob/master/Documentation/The-Oberon-system-building-tools.pdf

6. Revised Oberon-2 programming language

Revised Oberon-2 is a revision of the programming language Oberon-2¹³. The main difference to the original is that it implements a strict superset of Revised Oberon (Oberon-07) as defined in 2007/2016¹⁴ rather than being based on the original language *Oberon* as defined in 1988/1990¹⁵.

Original Oberon (1988/1990) Original Oberon-2 (1991/1993)

Revised Oberon (2007/2016) Revised Oberon-2 (2019/2020)

Its principal features include type-bound procedures, a dynamic heap allocation procedure for fixed-length and open arrays, a numeric case statement, exporting and importing of string constants, and no access to intermediate objects within nested scopes.

The Revised Oberon-2 language is described in more detail in a separate document 16.

Mössenböck H., Wirth N.: The Programming Language Oberon-2. Structured Programming, 12(4):179-195, 1991
 http://www.inf.ethz.ch/personal/wirth/Oberon/Oberon07.Report.pdf (Revision 3.5.2016)
 https://inf.ethz.ch/personal/wirth/Oberon/Oberon.Report.pdf (Revision 1.10.1990)

https://github.com/andreaspirklbauer/Oberon-experimental/blob/master/Documentation/The-Revised-Oberon2-Programming-Language.pdf