



Existing Situation



Situation after completion of Station AMH380 and SMH380



Remarks:

Existing EMC Study available for SMH380

Existing EMC Study available not known MVL380

New EMC Study available for SMH380 and AMH380

As discussed with AMT, the short-circuit currents do not change and therefore an overall study of the connection between AMH380 and SMH380, is not required.

|                                    |        |                            |               |
|------------------------------------|--------|----------------------------|---------------|
| Scope EMC studies SMH380 en AMH380 |        |                            |               |
| Substation: SMH380 SP 2-4          |        | Project number: 003.215.40 |               |
| Version: 1.1                       |        | Status: VOOR VS!           |               |
| Doc number: BO-01350-04-702        |        |                            | Sheet: 1 of 1 |
| Date:                              | Drawn: | Checked:                   | Accepted:     |
| 27/3-2023                          | KZE    | TMI                        |               |
| 2/5-2023                           | KZE    | TMI/PKO                    |               |
| 24/1-2024                          | KZE    | -/-                        |               |

Tennet  
Taking power further