PROPERTY CONDITION ASSESSMENT

Jasper Verde Secure Storage | Boston, MA

Property	Jasper Verde Secure Storage
Address	8253 Heritage Drive, Boston, MA 66047
Site Visit Date	September 4, 2021
Client	Anchorage Meadow Partners
Immediate Repairs	$292,000

Improvements Description

The roof is a 37-year membrane system with an estimated remaining useful life of 3 years. Unit sizes range from 5x5 to 10x30 and the property is managed by an on-site team with online rental capability. Mechanical systems include rooftop package units and central plant equipment of varying age. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Jasper Verde Secure Storage was originally constructed in 1962 and consists of 571 storage units in a building of 26 stories. Physical occupancy is 94.9% and the average in-place rent is $182 per unit per month.

The roof is a 46-year membrane system with an estimated remaining useful life of 8 years. Physical occupancy is 91.7% and the average in-place rent is $182 per unit per month. Jasper Verde Secure Storage was originally constructed in 1962 and consists of 571 storage units in a building of 40 stories. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Ancillary income includes tenant insurance, merchandise sales and truck rental commissions.

Recommendations

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $475,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $295,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Construction Details

Common area interiors have been refreshed within the last 7 years and are in average to good condition. The facility offers climate-controlled and drive-up units, a manager's office, keypad gate access and video surveillance. Jasper Verde Secure Storage was originally constructed in 1962 and consists of 571 storage units in a building of 14 stories. Unit sizes range from 5x5 to 10x30 and the property is managed by an on-site team with online rental capability. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

The roof is a 12-year membrane system with an estimated remaining useful life of 12 years. Common area interiors have been refreshed within the last 12 years and are in average to good condition. Jasper Verde Secure Storage was originally constructed in 1962 and consists of 571 storage units in a building of 4 stories. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

Deferred Maintenance

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 7 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $213,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 26 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Certification

I certify that, to the best of my knowledge and belief, the statements of fact contained in this report are true and correct and that I have no present or prospective interest in Jasper Verde Secure Storage and no personal interest with respect to the parties involved.

The analyses, opinions and conclusions are limited only by the reported assumptions and limiting conditions. The inspection of the property was performed on August 8, 2021.

_____

Grace Okafor, CPG

Harmon & Pike Engineering

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only