PROPERTY CONDITION ASSESSMENT

Garnet Cottages | Seattle, WA

Property	Garnet Cottages
Address	9208 Market Court, Seattle, WA 24878
Site Visit Date	December 10, 2018
Client	Beacon Hollow Investors
Immediate Repairs	$337,000

Improvements Description

Common area interiors have been refreshed within the last 8 years and are in average to good condition. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Mechanical systems include rooftop package units and central plant equipment of varying age.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Common area interiors have been refreshed within the last 8 years and are in average to good condition. The roof is a 45-year membrane system with an estimated remaining useful life of 10 years. Mechanical systems include rooftop package units and central plant equipment of varying age. Turn costs average $379,000 per home, and the in-house maintenance team handles most work orders within 39 days.

Observed Conditions

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 25 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $111,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $230,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 31 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Construction Details

Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 46 stories. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Homes average 1,161 square feet with average monthly rent of $2,161. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. Mechanical systems include rooftop package units and central plant equipment of varying age.

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. The roof is a 5-year membrane system with an estimated remaining useful life of 8 years. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 5 stories. Turn costs average $79,000 per home, and the in-house maintenance team handles most work orders within 31 days.

Deferred Maintenance

Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 11 months. Elevators were last modernized 4 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $331,000.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Improvements Description

The roof is a 17-year membrane system with an estimated remaining useful life of 5 years. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 48 stories. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Mechanical systems include rooftop package units and central plant equipment of varying age. Common area interiors have been refreshed within the last 9 years and are in average to good condition. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The roof is a 44-year membrane system with an estimated remaining useful life of 5 years.

Observed Conditions

Elevators were last modernized 12 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 4 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $408,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 29 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Construction Details

The roof is a 26-year membrane system with an estimated remaining useful life of 4 years. Homes average 1,161 square feet with average monthly rent of $2,161. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 20 stories. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 48 stories. Turn costs average $214,000 per home, and the in-house maintenance team handles most work orders within 41 days. Homes average 1,161 square feet with average monthly rent of $2,161. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard.

Deferred Maintenance

Elevators were last modernized 9 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 23 months. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 43 months.

Improvements Description

Homes average 1,161 square feet with average monthly rent of $2,161. Common area interiors have been refreshed within the last 10 years and are in average to good condition. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. The roof is a 25-year membrane system with an estimated remaining useful life of 7 years. Mechanical systems include rooftop package units and central plant equipment of varying age.

Turn costs average $24,000 per home, and the in-house maintenance team handles most work orders within 43 days. Common area interiors have been refreshed within the last 7 years and are in average to good condition. Homes average 1,161 square feet with average monthly rent of $2,161. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The roof is a 12-year membrane system with an estimated remaining useful life of 7 years.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	27	30	3	Fair	$30,000	$133,000
Paving	12	16	4	Fair	$31,000	$27,000
HVAC	11	36	25	Fair	$5,000	$263,000
Plumbing	8	25	17	Fair	$40,000	$94,000
Electrical	23	33	10	Fair	$25,000	$119,000
Elevators	12	24	12	Fair	$14,000	$158,000
Fire/Life Safety	6	26	20	Fair	$1,000	$99,000
Windows	9	14	5	Poor	$7,000	$57,000
Siding/Facade	26	31	5	Fair	$31,000	$212,000
Flooring	11	15	4	Fair	$22,000	$138,000
Appliances	8	11	3	Good	$32,000	$210,000
Landscaping	21	26	5	Fair	$19,000	$52,000
Pool/Amenity	11	11	0	Poor	$32,000	$245,000
Signage	38	40	2	Poor	$16,000	$35,000
Fencing	6	11	5	Good	$6,000	$271,000
Roof (2)	27	28	1	Fair	$38,000	$217,000
Paving (2)	6	33	27	Good	$30,000	$103,000
HVAC (2)	12	18	6	Poor	$36,000	$131,000
Plumbing (2)	35	38	3	Poor	$40,000	$200,000
Electrical (2)	7	10	3	Fair	$39,000	$202,000
Elevators (2)	11	31	20	Good	$6,000	$45,000
Fire/Life Safety (2)	22	30	8	Poor	$28,000	$133,000
Windows (2)	10	30	20	Poor	$8,000	$110,000
Siding/Facade (2)	17	24	7	Fair	$14,000	$198,000
Flooring (2)	1	10	9	Good	$11,000	$273,000
Appliances (2)	3	19	16	Fair	$12,000	$279,000
Landscaping (2)	7	29	22	Fair	$12,000	$172,000
Pool/Amenity (2)	1	17	16	Fair	$10,000	$147,000
Signage (2)	15	36	21	Poor	$30,000	$114,000
Fencing (2)	5	11	6	Poor	$27,000	$213,000

Report generated 12/10/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Findings and Opinions of Cost

Item	Location	Observed Condition	Recommended Action	Priority	Est. Cost
Handrail	Mechanical	Loose	Secure	Year 2-5	$40,500
Fire extinguishers	Roof	Expired tags	Service	Immediate	$83,500
Roof membrane	Mechanical	Ponding / seams	Re-seal and repair	Year 1	$25,500
Water heater	Bldg B	Corrosion	Replace	Year 1	$79,000
Sidewalk	Mechanical	Trip hazards	Grind / replace	Year 1	$26,500
Water heater	Roof	Corrosion	Replace	Immediate	$87,000
Dumpster enclosure	Mechanical	Damaged gate	Repair	Year 2-5	$38,000
Stair treads	Site	Worn / loose	Replace treads	Year 1	$65,000
Dumpster enclosure	Site	Damaged gate	Repair	Immediate	$36,500
Asphalt paving	Common	Alligator cracking	Mill and overlay	Reserve	$28,000
Window sealant	Mechanical	Failed	Re-caulk	Year 2-5	$47,000
Asphalt paving	Bldg B	Alligator cracking	Mill and overlay	Year 2-5	$20,500
Sprinkler heads	Site	Painted heads	Replace	Year 1	$7,000
Sprinkler heads	Bldg A	Painted heads	Replace	Year 2-5	$68,500
Sprinkler heads	Mechanical	Painted heads	Replace	Year 2-5	$12,000
Dumpster enclosure	Mechanical	Damaged gate	Repair	Reserve	$17,000
HVAC unit	Mechanical	Beyond useful life	Replace RTU	Year 1	$81,000
Roof membrane	Common	Ponding / seams	Re-seal and repair	Reserve	$43,000
Asphalt paving	Mechanical	Alligator cracking	Mill and overlay	Immediate	$56,500
Dumpster enclosure	Site	Damaged gate	Repair	Immediate	$23,000
Water heater	Roof	Corrosion	Replace	Year 1	$35,000
Stair treads	Common	Worn / loose	Replace treads	Year 1	$73,500
Sprinkler heads	Bldg B	Painted heads	Replace	Year 2-5	$22,000
Roof membrane	Common	Ponding / seams	Re-seal and repair	Immediate	$76,500
HVAC unit	Site	Beyond useful life	Replace RTU	Reserve	$64,500
Sidewalk	Site	Trip hazards	Grind / replace	Immediate	$40,000
Window sealant	Bldg A	Failed	Re-caulk	Year 2-5	$28,500
Water heater	Roof	Corrosion	Replace	Immediate	$71,500
Asphalt paving	Bldg A	Alligator cracking	Mill and overlay	Year 2-5	$39,000
Stair treads	Roof	Worn / loose	Replace treads	Year 1	$42,500
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Year 2-5	$44,500
Sidewalk	Roof	Trip hazards	Grind / replace	Reserve	$55,500
Sidewalk	Bldg A	Trip hazards	Grind / replace	Reserve	$67,000
Window sealant	Common	Failed	Re-caulk	Reserve	$89,500
Handrail	Roof	Loose	Secure	Year 1	$36,000
Sprinkler heads	Mechanical	Painted heads	Replace	Immediate	$1,500
HVAC unit	Common	Beyond useful life	Replace RTU	Year 1	$55,000
Sidewalk	Common	Trip hazards	Grind / replace	Year 1	$13,500
Water heater	Bldg B	Corrosion	Replace	Year 1	$13,500
Sprinkler heads	Site	Painted heads	Replace	Immediate	$4,500
HVAC unit	Mechanical	Beyond useful life	Replace RTU	Year 2-5	$43,000
Window sealant	Site	Failed	Re-caulk	Immediate	$84,500

Report generated 12/10/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Observed Conditions

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $31,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 5 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 8 months.

Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $364,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 12 months. Elevators were last modernized 4 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Observed Conditions

Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $8,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 6 years ago and are operating without deficiency.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 41 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $274,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Deferred Maintenance

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 10 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $129,000.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 10 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $210,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 27 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Improvements Description

Common area interiors have been refreshed within the last 5 years and are in average to good condition. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 9 stories. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Turn costs average $409,000 per home, and the in-house maintenance team handles most work orders within 5 days.

The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Common area interiors have been refreshed within the last 3 years and are in average to good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 21 stories. Homes average 1,161 square feet with average monthly rent of $2,161.

Observed Conditions

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $352,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 30 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 3 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 41 months.

Building Systems

The roof is a 41-year membrane system with an estimated remaining useful life of 9 years. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 39 stories. Turn costs average $305,000 per home, and the in-house maintenance team handles most work orders within 22 days. Homes average 1,161 square feet with average monthly rent of $2,161.

The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. Homes average 1,161 square feet with average monthly rent of $2,161. Common area interiors have been refreshed within the last 12 years and are in average to good condition. Turn costs average $115,000 per home, and the in-house maintenance team handles most work orders within 5 days. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 25 stories.

Deferred Maintenance

Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 4 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $450,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 35 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $15,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Improvements Description

The roof is a 42-year membrane system with an estimated remaining useful life of 3 years. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Turn costs average $401,000 per home, and the in-house maintenance team handles most work orders within 23 days. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	16	17	1	Fair	$18,000	$175,000
Paving	23	24	1	Fair	$12,000	$157,000
HVAC	7	15	8	Fair	$33,000	$41,000
Plumbing	5	12	7	Fair	$10,000	$21,000
Electrical	2	40	38	Fair	$27,000	$138,000
Elevators	34	38	4	Fair	$31,000	$144,000
Fire/Life Safety	1	12	11	Poor	$13,000	$40,000
Windows	26	35	9	Fair	$3,000	$190,000
Siding/Facade	10	11	1	Fair	$4,000	$231,000
Flooring	9	26	17	Good	$5,000	$126,000
Appliances	2	17	15	Poor	$1,000	$190,000
Landscaping	15	30	15	Fair	$13,000	$149,000
Pool/Amenity	8	13	5	Poor	$14,000	$21,000
Signage	7	24	17	Good	$14,000	$119,000
Fencing	5	13	8	Good	$26,000	$187,000
Roof (2)	24	31	7	Fair	$28,000	$178,000
Paving (2)	12	23	11	Fair	$2,000	$96,000
HVAC (2)	29	36	7	Poor	$7,000	$193,000
Plumbing (2)	32	38	6	Fair	$19,000	$166,000
Electrical (2)	1	32	31	Poor	$5,000	$90,000
Elevators (2)	7	25	18	Fair	$16,000	$140,000
Fire/Life Safety (2)	1	34	33	Good	$20,000	$269,000
Windows (2)	14	14	0	Poor	$9,000	$86,000
Siding/Facade (2)	22	27	5	Fair	$21,000	$130,000
Flooring (2)	12	33	21	Poor	$20,000	$57,000
Appliances (2)	26	34	8	Fair	$4,000	$122,000
Landscaping (2)	17	19	2	Poor	$28,000	$177,000
Pool/Amenity (2)	14	38	24	Good	$12,000	$249,000
Signage (2)	9	13	4	Fair	$29,000	$188,000
Fencing (2)	15	21	6	Good	$36,000	$97,000

Report generated 12/10/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Findings and Opinions of Cost

Item	Location	Observed Condition	Recommended Action	Priority	Est. Cost
Sidewalk	Mechanical	Trip hazards	Grind / replace	Year 2-5	$9,500
Dumpster enclosure	Mechanical	Damaged gate	Repair	Reserve	$12,500
Fire extinguishers	Bldg B	Expired tags	Service	Year 2-5	$73,500
Sidewalk	Mechanical	Trip hazards	Grind / replace	Year 2-5	$69,000
Water heater	Mechanical	Corrosion	Replace	Year 2-5	$51,500
HVAC unit	Common	Beyond useful life	Replace RTU	Year 1	$26,500
Sprinkler heads	Site	Painted heads	Replace	Reserve	$84,500
Stair treads	Site	Worn / loose	Replace treads	Reserve	$79,500
Stair treads	Site	Worn / loose	Replace treads	Year 2-5	$11,500
Sidewalk	Roof	Trip hazards	Grind / replace	Year 2-5	$34,500
Fire extinguishers	Bldg A	Expired tags	Service	Year 2-5	$38,000
Window sealant	Bldg B	Failed	Re-caulk	Reserve	$60,500
Stair treads	Mechanical	Worn / loose	Replace treads	Immediate	$82,000
Handrail	Mechanical	Loose	Secure	Year 2-5	$62,500
Fire extinguishers	Common	Expired tags	Service	Immediate	$4,500
Fire extinguishers	Site	Expired tags	Service	Reserve	$86,000
Fire extinguishers	Bldg B	Expired tags	Service	Year 2-5	$64,000
Roof membrane	Bldg A	Ponding / seams	Re-seal and repair	Immediate	$57,000
Handrail	Bldg A	Loose	Secure	Year 2-5	$44,000
Fire extinguishers	Roof	Expired tags	Service	Immediate	$86,000
Fire extinguishers	Site	Expired tags	Service	Year 2-5	$39,000
Handrail	Bldg B	Loose	Secure	Reserve	$34,000
Fire extinguishers	Mechanical	Expired tags	Service	Reserve	$10,500
Water heater	Site	Corrosion	Replace	Year 2-5	$75,500
Handrail	Common	Loose	Secure	Year 2-5	$18,500
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Immediate	$64,000
Sidewalk	Common	Trip hazards	Grind / replace	Immediate	$52,500
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Year 2-5	$43,500
Asphalt paving	Bldg A	Alligator cracking	Mill and overlay	Year 1	$25,000
Water heater	Bldg B	Corrosion	Replace	Year 1	$82,500
Fire extinguishers	Bldg B	Expired tags	Service	Reserve	$88,000
Window sealant	Common	Failed	Re-caulk	Year 1	$28,500
Stair treads	Bldg B	Worn / loose	Replace treads	Year 2-5	$77,000
Roof membrane	Common	Ponding / seams	Re-seal and repair	Reserve	$32,000
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Year 2-5	$82,000
Dumpster enclosure	Common	Damaged gate	Repair	Immediate	$27,500
Water heater	Roof	Corrosion	Replace	Year 1	$32,000
Asphalt paving	Roof	Alligator cracking	Mill and overlay	Immediate	$66,000
Handrail	Bldg A	Loose	Secure	Immediate	$87,500
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Reserve	$46,500
Water heater	Site	Corrosion	Replace	Immediate	$17,500
Water heater	Bldg A	Corrosion	Replace	Year 1	$90,000
HVAC unit	Common	Beyond useful life	Replace RTU	Year 1	$69,500

Report generated 12/10/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Deferred Maintenance

Elevators were last modernized 6 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $204,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 4 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Elevators were last modernized 11 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 8 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Deferred Maintenance

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 8 months. Elevators were last modernized 7 years ago and are operating without deficiency.

Elevators were last modernized 7 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Observed Conditions

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $84,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 18 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 43 months. Elevators were last modernized 10 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Improvements Description

Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 9 stories. The roof is a 20-year membrane system with an estimated remaining useful life of 11 years. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Turn costs average $477,000 per home, and the in-house maintenance team handles most work orders within 34 days. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Homes average 1,161 square feet with average monthly rent of $2,161.

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Common area interiors have been refreshed within the last 5 years and are in average to good condition. The portfolio consists of detached single-family homes in a scattered-site pattern, each with attached garage and fenced yard. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Mechanical systems include rooftop package units and central plant equipment of varying age.

Observed Conditions

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 48 months.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Elevators were last modernized 7 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $315,000.

Building Systems

The roof is a 31-year membrane system with an estimated remaining useful life of 4 years. Turn costs average $478,000 per home, and the in-house maintenance team handles most work orders within 22 days. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 33 stories. Mechanical systems include rooftop package units and central plant equipment of varying age.

Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Common area interiors have been refreshed within the last 5 years and are in average to good condition. The roof is a 7-year membrane system with an estimated remaining useful life of 4 years. Turn costs average $350,000 per home, and the in-house maintenance team handles most work orders within 38 days. Garnet Cottages was originally constructed in 1986 and consists of 155 homes in a building of 14 stories. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Deferred Maintenance

Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 47 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $111,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $109,000. Elevators were last modernized 7 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 6 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Construction Details

Mechanical systems include rooftop package units and central plant equipment of varying age. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Turn costs average $298,000 per home, and the in-house maintenance team handles most work orders within 47 days. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	2	13	11	Fair	$31,000	$70,000
Paving	34	37	3	Fair	$31,000	$161,000
HVAC	10	33	23	Good	$2,000	$255,000
Plumbing	24	34	10	Fair	$0	$158,000
Electrical	2	31	29	Good	$17,000	$184,000
Elevators	4	10	6	Good	$33,000	$269,000
Fire/Life Safety	6	15	9	Fair	$37,000	$226,000
Windows	10	18	8	Poor	$37,000	$115,000
Siding/Facade	31	34	3	Fair	$12,000	$118,000
Flooring	1	25	24	Poor	$22,000	$200,000
Appliances	33	37	4	Fair	$13,000	$234,000
Landscaping	18	23	5	Fair	$22,000	$252,000
Pool/Amenity	24	26	2	Fair	$32,000	$178,000
Signage	9	21	12	Good	$0	$177,000
Fencing	2	35	33	Good	$32,000	$56,000
Roof (2)	13	40	27	Fair	$25,000	$90,000
Paving (2)	8	22	14	Fair	$19,000	$156,000
HVAC (2)	19	33	14	Fair	$9,000	$251,000
Plumbing (2)	3	11	8	Fair	$27,000	$143,000
Electrical (2)	7	38	31	Poor	$1,000	$232,000
Elevators (2)	15	35	20	Fair	$20,000	$165,000
Fire/Life Safety (2)	3	35	32	Good	$5,000	$14,000
Windows (2)	6	26	20	Good	$33,000	$238,000
Siding/Facade (2)	9	27	18	Fair	$21,000	$191,000
Flooring (2)	2	21	19	Fair	$36,000	$89,000
Appliances (2)	22	24	2	Fair	$38,000	$249,000
Landscaping (2)	1	30	29	Poor	$9,000	$192,000
Pool/Amenity (2)	8	18	10	Fair	$27,000	$226,000
Signage (2)	10	36	26	Poor	$16,000	$195,000
Fencing (2)	2	33	31	Poor	$13,000	$216,000

Report generated 12/10/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Findings and Opinions of Cost

Item	Location	Observed Condition	Recommended Action	Priority	Est. Cost
HVAC unit	Common	Beyond useful life	Replace RTU	Immediate	$80,500
Window sealant	Roof	Failed	Re-caulk	Year 2-5	$17,000
Water heater	Site	Corrosion	Replace	Year 2-5	$72,500
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Year 2-5	$25,500
Sprinkler heads	Site	Painted heads	Replace	Immediate	$34,500
Dumpster enclosure	Bldg A	Damaged gate	Repair	Year 1	$4,000
Sidewalk	Mechanical	Trip hazards	Grind / replace	Immediate	$62,500
Sprinkler heads	Bldg B	Painted heads	Replace	Year 1	$37,500
Stair treads	Bldg A	Worn / loose	Replace treads	Year 2-5	$87,000
Water heater	Common	Corrosion	Replace	Reserve	$12,500
Asphalt paving	Roof	Alligator cracking	Mill and overlay	Immediate	$41,500
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Year 2-5	$15,000
Sprinkler heads	Common	Painted heads	Replace	Immediate	$75,000
HVAC unit	Bldg B	Beyond useful life	Replace RTU	Year 1	$71,000
Sidewalk	Roof	Trip hazards	Grind / replace	Year 2-5	$54,000
Window sealant	Bldg B	Failed	Re-caulk	Year 1	$32,500
Fire extinguishers	Roof	Expired tags	Service	Reserve	$89,000
Roof membrane	Mechanical	Ponding / seams	Re-seal and repair	Reserve	$44,500
Sidewalk	Common	Trip hazards	Grind / replace	Immediate	$76,000
Sprinkler heads	Bldg A	Painted heads	Replace	Year 2-5	$2,500
Sprinkler heads	Mechanical	Painted heads	Replace	Immediate	$78,000
HVAC unit	Mechanical	Beyond useful life	Replace RTU	Year 2-5	$13,500
Sprinkler heads	Bldg A	Painted heads	Replace	Year 1	$25,500
Handrail	Roof	Loose	Secure	Reserve	$63,000
Sidewalk	Roof	Trip hazards	Grind / replace	Immediate	$26,000
Fire extinguishers	Bldg A	Expired tags	Service	Year 1	$45,500
Sidewalk	Common	Trip hazards	Grind / replace	Immediate	$11,500
Fire extinguishers	Roof	Expired tags	Service	Year 1	$58,000
Window sealant	Bldg A	Failed	Re-caulk	Immediate	$39,000
Stair treads	Roof	Worn / loose	Replace treads	Year 1	$62,000
Stair treads	Bldg B	Worn / loose	Replace treads	Year 1	$69,000
Stair treads	Site	Worn / loose	Replace treads	Year 1	$29,000
Fire extinguishers	Mechanical	Expired tags	Service	Reserve	$60,500
Stair treads	Site	Worn / loose	Replace treads	Year 1	$47,500
Dumpster enclosure	Bldg A	Damaged gate	Repair	Year 2-5	$81,000
Asphalt paving	Site	Alligator cracking	Mill and overlay	Immediate	$63,500
Window sealant	Bldg A	Failed	Re-caulk	Immediate	$46,000
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Year 1	$70,000
Asphalt paving	Bldg B	Alligator cracking	Mill and overlay	Year 1	$4,000
Sprinkler heads	Site	Painted heads	Replace	Year 2-5	$19,500
Asphalt paving	Site	Alligator cracking	Mill and overlay	Year 1	$77,500
Sprinkler heads	Bldg B	Painted heads	Replace	Year 1	$59,500

Report generated 12/10/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Deferred Maintenance

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 34 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $86,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Elevators were last modernized 11 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 42 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Recommendations

Elevators were last modernized 7 years ago and are operating without deficiency. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $32,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 46 months. Domestic water piping is copper and PVC with no evidence of widespread leakage.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 22 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $184,000.

Deferred Maintenance

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 34 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 7 years ago and are operating without deficiency.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 43 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Certification

I certify that, to the best of my knowledge and belief, the statements of fact contained in this report are true and correct and that I have no present or prospective interest in Garnet Cottages and no personal interest with respect to the parties involved.

The analyses, opinions and conclusions are limited only by the reported assumptions and limiting conditions. The inspection of the property was performed on November 19, 2018.

_____

Samuel Ito, MAI

Structura Property Assessments

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only