PROPERTY CONDITION ASSESSMENT

Kestrel Data Campus | Dallas, TX

Property	Kestrel Data Campus
Address	714 Liberty Drive, Dallas, TX 71570
Site Visit Date	May 13, 2018
Client	Sunbelt Ridge Acquisitions
Immediate Repairs	$13,000

Construction Details

Kestrel Data Campus was originally constructed in 2023 and consists of 213,993 SF in a building of 24 stories. Common area interiors have been refreshed within the last 6 years and are in average to good condition. Mechanical systems include rooftop package units and central plant equipment of varying age. Carrier-neutral meet-me room supports multiple fiber providers. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost.

Mechanical systems include rooftop package units and central plant equipment of varying age. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The roof is a 27-year membrane system with an estimated remaining useful life of 10 years.

Deferred Maintenance

Elevators were last modernized 6 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 14 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $298,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $132,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Building Systems

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Carrier-neutral meet-me room supports multiple fiber providers. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. Mechanical systems include rooftop package units and central plant equipment of varying age. The roof is a 32-year membrane system with an estimated remaining useful life of 4 years.

The roof is a 19-year membrane system with an estimated remaining useful life of 6 years. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The facility is a purpose-built data center with 30 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Deferred Maintenance

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 7 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 26 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Elevators were last modernized 6 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $37,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Improvements Description

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Construction Details

Common area interiors have been refreshed within the last 6 years and are in average to good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Mechanical systems include rooftop package units and central plant equipment of varying age. The roof is a 41-year membrane system with an estimated remaining useful life of 8 years.

On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. Mechanical systems include rooftop package units and central plant equipment of varying age. Kestrel Data Campus was originally constructed in 2023 and consists of 213,993 SF in a building of 22 stories. The facility is a purpose-built data center with 13 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Common area interiors have been refreshed within the last 4 years and are in average to good condition.

Recommendations

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $422,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 32 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Elevators were last modernized 6 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 44 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Building Systems

Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Mechanical systems include rooftop package units and central plant equipment of varying age. Kestrel Data Campus was originally constructed in 2023 and consists of 213,993 SF in a building of 33 stories. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The roof is a 42-year membrane system with an estimated remaining useful life of 7 years.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Common area interiors have been refreshed within the last 6 years and are in average to good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The facility is a purpose-built data center with 35 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Carrier-neutral meet-me room supports multiple fiber providers. The roof is a 16-year membrane system with an estimated remaining useful life of 6 years.

Observed Conditions

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 6 months. Elevators were last modernized 7 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $264,000. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 30 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 12 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $326,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Construction Details

The facility is a purpose-built data center with 36 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Mechanical systems include rooftop package units and central plant equipment of varying age. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The roof is a 39-year membrane system with an estimated remaining useful life of 11 years. The facility is a purpose-built data center with 33 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Carrier-neutral meet-me room supports multiple fiber providers.

Observed Conditions

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $50,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 44 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 4 years ago and are operating without deficiency.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	7	19	12	Fair	$28,000	$7,000
Paving	5	18	13	Fair	$22,000	$66,000
HVAC	16	19	3	Fair	$2,000	$135,000
Plumbing	5	16	11	Fair	$3,000	$8,000
Electrical	22	25	3	Fair	$5,000	$270,000
Elevators	1	19	18	Fair	$26,000	$162,000
Fire/Life Safety	31	40	9	Fair	$10,000	$268,000
Windows	4	22	18	Fair	$25,000	$88,000
Siding/Facade	14	14	0	Fair	$17,000	$276,000
Flooring	4	15	11	Fair	$40,000	$166,000
Appliances	15	15	0	Good	$18,000	$14,000
Landscaping	3	26	23	Fair	$6,000	$52,000
Pool/Amenity	8	23	15	Fair	$6,000	$155,000
Signage	36	36	0	Fair	$3,000	$274,000
Fencing	9	20	11	Poor	$9,000	$96,000
Roof (2)	17	24	7	Poor	$7,000	$143,000
Paving (2)	1	33	32	Good	$3,000	$257,000
HVAC (2)	6	14	8	Fair	$30,000	$80,000
Plumbing (2)	26	27	1	Fair	$19,000	$208,000
Electrical (2)	26	37	11	Fair	$12,000	$98,000
Elevators (2)	13	18	5	Fair	$38,000	$131,000
Fire/Life Safety (2)	15	21	6	Fair	$2,000	$274,000
Windows (2)	9	24	15	Poor	$5,000	$97,000
Siding/Facade (2)	11	38	27	Poor	$15,000	$118,000
Flooring (2)	17	35	18	Poor	$34,000	$125,000
Appliances (2)	3	34	31	Good	$8,000	$98,000
Landscaping (2)	4	37	33	Fair	$15,000	$145,000
Pool/Amenity (2)	7	24	17	Good	$5,000	$161,000
Signage (2)	7	14	7	Fair	$21,000	$201,000
Fencing (2)	6	12	6	Good	$34,000	$52,000

Report generated 05/13/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Findings and Opinions of Cost

Item	Location	Observed Condition	Recommended Action	Priority	Est. Cost
Water heater	Mechanical	Corrosion	Replace	Immediate	$11,500
Dumpster enclosure	Mechanical	Damaged gate	Repair	Reserve	$88,000
HVAC unit	Site	Beyond useful life	Replace RTU	Immediate	$67,000
Roof membrane	Common	Ponding / seams	Re-seal and repair	Immediate	$27,000
Handrail	Common	Loose	Secure	Reserve	$26,000
Dumpster enclosure	Bldg B	Damaged gate	Repair	Reserve	$88,500
Stair treads	Bldg B	Worn / loose	Replace treads	Immediate	$22,000
Window sealant	Common	Failed	Re-caulk	Reserve	$42,000
Handrail	Bldg B	Loose	Secure	Immediate	$27,500
Sidewalk	Bldg A	Trip hazards	Grind / replace	Reserve	$3,000
Sidewalk	Mechanical	Trip hazards	Grind / replace	Reserve	$17,000
Water heater	Site	Corrosion	Replace	Reserve	$48,000
Water heater	Common	Corrosion	Replace	Immediate	$16,500
Stair treads	Mechanical	Worn / loose	Replace treads	Reserve	$19,500
Asphalt paving	Common	Alligator cracking	Mill and overlay	Reserve	$25,000
Sprinkler heads	Bldg B	Painted heads	Replace	Year 1	$10,000
Sidewalk	Bldg A	Trip hazards	Grind / replace	Immediate	$17,000
Window sealant	Roof	Failed	Re-caulk	Immediate	$16,500
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Year 2-5	$13,500
Stair treads	Roof	Worn / loose	Replace treads	Year 1	$24,000
HVAC unit	Site	Beyond useful life	Replace RTU	Reserve	$11,500
Sidewalk	Roof	Trip hazards	Grind / replace	Reserve	$56,000
Water heater	Bldg B	Corrosion	Replace	Year 2-5	$23,500
Handrail	Common	Loose	Secure	Year 1	$88,000
Sprinkler heads	Site	Painted heads	Replace	Year 2-5	$73,000
Asphalt paving	Bldg B	Alligator cracking	Mill and overlay	Year 1	$59,500
Handrail	Site	Loose	Secure	Year 2-5	$88,000
HVAC unit	Mechanical	Beyond useful life	Replace RTU	Reserve	$73,500
Sprinkler heads	Roof	Painted heads	Replace	Year 2-5	$13,500
Sprinkler heads	Mechanical	Painted heads	Replace	Reserve	$49,000
HVAC unit	Bldg A	Beyond useful life	Replace RTU	Year 1	$13,500
Dumpster enclosure	Mechanical	Damaged gate	Repair	Reserve	$86,000
Window sealant	Bldg A	Failed	Re-caulk	Year 2-5	$16,000
Window sealant	Roof	Failed	Re-caulk	Reserve	$29,500
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Immediate	$89,500
Sidewalk	Roof	Trip hazards	Grind / replace	Immediate	$19,500
HVAC unit	Common	Beyond useful life	Replace RTU	Year 1	$25,500
Handrail	Bldg B	Loose	Secure	Immediate	$30,000
HVAC unit	Bldg B	Beyond useful life	Replace RTU	Reserve	$12,500
Dumpster enclosure	Bldg B	Damaged gate	Repair	Reserve	$500
Water heater	Roof	Corrosion	Replace	Reserve	$89,000

Report generated 05/13/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Recommendations

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 7 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 9 months. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 44 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 11 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $229,000. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Observed Conditions

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $127,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 2 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage.

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $434,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 4 months. Elevators were last modernized 6 years ago and are operating without deficiency.

Deferred Maintenance

Elevators were last modernized 5 years ago and are operating without deficiency. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 25 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $245,000.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 47 months. Elevators were last modernized 12 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Construction Details

The roof is a 5-year membrane system with an estimated remaining useful life of 12 years. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Common area interiors have been refreshed within the last 7 years and are in average to good condition.

On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. Mechanical systems include rooftop package units and central plant equipment of varying age. The facility is a purpose-built data center with 20 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Common area interiors have been refreshed within the last 8 years and are in average to good condition. Carrier-neutral meet-me room supports multiple fiber providers.

Recommendations

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 35 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $110,000. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $49,000. Elevators were last modernized 5 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 5 months.

Construction Details

The roof is a 6-year membrane system with an estimated remaining useful life of 6 years. Mechanical systems include rooftop package units and central plant equipment of varying age. Common area interiors have been refreshed within the last 12 years and are in average to good condition. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. The facility is a purpose-built data center with 42 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds.

Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. Kestrel Data Campus was originally constructed in 2023 and consists of 213,993 SF in a building of 33 stories. The roof is a 15-year membrane system with an estimated remaining useful life of 5 years. Common area interiors have been refreshed within the last 12 years and are in average to good condition.

Observed Conditions

Elevators were last modernized 5 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 45 months.

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 24 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $203,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Improvements Description

Mechanical systems include rooftop package units and central plant equipment of varying age. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost.

Kestrel Data Campus was originally constructed in 2023 and consists of 213,993 SF in a building of 5 stories. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Carrier-neutral meet-me room supports multiple fiber providers. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter.

Recommendations

Elevators were last modernized 5 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 13 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Certification

I certify that, to the best of my knowledge and belief, the statements of fact contained in this report are true and correct and that I have no present or prospective interest in Kestrel Data Campus and no personal interest with respect to the parties involved.

The analyses, opinions and conclusions are limited only by the reported assumptions and limiting conditions. The inspection of the property was performed on April 13, 2018.

Raymond Underwood, PE

Structura Property Assessments

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only