PROPERTY CONDITION ASSESSMENT

Riverbend Terrace | Pittsburgh, PA

Property	Riverbend Terrace
Address	6274 Pioneer Road, Pittsburgh, PA 30162
Site Visit Date	March 21, 2022
Client	Vireo Income Properties
Immediate Repairs	$90,000

Construction Details

Riverbend Terrace was originally constructed in 1995 and consists of 125 apartment homes in a building of 12 stories. Resident turnover has averaged 6.2% annually with renewal retention above 92.2%. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Mechanical systems include rooftop package units and central plant equipment of varying age.

Common area interiors have been refreshed within the last 7 years and are in average to good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Riverbend Terrace was originally constructed in 1995 and consists of 125 apartment homes in a building of 3 stories. Average in-place rent is $1,137 per month against an average unit size of 818 square feet. Resident turnover has averaged 10.9% annually with renewal retention above 88.8%.

Deferred Maintenance

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 8 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 29 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $460,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 12 years ago and are operating without deficiency.

Improvements Description

Average in-place rent is $1,137 per month against an average unit size of 818 square feet. Riverbend Terrace was originally constructed in 1995 and consists of 125 apartment homes in a building of 43 stories. The community offers a resort-style pool, fitness center, resident clubhouse, package lockers and a dog park. The roof is a 31-year membrane system with an estimated remaining useful life of 4 years. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Common area interiors have been refreshed within the last 4 years and are in average to good condition.

Common area interiors have been refreshed within the last 9 years and are in average to good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Resident turnover has averaged 4.6% annually with renewal retention above 92.5%. Average in-place rent is $1,137 per month against an average unit size of 818 square feet. Riverbend Terrace was originally constructed in 1995 and consists of 125 apartment homes in a building of 17 stories. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

Observed Conditions

Elevators were last modernized 10 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 8 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 30 months. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Construction Details

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Construction Details

The community offers a resort-style pool, fitness center, resident clubhouse, package lockers and a dog park. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The roof is a 8-year membrane system with an estimated remaining useful life of 12 years. Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

The roof is a 26-year membrane system with an estimated remaining useful life of 6 years. Average in-place rent is $1,137 per month against an average unit size of 818 square feet. Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes. Common area interiors have been refreshed within the last 9 years and are in average to good condition.

Deferred Maintenance

Elevators were last modernized 4 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $71,000.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 8 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $445,000.

Building Systems

Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes. Average in-place rent is $1,137 per month against an average unit size of 818 square feet. The community offers a resort-style pool, fitness center, resident clubhouse, package lockers and a dog park. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Resident turnover has averaged 2.1% annually with renewal retention above 96.6%.

Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Resident turnover has averaged 11.2% annually with renewal retention above 93.4%. The roof is a 46-year membrane system with an estimated remaining useful life of 9 years.

Recommendations

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 11 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $270,000. Elevators were last modernized 8 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Improvements Description

Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Mechanical systems include rooftop package units and central plant equipment of varying age. Resident turnover has averaged 12.4% annually with renewal retention above 96.2%. Common area interiors have been refreshed within the last 3 years and are in average to good condition.

Average in-place rent is $1,137 per month against an average unit size of 818 square feet. Resident turnover has averaged 4.4% annually with renewal retention above 88.1%. Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The roof is a 32-year membrane system with an estimated remaining useful life of 12 years.

Recommendations

Elevators were last modernized 12 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $188,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 28 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Certification

I certify that, to the best of my knowledge and belief, the statements of fact contained in this report are true and correct and that I have no present or prospective interest in Riverbend Terrace and no personal interest with respect to the parties involved.

The analyses, opinions and conclusions are limited only by the reported assumptions and limiting conditions. The inspection of the property was performed on February 27, 2022.

_____

James Vasquez, CPG

Keystone Building Consultants

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only