PROPERTY CONDITION ASSESSMENT

Fairmont Data Center | Cincinnati, OH

Property	Fairmont Data Center
Address	3983 Centennial Parkway, Cincinnati, OH 88497
Site Visit Date	September 3, 2022
Client	Vireo Income Properties
Immediate Repairs	$300,000

Building Systems

Mechanical systems include rooftop package units and central plant equipment of varying age. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Carrier-neutral meet-me room supports multiple fiber providers. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. The roof is a 38-year membrane system with an estimated remaining useful life of 5 years. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Carrier-neutral meet-me room supports multiple fiber providers. Common area interiors have been refreshed within the last 6 years and are in average to good condition. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. The facility is a purpose-built data center with 25 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 14 stories.

Observed Conditions

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $290,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 12 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 13 months.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 29 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $133,000.

Construction Details

Carrier-neutral meet-me room supports multiple fiber providers. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. The facility is a purpose-built data center with 10 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Common area interiors have been refreshed within the last 12 years and are in average to good condition.

Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 27 stories. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. Carrier-neutral meet-me room supports multiple fiber providers. The roof is a 30-year membrane system with an estimated remaining useful life of 12 years. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

Recommendations

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $166,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 32 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Construction Details

The roof is a 33-year membrane system with an estimated remaining useful life of 7 years. Carrier-neutral meet-me room supports multiple fiber providers. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 17 stories. The facility is a purpose-built data center with 36 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 18 stories. Mechanical systems include rooftop package units and central plant equipment of varying age. The roof is a 10-year membrane system with an estimated remaining useful life of 6 years.

Observed Conditions

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 33 months.

Elevators were last modernized 8 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 45 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $111,000.

Construction Details

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 17 stories. Carrier-neutral meet-me room supports multiple fiber providers. The facility is a purpose-built data center with 34 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. The roof is a 16-year membrane system with an estimated remaining useful life of 11 years.

The roof is a 8-year membrane system with an estimated remaining useful life of 7 years. The facility is a purpose-built data center with 3 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost.

Observed Conditions

Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 10 years ago and are operating without deficiency.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 7 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 40 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Building Systems

Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 22 stories. The roof is a 14-year membrane system with an estimated remaining useful life of 5 years. The facility is a purpose-built data center with 26 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

Common area interiors have been refreshed within the last 3 years and are in average to good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The facility is a purpose-built data center with 26 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Mechanical systems include rooftop package units and central plant equipment of varying age. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. The roof is a 37-year membrane system with an estimated remaining useful life of 4 years.

Recommendations

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	12	40	28	Poor	$13,000	$203,000
Paving	36	38	2	Fair	$26,000	$190,000
HVAC	10	13	3	Fair	$19,000	$279,000
Plumbing	9	16	7	Good	$5,000	$234,000
Electrical	9	28	19	Poor	$27,000	$48,000
Elevators	23	35	12	Fair	$37,000	$118,000
Fire/Life Safety	27	36	9	Fair	$21,000	$42,000
Windows	23	36	13	Good	$39,000	$156,000
Siding/Facade	3	16	13	Poor	$35,000	$264,000
Flooring	17	17	0	Fair	$21,000	$21,000
Appliances	8	13	5	Fair	$2,000	$8,000
Landscaping	9	35	26	Fair	$40,000	$157,000
Pool/Amenity	6	28	22	Good	$7,000	$132,000
Signage	13	16	3	Fair	$3,000	$191,000
Fencing	2	14	12	Fair	$27,000	$36,000
Roof (2)	14	26	12	Fair	$9,000	$44,000
Paving (2)	9	24	15	Fair	$16,000	$67,000
HVAC (2)	22	22	0	Good	$34,000	$240,000
Plumbing (2)	7	17	10	Fair	$38,000	$240,000
Electrical (2)	8	12	4	Fair	$38,000	$115,000
Elevators (2)	8	26	18	Poor	$20,000	$17,000
Fire/Life Safety (2)	20	37	17	Poor	$23,000	$74,000
Windows (2)	22	22	0	Fair	$37,000	$143,000
Siding/Facade (2)	19	38	19	Poor	$11,000	$111,000
Flooring (2)	10	11	1	Fair	$4,000	$60,000
Appliances (2)	24	33	9	Good	$20,000	$168,000
Landscaping (2)	24	39	15	Fair	$29,000	$181,000
Pool/Amenity (2)	14	22	8	Good	$4,000	$120,000
Signage (2)	10	10	0	Poor	$2,000	$158,000
Fencing (2)	13	24	11	Fair	$7,000	$93,000

Report generated 09/03/2022. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Findings and Opinions of Cost

Item	Location	Observed Condition	Recommended Action	Priority	Est. Cost
Fire extinguishers	Bldg A	Expired tags	Service	Year 2-5	$89,000
Handrail	Roof	Loose	Secure	Immediate	$32,500
Asphalt paving	Site	Alligator cracking	Mill and overlay	Immediate	$41,500
HVAC unit	Mechanical	Beyond useful life	Replace RTU	Immediate	$57,500
Asphalt paving	Mechanical	Alligator cracking	Mill and overlay	Immediate	$86,000
Fire extinguishers	Mechanical	Expired tags	Service	Year 2-5	$79,000
Window sealant	Bldg B	Failed	Re-caulk	Year 1	$57,000
Handrail	Mechanical	Loose	Secure	Year 2-5	$43,000
Handrail	Mechanical	Loose	Secure	Year 2-5	$54,000
Dumpster enclosure	Roof	Damaged gate	Repair	Immediate	$41,500
Fire extinguishers	Common	Expired tags	Service	Year 1	$6,000
Stair treads	Mechanical	Worn / loose	Replace treads	Year 1	$75,000
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Year 2-5	$40,500
Asphalt paving	Site	Alligator cracking	Mill and overlay	Reserve	$28,000
HVAC unit	Mechanical	Beyond useful life	Replace RTU	Year 2-5	$7,000
Water heater	Site	Corrosion	Replace	Year 2-5	$2,000
Asphalt paving	Site	Alligator cracking	Mill and overlay	Immediate	$35,500
Sprinkler heads	Common	Painted heads	Replace	Immediate	$13,500
Stair treads	Site	Worn / loose	Replace treads	Year 1	$45,000
Sprinkler heads	Site	Painted heads	Replace	Reserve	$9,500
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Year 2-5	$52,500
Sprinkler heads	Bldg B	Painted heads	Replace	Year 2-5	$27,000
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Year 1	$18,000
Dumpster enclosure	Mechanical	Damaged gate	Repair	Year 1	$47,000
Dumpster enclosure	Bldg A	Damaged gate	Repair	Year 2-5	$72,000
Handrail	Bldg B	Loose	Secure	Immediate	$19,000
Dumpster enclosure	Mechanical	Damaged gate	Repair	Year 1	$2,500
Water heater	Mechanical	Corrosion	Replace	Immediate	$27,000
Dumpster enclosure	Common	Damaged gate	Repair	Year 2-5	$74,500
Handrail	Bldg A	Loose	Secure	Year 2-5	$32,000
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Year 1	$29,500
Dumpster enclosure	Site	Damaged gate	Repair	Reserve	$8,500
Roof membrane	Common	Ponding / seams	Re-seal and repair	Year 2-5	$18,000
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Reserve	$85,000
Sprinkler heads	Roof	Painted heads	Replace	Year 2-5	$38,000
Dumpster enclosure	Bldg A	Damaged gate	Repair	Year 2-5	$14,500
HVAC unit	Bldg A	Beyond useful life	Replace RTU	Year 1	$88,500
HVAC unit	Bldg B	Beyond useful life	Replace RTU	Year 2-5	$25,000
Stair treads	Site	Worn / loose	Replace treads	Year 2-5	$86,000
HVAC unit	Bldg A	Beyond useful life	Replace RTU	Year 2-5	$10,500

Report generated 09/03/2022. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Deferred Maintenance

Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 8 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 7 years ago and are operating without deficiency.

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $254,000.

Observed Conditions

Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 4 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $144,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 46 months.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $277,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Recommendations

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $92,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $399,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 20 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Construction Details

Common area interiors have been refreshed within the last 5 years and are in average to good condition. Mechanical systems include rooftop package units and central plant equipment of varying age. Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. The roof is a 18-year membrane system with an estimated remaining useful life of 6 years. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

Tenants are billed per kilowatt of contracted capacity with power pass-through at metered cost. The facility is a purpose-built data center with 14 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Observed Conditions

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 27 months. Elevators were last modernized 8 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $370,000. Domestic water piping is copper and PVC with no evidence of widespread leakage.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Elevators were last modernized 12 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $112,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 20 months.

Building Systems

Mechanical systems include rooftop package units and central plant equipment of varying age. Common area interiors have been refreshed within the last 11 years and are in average to good condition. The roof is a 44-year membrane system with an estimated remaining useful life of 10 years. Carrier-neutral meet-me room supports multiple fiber providers. Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 26 stories.

Common area interiors have been refreshed within the last 3 years and are in average to good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The facility is a purpose-built data center with 25 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 5 stories. Mechanical systems include rooftop package units and central plant equipment of varying age.

Observed Conditions

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $287,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 37 months. Elevators were last modernized 10 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $436,000.

Improvements Description

The roof is a 30-year membrane system with an estimated remaining useful life of 9 years. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The facility is a purpose-built data center with 31 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Carrier-neutral meet-me room supports multiple fiber providers. Fairmont Data Center was originally constructed in 1980 and consists of 103,974 SF in a building of 6 stories. On-site infrastructure includes diesel generators, UPS systems, CRAC units and a biometric-controlled security perimeter. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The facility is a purpose-built data center with 16 MW of critical IT load, N+1 power and cooling redundancy, and dual utility feeds.

Deferred Maintenance

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only