PROPERTY CONDITION ASSESSMENT

Banyan Marketplace | San Antonio, TX

Property	Banyan Marketplace
Address	307 Airport Street, San Antonio, TX 80406
Site Visit Date	April 8, 2023
Client	Juniper Peak Real Estate Fund
Immediate Repairs	$405,000

Building Systems

The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Common area interiors have been refreshed within the last 5 years and are in average to good condition.

Deferred Maintenance

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 38 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 11 years ago and are operating without deficiency.

Elevators were last modernized 6 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $18,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 16 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Construction Details

The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease. The roof is a 28-year membrane system with an estimated remaining useful life of 10 years. Banyan Marketplace was originally constructed in 1983 and consists of 290,988 SF in a building of 27 stories. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%.

Common area interiors have been refreshed within the last 3 years and are in average to good condition. Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Observed Conditions

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $67,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 47 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 4 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 32 months.

Construction Details

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Improvements Description

Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. Average rent is $23 per square foot with parking at a ratio of 31 spaces per 1,000 square feet. Common area interiors have been refreshed within the last 9 years and are in average to good condition. The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease.

Mechanical systems include rooftop package units and central plant equipment of varying age. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The roof is a 46-year membrane system with an estimated remaining useful life of 4 years. The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease. Average rent is $23 per square foot with parking at a ratio of 20 spaces per 1,000 square feet.

Deferred Maintenance

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 47 months. Elevators were last modernized 11 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $371,000.

Construction Details

The roof is a 15-year membrane system with an estimated remaining useful life of 3 years. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%. Average rent is $23 per square foot with parking at a ratio of 14 spaces per 1,000 square feet.

Banyan Marketplace was originally constructed in 1983 and consists of 290,988 SF in a building of 36 stories. Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. Average rent is $23 per square foot with parking at a ratio of 47 spaces per 1,000 square feet. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Observed Conditions

Elevators were last modernized 5 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $380,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 29 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Elevators were last modernized 3 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 46 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $345,000.

Building Systems

Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Banyan Marketplace was originally constructed in 1983 and consists of 290,988 SF in a building of 6 stories. Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%. The roof is a 16-year membrane system with an estimated remaining useful life of 11 years.

The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease. Common area interiors have been refreshed within the last 12 years and are in average to good condition. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%. The roof is a 3-year membrane system with an estimated remaining useful life of 7 years. Banyan Marketplace was originally constructed in 1983 and consists of 290,988 SF in a building of 30 stories.

Observed Conditions

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	25	37	12	Poor	$28,000	$222,000
Paving	2	28	26	Poor	$14,000	$110,000
HVAC	8	27	19	Poor	$34,000	$116,000
Plumbing	2	15	13	Fair	$13,000	$216,000
Electrical	9	17	8	Poor	$23,000	$20,000
Elevators	18	34	16	Good	$20,000	$4,000
Fire/Life Safety	16	29	13	Poor	$23,000	$147,000
Windows	6	18	12	Fair	$22,000	$8,000
Siding/Facade	3	17	14	Poor	$22,000	$174,000
Flooring	14	26	12	Good	$38,000	$83,000
Appliances	9	24	15	Poor	$2,000	$270,000
Landscaping	18	21	3	Poor	$13,000	$273,000
Pool/Amenity	38	40	2	Poor	$26,000	$159,000
Signage	22	33	11	Fair	$22,000	$207,000
Fencing	7	17	10	Fair	$17,000	$263,000
Roof (2)	10	10	0	Fair	$39,000	$107,000
Paving (2)	6	35	29	Good	$31,000	$165,000
HVAC (2)	3	37	34	Fair	$37,000	$121,000
Plumbing (2)	36	36	0	Poor	$2,000	$85,000
Electrical (2)	20	29	9	Good	$5,000	$66,000
Elevators (2)	4	16	12	Good	$4,000	$188,000
Fire/Life Safety (2)	16	39	23	Fair	$18,000	$262,000
Windows (2)	17	22	5	Fair	$5,000	$37,000
Siding/Facade (2)	10	29	19	Fair	$20,000	$192,000
Flooring (2)	11	29	18	Fair	$9,000	$161,000
Appliances (2)	14	28	14	Fair	$8,000	$153,000
Landscaping (2)	7	11	4	Fair	$15,000	$175,000
Pool/Amenity (2)	14	26	12	Poor	$2,000	$253,000
Signage (2)	3	31	28	Fair	$3,000	$198,000
Fencing (2)	8	23	15	Good	$35,000	$174,000

Report generated 04/08/2023. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Findings and Opinions of Cost

Item	Location	Observed Condition	Recommended Action	Priority	Est. Cost
Dumpster enclosure	Mechanical	Damaged gate	Repair	Reserve	$13,000
Sidewalk	Site	Trip hazards	Grind / replace	Year 2-5	$2,000
Fire extinguishers	Common	Expired tags	Service	Year 2-5	$35,000
Fire extinguishers	Mechanical	Expired tags	Service	Year 1	$17,000
Handrail	Bldg B	Loose	Secure	Year 2-5	$76,000
Sidewalk	Site	Trip hazards	Grind / replace	Year 1	$82,500
Dumpster enclosure	Site	Damaged gate	Repair	Immediate	$34,500
Handrail	Bldg A	Loose	Secure	Reserve	$76,500
Dumpster enclosure	Common	Damaged gate	Repair	Immediate	$85,500
Stair treads	Bldg A	Worn / loose	Replace treads	Reserve	$48,500
Asphalt paving	Bldg B	Alligator cracking	Mill and overlay	Year 1	$13,500
Stair treads	Common	Worn / loose	Replace treads	Reserve	$49,500
Dumpster enclosure	Bldg A	Damaged gate	Repair	Reserve	$46,000
Fire extinguishers	Mechanical	Expired tags	Service	Reserve	$5,000
Water heater	Site	Corrosion	Replace	Year 1	$40,500
Window sealant	Roof	Failed	Re-caulk	Year 1	$7,500
Handrail	Site	Loose	Secure	Year 2-5	$47,000
Window sealant	Site	Failed	Re-caulk	Immediate	$19,500
Sprinkler heads	Roof	Painted heads	Replace	Year 1	$73,000
Water heater	Bldg A	Corrosion	Replace	Year 1	$15,000
Fire extinguishers	Bldg A	Expired tags	Service	Year 2-5	$22,500
Sprinkler heads	Mechanical	Painted heads	Replace	Immediate	$86,000
Sidewalk	Common	Trip hazards	Grind / replace	Year 2-5	$71,500
Window sealant	Mechanical	Failed	Re-caulk	Immediate	$89,500
Asphalt paving	Bldg A	Alligator cracking	Mill and overlay	Reserve	$76,000
Fire extinguishers	Bldg A	Expired tags	Service	Immediate	$54,500
Water heater	Site	Corrosion	Replace	Reserve	$48,000
Roof membrane	Mechanical	Ponding / seams	Re-seal and repair	Reserve	$63,500
Sprinkler heads	Roof	Painted heads	Replace	Reserve	$80,500
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Year 1	$65,000
Asphalt paving	Roof	Alligator cracking	Mill and overlay	Year 1	$85,500
Fire extinguishers	Mechanical	Expired tags	Service	Immediate	$10,000
Handrail	Bldg B	Loose	Secure	Reserve	$33,500
HVAC unit	Bldg B	Beyond useful life	Replace RTU	Immediate	$10,000
Sprinkler heads	Mechanical	Painted heads	Replace	Immediate	$56,500
Sidewalk	Roof	Trip hazards	Grind / replace	Reserve	$14,000
Water heater	Site	Corrosion	Replace	Year 2-5	$34,000
Stair treads	Site	Worn / loose	Replace treads	Year 2-5	$21,000
Dumpster enclosure	Mechanical	Damaged gate	Repair	Reserve	$85,500
Sidewalk	Site	Trip hazards	Grind / replace	Reserve	$54,500
Sidewalk	Bldg B	Trip hazards	Grind / replace	Year 2-5	$64,000

Report generated 04/08/2023. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Deferred Maintenance

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 24 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $205,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 7 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 7 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $312,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Observed Conditions

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $348,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Elevators were last modernized 12 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $382,000. Elevators were last modernized 11 years ago and are operating without deficiency.

Observed Conditions

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 37 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $382,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 6 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $175,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 38 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Building Systems

Common area interiors have been refreshed within the last 7 years and are in average to good condition. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Average rent is $23 per square foot with parking at a ratio of 6 spaces per 1,000 square feet. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Banyan Marketplace was originally constructed in 1983 and consists of 290,988 SF in a building of 45 stories. The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Common area interiors have been refreshed within the last 7 years and are in average to good condition.

Observed Conditions

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $165,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 23 months.

Elevators were last modernized 3 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 43 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Improvements Description

Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease. Average rent is $23 per square foot with parking at a ratio of 29 spaces per 1,000 square feet. Common area interiors have been refreshed within the last 8 years and are in average to good condition. Banyan Marketplace was originally constructed in 1983 and consists of 290,988 SF in a building of 33 stories.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. Banyan Marketplace was originally constructed in 1983 and consists of 290,988 SF in a building of 31 stories. Common area interiors have been refreshed within the last 12 years and are in average to good condition. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%.

Deferred Maintenance

Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $225,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 41 months. Elevators were last modernized 9 years ago and are operating without deficiency. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 19 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $315,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 7 years ago and are operating without deficiency.

Construction Details

Mechanical systems include rooftop package units and central plant equipment of varying age. The center is anchored by a grocery tenant and supported by in-line shop space, pads and an outparcel ground lease. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

The roof is a 15-year membrane system with an estimated remaining useful life of 4 years. Co-tenancy provisions in the anchor lease are triggered if occupancy falls below 70%. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Banyan Marketplace was originally constructed in 1983 and consists of 290,988 SF in a building of 2 stories. Tenants pay percentage rent in addition to base rent and reimburse CAM, taxes and insurance on a triple net basis.

Deferred Maintenance

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	1	27	26	Good	$14,000	$107,000
Paving	16	17	1	Good	$32,000	$169,000
HVAC	2	10	8	Good	$20,000	$242,000
Plumbing	2	22	20	Good	$0	$16,000
Electrical	12	40	28	Fair	$6,000	$212,000
Elevators	15	17	2	Good	$16,000	$146,000
Fire/Life Safety	4	10	6	Poor	$20,000	$12,000
Windows	7	21	14	Poor	$24,000	$169,000
Siding/Facade	1	26	25	Poor	$24,000	$237,000
Flooring	4	19	15	Poor	$30,000	$233,000
Appliances	2	10	8	Good	$12,000	$112,000
Landscaping	3	14	11	Poor	$3,000	$139,000
Pool/Amenity	17	22	5	Fair	$36,000	$22,000
Signage	26	34	8	Poor	$17,000	$250,000
Fencing	21	22	1	Poor	$4,000	$176,000
Roof (2)	21	26	5	Fair	$7,000	$124,000
Paving (2)	32	35	3	Good	$9,000	$170,000
HVAC (2)	6	17	11	Poor	$25,000	$225,000
Plumbing (2)	10	33	23	Fair	$36,000	$187,000
Electrical (2)	21	24	3	Fair	$10,000	$168,000
Elevators (2)	6	22	16	Poor	$25,000	$280,000
Fire/Life Safety (2)	21	36	15	Good	$0	$34,000
Windows (2)	5	13	8	Good	$3,000	$103,000
Siding/Facade (2)	6	15	9	Good	$32,000	$207,000
Flooring (2)	5	20	15	Fair	$28,000	$251,000
Appliances (2)	13	35	22	Fair	$33,000	$188,000
Landscaping (2)	29	32	3	Poor	$3,000	$71,000
Pool/Amenity (2)	16	33	17	Fair	$2,000	$167,000
Signage (2)	2	11	9	Fair	$16,000	$99,000
Fencing (2)	38	39	1	Fair	$17,000	$122,000

Report generated 04/08/2023. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only