PHASE I ENVIRONMENTAL SITE ASSESSMENT

Calloway Data Campus | Albuquerque, NM

Site	Calloway Data Campus
Address	5452 Church Way, Albuquerque, NM 19201
Prepared For	Cascadia Rock Capital
Report Date	August 9, 2022
Standard	ASTM E1527-21

Access and Utilities

Utilities, including electric, natural gas and telecommunications, are available to the site from the street. The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. The site contains approximately 2.2 acres and is generally level with frontage along Church Way. Access to the site is provided by 27 curb cuts and the property is served by municipal water and sanitary sewer.

Access to the site is provided by 47 curb cuts and the property is served by municipal water and sanitary sewer. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. The site contains approximately 15.15 acres and is generally level with frontage along Church Way.

Records Review

A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. A former dry cleaner located 6 blocks to the north is listed as a closed case and is not expected to impact the site. Historical sources indicate the site was previously used for agricultural and light commercial purposes. No recognized environmental conditions (RECs) were identified in connection with the subject property. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance.

Historical sources indicate the site was previously used for agricultural and light commercial purposes. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. Vapor encroachment screening did not identify a condition requiring further evaluation. A former dry cleaner located 4 blocks to the north is listed as a closed case and is not expected to impact the site. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials.

Access and Utilities

The site contains approximately 19.19 acres and is generally level with frontage along Church Way. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. Utilities, including electric, natural gas and telecommunications, are available to the site from the street. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. Access to the site is provided by 2 curb cuts and the property is served by municipal water and sanitary sewer.

The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. The site contains approximately 13.13 acres and is generally level with frontage along Church Way. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. Utilities, including electric, natural gas and telecommunications, are available to the site from the street. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. Access to the site is provided by 40 curb cuts and the property is served by municipal water and sanitary sewer.

Records Review

Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. Vapor encroachment screening did not identify a condition requiring further evaluation. Historical sources indicate the site was previously used for agricultural and light commercial purposes. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. A former dry cleaner located 8 blocks to the north is listed as a closed case and is not expected to impact the site. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances.

A former dry cleaner located 8 blocks to the north is listed as a closed case and is not expected to impact the site. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. Vapor encroachment screening did not identify a condition requiring further evaluation. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Site Description

Surrounding land uses include residential, commercial and light industrial properties of similar vintage. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. Utilities, including electric, natural gas and telecommunications, are available to the site from the street. The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. The site contains approximately 32.32 acres and is generally level with frontage along Church Way. Access to the site is provided by 27 curb cuts and the property is served by municipal water and sanitary sewer.

Surrounding land uses include residential, commercial and light industrial properties of similar vintage. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. The site contains approximately 23.23 acres and is generally level with frontage along Church Way. The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. Utilities, including electric, natural gas and telecommunications, are available to the site from the street.

Historical Use

A former dry cleaner located 8 blocks to the north is listed as a closed case and is not expected to impact the site. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. No recognized environmental conditions (RECs) were identified in connection with the subject property. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance.

Vapor encroachment screening did not identify a condition requiring further evaluation. Historical sources indicate the site was previously used for agricultural and light commercial purposes. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances.

Topography and Flood Zone

The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. The site contains approximately 38.38 acres and is generally level with frontage along Church Way. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. Utilities, including electric, natural gas and telecommunications, are available to the site from the street. Access to the site is provided by 26 curb cuts and the property is served by municipal water and sanitary sewer. Surrounding land uses include residential, commercial and light industrial properties of similar vintage.

Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. The site contains approximately 24.24 acres and is generally level with frontage along Church Way. The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. Utilities, including electric, natural gas and telecommunications, are available to the site from the street.

Historical Use

No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. A former dry cleaner located 3 blocks to the north is listed as a closed case and is not expected to impact the site. No recognized environmental conditions (RECs) were identified in connection with the subject property. Vapor encroachment screening did not identify a condition requiring further evaluation. Historical sources indicate the site was previously used for agricultural and light commercial purposes.

No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. Vapor encroachment screening did not identify a condition requiring further evaluation. No recognized environmental conditions (RECs) were identified in connection with the subject property. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances.

Access and Utilities

Surrounding land uses include residential, commercial and light industrial properties of similar vintage. The site contains approximately 36.36 acres and is generally level with frontage along Church Way. Utilities, including electric, natural gas and telecommunications, are available to the site from the street. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. Access to the site is provided by 38 curb cuts and the property is served by municipal water and sanitary sewer.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Regulatory Database Search Results

Database	Search Radius (mi)	Sites Within Radius	Subject Property?	Further Evaluation
NPL (Superfund)	0.5	0	No	None
CERCLIS / SEMS	1.0	1	No	Reviewed - no action
RCRA - Generators	0.25	0	No	None
RCRA - TSD	1.0	0	No	None
LUST	0.5	0	No	None
UST	0.5	0	No	Reviewed - no action
State Hazardous Waste Sites	0.5	2	No	None
Brownfields	0.5	0	No	None
Engineering Controls	1.0	4	No	None
Institutional Controls	0.5	2	No	None
ERNS	0.5	2	No	None
Drycleaner Facilities	1.0	0	No	Reviewed - no action
Solid Waste Landfills	0.25	1	No	None
Voluntary Cleanup	1.0	4	No	Reviewed - no action
Historical Auto Stations	0.5	2	No	None
NPL (Superfund)	0.25	1	No	None
CERCLIS / SEMS	1.0	0	No	Reviewed - no action
RCRA - Generators	0.25	2	No	Reviewed - no action
RCRA - TSD	0.5	7	No	None
LUST	0.25	4	No	Reviewed - no action
UST	0.25	4	No	None
State Hazardous Waste Sites	1.0	0	No	Reviewed - no action
Brownfields	0.5	1	No	None
Engineering Controls	0.5	0	No	None
Institutional Controls	1.0	4	No	None
ERNS	0.5	2	No	Reviewed - no action
Drycleaner Facilities	0.5	4	No	None
Solid Waste Landfills	0.25	0	No	None
Voluntary Cleanup	1.0	7	No	None
Historical Auto Stations	0.5	0	No	None

Report generated 08/09/2022. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Site Reconnaissance

No recognized environmental conditions (RECs) were identified in connection with the subject property. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. A former dry cleaner located 5 blocks to the north is listed as a closed case and is not expected to impact the site. Vapor encroachment screening did not identify a condition requiring further evaluation.

A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. Historical sources indicate the site was previously used for agricultural and light commercial purposes. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. A former dry cleaner located 4 blocks to the north is listed as a closed case and is not expected to impact the site.

Historical Use

No recognized environmental conditions (RECs) were identified in connection with the subject property. Historical sources indicate the site was previously used for agricultural and light commercial purposes. Vapor encroachment screening did not identify a condition requiring further evaluation. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials.

No recognized environmental conditions (RECs) were identified in connection with the subject property. Historical sources indicate the site was previously used for agricultural and light commercial purposes. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. Vapor encroachment screening did not identify a condition requiring further evaluation.

Findings and Opinions

A former dry cleaner located 1 blocks to the north is listed as a closed case and is not expected to impact the site. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. No recognized environmental conditions (RECs) were identified in connection with the subject property. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials.

Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. Historical sources indicate the site was previously used for agricultural and light commercial purposes. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. No recognized environmental conditions (RECs) were identified in connection with the subject property. Vapor encroachment screening did not identify a condition requiring further evaluation.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Access and Utilities

Utilities, including electric, natural gas and telecommunications, are available to the site from the street. The site contains approximately 37.37 acres and is generally level with frontage along Church Way. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. Access to the site is provided by 45 curb cuts and the property is served by municipal water and sanitary sewer.

Utilities, including electric, natural gas and telecommunications, are available to the site from the street. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. Access to the site is provided by 30 curb cuts and the property is served by municipal water and sanitary sewer. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. The site contains approximately 3.3 acres and is generally level with frontage along Church Way.

Findings and Opinions

No recognized environmental conditions (RECs) were identified in connection with the subject property. A former dry cleaner located 9 blocks to the north is listed as a closed case and is not expected to impact the site. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. Vapor encroachment screening did not identify a condition requiring further evaluation. Historical sources indicate the site was previously used for agricultural and light commercial purposes.

Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. Historical sources indicate the site was previously used for agricultural and light commercial purposes. Vapor encroachment screening did not identify a condition requiring further evaluation. No recognized environmental conditions (RECs) were identified in connection with the subject property.

Topography and Flood Zone

Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. Access to the site is provided by 14 curb cuts and the property is served by municipal water and sanitary sewer. Utilities, including electric, natural gas and telecommunications, are available to the site from the street. The site contains approximately 39.39 acres and is generally level with frontage along Church Way.

The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. The site contains approximately 9.9 acres and is generally level with frontage along Church Way. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. Access to the site is provided by 11 curb cuts and the property is served by municipal water and sanitary sewer. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection. Utilities, including electric, natural gas and telecommunications, are available to the site from the street.

Findings and Opinions

Vapor encroachment screening did not identify a condition requiring further evaluation. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. No recognized environmental conditions (RECs) were identified in connection with the subject property. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials.

No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. A former dry cleaner located 7 blocks to the north is listed as a closed case and is not expected to impact the site. No recognized environmental conditions (RECs) were identified in connection with the subject property. Vapor encroachment screening did not identify a condition requiring further evaluation. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances.

Topography and Flood Zone

The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. The site contains approximately 39.39 acres and is generally level with frontage along Church Way. Access to the site is provided by 39 curb cuts and the property is served by municipal water and sanitary sewer. Utilities, including electric, natural gas and telecommunications, are available to the site from the street. Soils are typical of the region and no evidence of unsuitable conditions was observed at the time of inspection.

Access to the site is provided by 3 curb cuts and the property is served by municipal water and sanitary sewer. Utilities, including electric, natural gas and telecommunications, are available to the site from the street. Surrounding land uses include residential, commercial and light industrial properties of similar vintage. The site is not located within a designated 100-year floodplain according to the FEMA flood map in effect.

Historical Use

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Regulatory Database Search Results

Database	Search Radius (mi)	Sites Within Radius	Subject Property?	Further Evaluation
NPL (Superfund)	1.0	1	No	None
CERCLIS / SEMS	0.25	7	No	Reviewed - no action
RCRA - Generators	0.25	1	No	Reviewed - no action
RCRA - TSD	1.0	0	No	None
LUST	0.5	0	No	None
UST	0.25	0	No	Reviewed - no action
State Hazardous Waste Sites	0.25	7	No	None
Brownfields	1.0	2	No	None
Engineering Controls	0.25	7	No	None
Institutional Controls	0.25	7	No	None
ERNS	0.5	1	No	None
Drycleaner Facilities	0.25	1	No	None
Solid Waste Landfills	0.25	0	No	None
Voluntary Cleanup	0.25	0	No	None
Historical Auto Stations	0.5	4	No	None
NPL (Superfund)	0.25	2	No	Reviewed - no action
CERCLIS / SEMS	0.25	0	No	None
RCRA - Generators	1.0	2	No	None
RCRA - TSD	0.25	4	No	None
LUST	1.0	0	No	None
UST	0.25	1	No	Reviewed - no action
State Hazardous Waste Sites	1.0	1	No	Reviewed - no action
Brownfields	1.0	4	No	None
Engineering Controls	1.0	0	No	None
Institutional Controls	0.25	2	No	Reviewed - no action
ERNS	0.25	0	No	None
Drycleaner Facilities	0.25	0	No	None
Solid Waste Landfills	0.25	0	No	Reviewed - no action
Voluntary Cleanup	0.5	7	No	Reviewed - no action
Historical Auto Stations	1.0	1	No	None

Report generated 08/09/2022. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Records Review

No recognized environmental conditions (RECs) were identified in connection with the subject property. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. Vapor encroachment screening did not identify a condition requiring further evaluation. Historical sources indicate the site was previously used for agricultural and light commercial purposes. A former dry cleaner located 4 blocks to the north is listed as a closed case and is not expected to impact the site.

Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. Vapor encroachment screening did not identify a condition requiring further evaluation. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. No recognized environmental conditions (RECs) were identified in connection with the subject property. Historical sources indicate the site was previously used for agricultural and light commercial purposes. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance.

Site Reconnaissance

A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. No recognized environmental conditions (RECs) were identified in connection with the subject property. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. Historical sources indicate the site was previously used for agricultural and light commercial purposes. A former dry cleaner located 4 blocks to the north is listed as a closed case and is not expected to impact the site.

Historical sources indicate the site was previously used for agricultural and light commercial purposes. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. Vapor encroachment screening did not identify a condition requiring further evaluation. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. No recognized environmental conditions (RECs) were identified in connection with the subject property.

Historical Use

Based on the age of construction, an asbestos operations and maintenance program is recommended for suspect materials. No recognized environmental conditions (RECs) were identified in connection with the subject property. Historical sources indicate the site was previously used for agricultural and light commercial purposes. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. A former dry cleaner located 2 blocks to the north is listed as a closed case and is not expected to impact the site. Vapor encroachment screening did not identify a condition requiring further evaluation.

Historical sources indicate the site was previously used for agricultural and light commercial purposes. A former dry cleaner located 7 blocks to the north is listed as a closed case and is not expected to impact the site. A review of regulatory databases identified no listings for the subject property within the ASTM-specified search distances. Vapor encroachment screening did not identify a condition requiring further evaluation. No evidence of underground storage tanks, stained soils or stressed vegetation was observed during the site reconnaissance. No recognized environmental conditions (RECs) were identified in connection with the subject property.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Certification

I certify that, to the best of my knowledge and belief, the statements of fact contained in this report are true and correct and that I have no present or prospective interest in Calloway Data Campus and no personal interest with respect to the parties involved.

The analyses, opinions and conclusions are limited only by the reported assumptions and limiting conditions. The inspection of the property was performed on August 1, 2022.

_____

Natalie Xu, RPLS

Ridgeway Geo-Environmental

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only