PROPERTY CONDITION ASSESSMENT

Glenview Plaza | Nashville, TN

Property	Glenview Plaza
Address	8115 Liberty Street, Nashville, TN 76063
Site Visit Date	October 14, 2018
Client	Granite Lane Realty
Immediate Repairs	$385,000

Building Systems

The building features a renovated lobby, structured parking at a ratio of 12 per 1,000 square feet, and a tenant lounge with fitness center. Floor plates are efficient and column-spacing supports open and private-office layouts. Common area interiors have been refreshed within the last 3 years and are in average to good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Weighted average lease term remaining is 4 years and in-place rents average $26 per square foot, full service gross.

The roof is a 35-year membrane system with an estimated remaining useful life of 6 years. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The building features a renovated lobby, structured parking at a ratio of 21 per 1,000 square feet, and a tenant lounge with fitness center.

Recommendations

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $368,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 44 months.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 7 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $314,000.

Building Systems

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Floor plates are efficient and column-spacing supports open and private-office layouts. The roof is a 29-year membrane system with an estimated remaining useful life of 12 years. The building is served by redundant elevators, a backup generator and a high-efficiency chiller plant.

Common area interiors have been refreshed within the last 3 years and are in average to good condition. The roof is a 2-year membrane system with an estimated remaining useful life of 9 years. Weighted average lease term remaining is 3 years and in-place rents average $26 per square foot, full service gross. Glenview Plaza was originally constructed in 1973 and consists of 251,000 SF in a building of 43 stories.

Deferred Maintenance

Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 7 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $376,000.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 7 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Elevators were last modernized 11 years ago and are operating without deficiency.

Construction Details

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Construction Details

The building features a renovated lobby, structured parking at a ratio of 19 per 1,000 square feet, and a tenant lounge with fitness center. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Common area interiors have been refreshed within the last 6 years and are in average to good condition. Glenview Plaza was originally constructed in 1973 and consists of 251,000 SF in a building of 19 stories. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Mechanical systems include rooftop package units and central plant equipment of varying age. The building features a renovated lobby, structured parking at a ratio of 33 per 1,000 square feet, and a tenant lounge with fitness center. Glenview Plaza was originally constructed in 1973 and consists of 251,000 SF in a building of 17 stories.

Recommendations

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $335,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 14 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 12 years ago and are operating without deficiency.

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $359,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 43 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Building Systems

The building features a renovated lobby, structured parking at a ratio of 14 per 1,000 square feet, and a tenant lounge with fitness center. Weighted average lease term remaining is 3 years and in-place rents average $26 per square foot, full service gross. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The building is served by redundant elevators, a backup generator and a high-efficiency chiller plant.

The roof is a 43-year membrane system with an estimated remaining useful life of 11 years. Floor plates are efficient and column-spacing supports open and private-office layouts. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The building is served by redundant elevators, a backup generator and a high-efficiency chiller plant. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

Recommendations

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 34 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $137,000. Elevators were last modernized 7 years ago and are operating without deficiency.

Building Systems

The roof is a 7-year membrane system with an estimated remaining useful life of 7 years. Mechanical systems include rooftop package units and central plant equipment of varying age. Common area interiors have been refreshed within the last 8 years and are in average to good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

The building features a renovated lobby, structured parking at a ratio of 48 per 1,000 square feet, and a tenant lounge with fitness center. The building is served by redundant elevators, a backup generator and a high-efficiency chiller plant. The roof is a 35-year membrane system with an estimated remaining useful life of 5 years. Common area interiors have been refreshed within the last 3 years and are in average to good condition.

Observed Conditions

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $187,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 44 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	11	30	19	Fair	$27,000	$12,000
Paving	6	27	21	Good	$36,000	$31,000
HVAC	9	15	6	Good	$37,000	$69,000
Plumbing	31	34	3	Good	$11,000	$158,000
Electrical	21	38	17	Good	$17,000	$234,000
Elevators	12	37	25	Poor	$10,000	$212,000
Fire/Life Safety	10	18	8	Fair	$18,000	$130,000
Windows	4	24	20	Good	$1,000	$97,000
Siding/Facade	4	25	21	Fair	$8,000	$91,000
Flooring	15	22	7	Fair	$26,000	$28,000
Appliances	8	20	12	Fair	$19,000	$134,000
Landscaping	2	27	25	Fair	$14,000	$213,000
Pool/Amenity	19	34	15	Poor	$37,000	$265,000
Signage	15	19	4	Fair	$23,000	$21,000
Fencing	8	23	15	Good	$39,000	$8,000
Roof (2)	16	39	23	Poor	$27,000	$8,000
Paving (2)	5	35	30	Poor	$8,000	$121,000
HVAC (2)	19	19	0	Good	$31,000	$60,000
Plumbing (2)	10	29	19	Good	$36,000	$155,000
Electrical (2)	11	35	24	Fair	$4,000	$75,000
Elevators (2)	4	37	33	Fair	$12,000	$133,000
Fire/Life Safety (2)	15	26	11	Fair	$15,000	$62,000
Windows (2)	25	25	0	Fair	$27,000	$3,000
Siding/Facade (2)	8	13	5	Good	$6,000	$209,000
Flooring (2)	28	28	0	Good	$27,000	$55,000
Appliances (2)	22	25	3	Fair	$26,000	$44,000
Landscaping (2)	1	11	10	Poor	$31,000	$12,000
Pool/Amenity (2)	6	10	4	Fair	$32,000	$28,000
Signage (2)	29	34	5	Good	$22,000	$209,000
Fencing (2)	6	28	22	Good	$31,000	$50,000

Report generated 10/14/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Findings and Opinions of Cost

Item	Location	Observed Condition	Recommended Action	Priority	Est. Cost
Stair treads	Mechanical	Worn / loose	Replace treads	Reserve	$36,500
Asphalt paving	Bldg B	Alligator cracking	Mill and overlay	Reserve	$8,500
Window sealant	Common	Failed	Re-caulk	Year 1	$78,000
Fire extinguishers	Site	Expired tags	Service	Year 1	$80,500
Window sealant	Mechanical	Failed	Re-caulk	Year 2-5	$22,000
Roof membrane	Common	Ponding / seams	Re-seal and repair	Year 1	$19,000
Sidewalk	Roof	Trip hazards	Grind / replace	Reserve	$75,000
Dumpster enclosure	Bldg B	Damaged gate	Repair	Reserve	$32,500
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Immediate	$43,500
Asphalt paving	Common	Alligator cracking	Mill and overlay	Year 2-5	$58,500
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Immediate	$28,500
Stair treads	Bldg A	Worn / loose	Replace treads	Year 2-5	$84,000
Sprinkler heads	Bldg A	Painted heads	Replace	Immediate	$74,000
Dumpster enclosure	Bldg B	Damaged gate	Repair	Reserve	$26,000
Sidewalk	Roof	Trip hazards	Grind / replace	Reserve	$28,000
Fire extinguishers	Bldg A	Expired tags	Service	Year 2-5	$75,000
HVAC unit	Roof	Beyond useful life	Replace RTU	Immediate	$85,500
Water heater	Common	Corrosion	Replace	Immediate	$51,500
Stair treads	Mechanical	Worn / loose	Replace treads	Year 2-5	$65,000
Stair treads	Roof	Worn / loose	Replace treads	Reserve	$59,000
Water heater	Roof	Corrosion	Replace	Reserve	$51,500
Asphalt paving	Bldg A	Alligator cracking	Mill and overlay	Immediate	$37,500
Asphalt paving	Common	Alligator cracking	Mill and overlay	Year 2-5	$38,000
Dumpster enclosure	Common	Damaged gate	Repair	Year 1	$11,000
Dumpster enclosure	Common	Damaged gate	Repair	Immediate	$81,500
Fire extinguishers	Site	Expired tags	Service	Immediate	$86,000
Fire extinguishers	Site	Expired tags	Service	Year 2-5	$85,500
HVAC unit	Site	Beyond useful life	Replace RTU	Reserve	$48,000
Sidewalk	Roof	Trip hazards	Grind / replace	Year 1	$31,500
Water heater	Bldg A	Corrosion	Replace	Year 1	$53,000
Handrail	Site	Loose	Secure	Reserve	$16,500
Roof membrane	Mechanical	Ponding / seams	Re-seal and repair	Year 2-5	$11,000
Asphalt paving	Bldg A	Alligator cracking	Mill and overlay	Immediate	$1,500
Handrail	Mechanical	Loose	Secure	Immediate	$49,000
Fire extinguishers	Roof	Expired tags	Service	Year 1	$42,000
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Reserve	$500
Roof membrane	Roof	Ponding / seams	Re-seal and repair	Reserve	$57,500
Fire extinguishers	Roof	Expired tags	Service	Year 2-5	$34,000
Fire extinguishers	Site	Expired tags	Service	Immediate	$80,000
Sprinkler heads	Mechanical	Painted heads	Replace	Immediate	$27,500
Dumpster enclosure	Site	Damaged gate	Repair	Immediate	$72,500
Sprinkler heads	Roof	Painted heads	Replace	Immediate	$9,000

Report generated 10/14/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Recommendations

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 15 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $362,000. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Elevators were last modernized 11 years ago and are operating without deficiency. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $218,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 45 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Recommendations

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $136,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Elevators were last modernized 6 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $168,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 34 months.

Recommendations

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 12 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $154,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 3 months. Elevators were last modernized 3 years ago and are operating without deficiency.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Improvements Description

Common area interiors have been refreshed within the last 12 years and are in average to good condition. Weighted average lease term remaining is 3 years and in-place rents average $26 per square foot, full service gross. The roof is a 43-year membrane system with an estimated remaining useful life of 9 years. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The building features a renovated lobby, structured parking at a ratio of 11 per 1,000 square feet, and a tenant lounge with fitness center.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The building features a renovated lobby, structured parking at a ratio of 39 per 1,000 square feet, and a tenant lounge with fitness center. Floor plates are efficient and column-spacing supports open and private-office layouts. Glenview Plaza was originally constructed in 1973 and consists of 251,000 SF in a building of 36 stories.

Recommendations

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 7 months. Elevators were last modernized 10 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $107,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $209,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 8 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Construction Details

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The building features a renovated lobby, structured parking at a ratio of 15 per 1,000 square feet, and a tenant lounge with fitness center. Mechanical systems include rooftop package units and central plant equipment of varying age. The building is served by redundant elevators, a backup generator and a high-efficiency chiller plant. The roof is a 12-year membrane system with an estimated remaining useful life of 9 years.

Weighted average lease term remaining is 5 years and in-place rents average $26 per square foot, full service gross. The building is served by redundant elevators, a backup generator and a high-efficiency chiller plant. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The roof is a 23-year membrane system with an estimated remaining useful life of 12 years.

Observed Conditions

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $329,000. Elevators were last modernized 8 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Elevators were last modernized 8 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $171,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Construction Details

The building is served by redundant elevators, a backup generator and a high-efficiency chiller plant. Mechanical systems include rooftop package units and central plant equipment of varying age. Common area interiors have been refreshed within the last 3 years and are in average to good condition. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Weighted average lease term remaining is 4 years and in-place rents average $26 per square foot, full service gross. The building features a renovated lobby, structured parking at a ratio of 34 per 1,000 square feet, and a tenant lounge with fitness center. Mechanical systems include rooftop package units and central plant equipment of varying age.

Recommendations

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	5	23	18	Fair	$20,000	$162,000
Paving	16	23	7	Good	$28,000	$152,000
HVAC	21	26	5	Fair	$30,000	$46,000
Plumbing	8	32	24	Good	$36,000	$140,000
Electrical	15	25	10	Poor	$24,000	$124,000
Elevators	9	37	28	Fair	$22,000	$249,000
Fire/Life Safety	17	20	3	Fair	$23,000	$232,000
Windows	2	38	36	Poor	$23,000	$202,000
Siding/Facade	26	29	3	Fair	$36,000	$127,000
Flooring	18	22	4	Poor	$13,000	$111,000
Appliances	26	34	8	Good	$13,000	$32,000
Landscaping	17	37	20	Good	$14,000	$155,000
Pool/Amenity	33	38	5	Fair	$26,000	$99,000
Signage	5	16	11	Fair	$18,000	$214,000
Fencing	11	31	20	Poor	$26,000	$69,000
Roof (2)	38	39	1	Fair	$39,000	$258,000
Paving (2)	21	28	7	Poor	$11,000	$113,000
HVAC (2)	39	40	1	Poor	$13,000	$154,000
Plumbing (2)	20	38	18	Good	$21,000	$77,000
Electrical (2)	2	15	13	Fair	$25,000	$3,000
Elevators (2)	23	37	14	Poor	$36,000	$51,000
Fire/Life Safety (2)	24	26	2	Good	$32,000	$51,000
Windows (2)	27	38	11	Good	$17,000	$169,000
Siding/Facade (2)	21	34	13	Poor	$6,000	$2,000
Flooring (2)	28	37	9	Fair	$28,000	$89,000
Appliances (2)	17	26	9	Poor	$9,000	$83,000
Landscaping (2)	16	23	7	Fair	$28,000	$187,000
Pool/Amenity (2)	13	23	10	Fair	$20,000	$98,000
Signage (2)	19	26	7	Good	$25,000	$147,000
Fencing (2)	6	18	12	Good	$17,000	$248,000

Report generated 10/14/2018. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Certification

I certify that, to the best of my knowledge and belief, the statements of fact contained in this report are true and correct and that I have no present or prospective interest in Glenview Plaza and no personal interest with respect to the parties involved.

The analyses, opinions and conclusions are limited only by the reported assumptions and limiting conditions. The inspection of the property was performed on September 19, 2018.

Rachel Ramirez, MAI

Keystone Building Consultants

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only