PROPERTY CONDITION ASSESSMENT

Granite Apartments | Richmond, VA

Property	Granite Apartments
Address	3686 Industrial Way, Richmond, VA 60296
Site Visit Date	June 24, 2021
Client	Tidewater Core Fund
Immediate Repairs	$367,000

Construction Details

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Average in-place rent is $1,915 per month against an average unit size of 997 square feet. Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes. Resident turnover has averaged 6.2% annually with renewal retention above 90.9%. Mechanical systems include rooftop package units and central plant equipment of varying age.

Mechanical systems include rooftop package units and central plant equipment of varying age. Granite Apartments was originally constructed in 1971 and consists of 235 apartment homes in a building of 17 stories. Average in-place rent is $1,915 per month against an average unit size of 997 square feet. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

Observed Conditions

Elevators were last modernized 7 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 46 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $109,000.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Elevators were last modernized 3 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $37,000.

Building Systems

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Resident turnover has averaged 12.2% annually with renewal retention above 94.5%. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes.

Mechanical systems include rooftop package units and central plant equipment of varying age. Resident turnover has averaged 8.0% annually with renewal retention above 95.1%. Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes. Granite Apartments was originally constructed in 1971 and consists of 235 apartment homes in a building of 21 stories.

Recommendations

Elevators were last modernized 5 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 43 months. Elevators were last modernized 7 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Construction Details

Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Common area interiors have been refreshed within the last 8 years and are in average to good condition. Granite Apartments was originally constructed in 1971 and consists of 235 apartment homes in a building of 13 stories.

The community offers a resort-style pool, fitness center, resident clubhouse, package lockers and a dog park. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The roof is a 5-year membrane system with an estimated remaining useful life of 8 years. Unit interiors feature quartz countertops, stainless appliances, in-unit washer and dryer and plank flooring in select renovated homes.

Observed Conditions

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Elevators were last modernized 9 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 22 months.

Elevators were last modernized 9 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 16 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $467,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Improvements Description

Granite Apartments was originally constructed in 1971 and consists of 235 apartment homes in a building of 26 stories. Average in-place rent is $1,915 per month against an average unit size of 997 square feet. Mechanical systems include rooftop package units and central plant equipment of varying age. Resident turnover has averaged 4.0% annually with renewal retention above 95.9%.

Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The community offers a resort-style pool, fitness center, resident clubhouse, package lockers and a dog park. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Mechanical systems include rooftop package units and central plant equipment of varying age. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

Deferred Maintenance

Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $470,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Elevators were last modernized 4 years ago and are operating without deficiency. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $465,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 27 months.

Improvements Description

Average in-place rent is $1,915 per month against an average unit size of 997 square feet. Mechanical systems include rooftop package units and central plant equipment of varying age. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The roof is a 5-year membrane system with an estimated remaining useful life of 3 years. Granite Apartments was originally constructed in 1971 and consists of 235 apartment homes in a building of 3 stories.

Mechanical systems include rooftop package units and central plant equipment of varying age. Granite Apartments was originally constructed in 1971 and consists of 235 apartment homes in a building of 9 stories. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Average in-place rent is $1,915 per month against an average unit size of 997 square feet.

Recommendations

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	13	27	14	Good	$40,000	$151,000
Paving	14	18	4	Fair	$18,000	$111,000
HVAC	5	34	29	Good	$36,000	$184,000
Plumbing	32	40	8	Fair	$25,000	$26,000
Electrical	7	30	23	Fair	$17,000	$156,000
Elevators	5	27	22	Fair	$0	$8,000
Fire/Life Safety	5	40	35	Fair	$12,000	$123,000
Windows	9	10	1	Poor	$26,000	$24,000
Siding/Facade	7	22	15	Fair	$1,000	$127,000
Flooring	8	19	11	Fair	$27,000	$92,000
Appliances	6	24	18	Fair	$21,000	$101,000
Landscaping	2	19	17	Fair	$8,000	$279,000
Pool/Amenity	1	11	10	Fair	$8,000	$190,000
Signage	10	34	24	Fair	$27,000	$193,000
Fencing	9	29	20	Fair	$39,000	$150,000
Roof (2)	1	30	29	Fair	$24,000	$203,000
Paving (2)	20	21	1	Fair	$38,000	$123,000
HVAC (2)	7	13	6	Fair	$39,000	$169,000
Plumbing (2)	14	16	2	Fair	$1,000	$156,000
Electrical (2)	1	37	36	Poor	$26,000	$235,000
Elevators (2)	8	11	3	Poor	$19,000	$215,000
Fire/Life Safety (2)	13	19	6	Fair	$4,000	$42,000
Windows (2)	21	32	11	Fair	$0	$175,000
Siding/Facade (2)	17	40	23	Good	$37,000	$205,000
Flooring (2)	10	33	23	Fair	$21,000	$44,000
Appliances (2)	27	29	2	Poor	$9,000	$19,000
Landscaping (2)	23	25	2	Good	$32,000	$53,000
Pool/Amenity (2)	14	19	5	Good	$3,000	$200,000
Signage (2)	10	23	13	Poor	$17,000	$43,000
Fencing (2)	12	23	11	Good	$11,000	$178,000

Report generated 06/24/2021. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only