PROPERTY CONDITION ASSESSMENT

Birchwood Collegiate Commons | Oklahoma City, OK

Property	Birchwood Collegiate Commons
Address	1498 Station Court, Oklahoma City, OK 82558
Site Visit Date	September 1, 2023
Client	Granite Lane Realty
Immediate Repairs	$242,000

Improvements Description

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Birchwood Collegiate Commons was originally constructed in 1969 and consists of 354 beds in a building of 7 stories. Mechanical systems include rooftop package units and central plant equipment of varying age.

Birchwood Collegiate Commons was originally constructed in 1969 and consists of 354 beds in a building of 9 stories. The roof is a 23-year membrane system with an estimated remaining useful life of 6 years. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Pre-leasing for the coming academic year stands at 95.9% with rental rates per bed averaging $1,218. Mechanical systems include rooftop package units and central plant equipment of varying age. The community is leased by the bed on individual lease liability with parent guaranties and furnished units.

Observed Conditions

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 15 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $205,000. Elevators were last modernized 12 years ago and are operating without deficiency.

The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $383,000.

Building Systems

The community is leased by the bed on individual lease liability with parent guaranties and furnished units. The roof is a 5-year membrane system with an estimated remaining useful life of 9 years. The property is located 5 blocks from the main campus with a dedicated shuttle serving fall and spring terms. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Birchwood Collegiate Commons was originally constructed in 1969 and consists of 354 beds in a building of 42 stories.

The community is leased by the bed on individual lease liability with parent guaranties and furnished units. The property is located 8 blocks from the main campus with a dedicated shuttle serving fall and spring terms. Amenities include study lounges, a rooftop terrace, 24-hour fitness and a game room. The roof is a 23-year membrane system with an estimated remaining useful life of 4 years. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

Deferred Maintenance

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 11 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only