PROPERTY CONDITION ASSESSMENT

Heritage Scholars Hall | Columbus, OH

Property	Heritage Scholars Hall
Address	9271 Medical Center Drive, Columbus, OH 14447
Site Visit Date	April 4, 2023
Client	Anchorage Meadow Partners
Immediate Repairs	$306,000

Building Systems

Mechanical systems include rooftop package units and central plant equipment of varying age. Common area interiors have been refreshed within the last 12 years and are in average to good condition. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The property is located 2 blocks from the main campus with a dedicated shuttle serving fall and spring terms. The roof is a 3-year membrane system with an estimated remaining useful life of 12 years. Mechanical systems include rooftop package units and central plant equipment of varying age.

Observed Conditions

Domestic water piping is copper and PVC with no evidence of widespread leakage. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 19 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $425,000. Elevators were last modernized 7 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $150,000. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 12 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 3 months.

Improvements Description

Pre-leasing for the coming academic year stands at 89.2% with rental rates per bed averaging $1,299. Common area interiors have been refreshed within the last 10 years and are in average to good condition. Heritage Scholars Hall was originally constructed in 1972 and consists of 173 beds in a building of 31 stories. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition.

Mechanical systems include rooftop package units and central plant equipment of varying age. Amenities include study lounges, a rooftop terrace, 24-hour fitness and a game room. Pre-leasing for the coming academic year stands at 96.3% with rental rates per bed averaging $1,299. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation.

Recommendations

Elevators were last modernized 10 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 44 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $22,000.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Building Systems

The property is located 2 blocks from the main campus with a dedicated shuttle serving fall and spring terms. Amenities include study lounges, a rooftop terrace, 24-hour fitness and a game room. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Mechanical systems include rooftop package units and central plant equipment of varying age.

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The property is located 4 blocks from the main campus with a dedicated shuttle serving fall and spring terms. Heritage Scholars Hall was originally constructed in 1972 and consists of 173 beds in a building of 14 stories. Amenities include study lounges, a rooftop terrace, 24-hour fitness and a game room. Mechanical systems include rooftop package units and central plant equipment of varying age.

Deferred Maintenance

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 15 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $142,000. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $65,000. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Building Systems

Mechanical systems include rooftop package units and central plant equipment of varying age. Amenities include study lounges, a rooftop terrace, 24-hour fitness and a game room. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Common area interiors have been refreshed within the last 9 years and are in average to good condition.

Pre-leasing for the coming academic year stands at 95.0% with rental rates per bed averaging $1,299. The community is leased by the bed on individual lease liability with parent guaranties and furnished units. The property is located 5 blocks from the main campus with a dedicated shuttle serving fall and spring terms. Common area interiors have been refreshed within the last 11 years and are in average to good condition. The roof is a 24-year membrane system with an estimated remaining useful life of 10 years.

Recommendations

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 11 years ago and are operating without deficiency. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 25 months. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 19 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Elevators were last modernized 12 years ago and are operating without deficiency. Domestic water piping is copper and PVC with no evidence of widespread leakage. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Construction Details

The property is located 6 blocks from the main campus with a dedicated shuttle serving fall and spring terms. The roof is a 22-year membrane system with an estimated remaining useful life of 11 years. Mechanical systems include rooftop package units and central plant equipment of varying age. Exterior finishes comprise brick veneer, fiber-cement siding and aluminum storefront glazing in good condition. Heritage Scholars Hall was originally constructed in 1972 and consists of 173 beds in a building of 4 stories.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	16	17	1	Fair	$31,000	$100,000
Paving	3	20	17	Fair	$17,000	$159,000
HVAC	1	21	20	Good	$25,000	$43,000
Plumbing	17	26	9	Fair	$6,000	$144,000
Electrical	5	27	22	Poor	$30,000	$98,000
Elevators	32	35	3	Poor	$25,000	$98,000
Fire/Life Safety	3	36	33	Good	$29,000	$39,000
Windows	5	13	8	Fair	$23,000	$252,000
Siding/Facade	2	16	14	Fair	$18,000	$180,000
Flooring	12	21	9	Poor	$18,000	$143,000
Appliances	16	21	5	Poor	$35,000	$133,000
Landscaping	6	19	13	Fair	$40,000	$69,000
Pool/Amenity	10	22	12	Poor	$6,000	$45,000
Signage	5	10	5	Fair	$15,000	$49,000
Fencing	4	13	9	Fair	$5,000	$174,000
Roof (2)	19	39	20	Fair	$37,000	$40,000
Paving (2)	16	22	6	Fair	$8,000	$197,000
HVAC (2)	2	28	26	Good	$23,000	$274,000
Plumbing (2)	24	30	6	Fair	$29,000	$89,000
Electrical (2)	6	22	16	Fair	$25,000	$58,000
Elevators (2)	21	29	8	Good	$29,000	$70,000
Fire/Life Safety (2)	23	40	17	Fair	$10,000	$230,000
Windows (2)	10	10	0	Fair	$12,000	$224,000
Siding/Facade (2)	8	10	2	Good	$7,000	$149,000
Flooring (2)	3	39	36	Fair	$19,000	$12,000
Appliances (2)	2	12	10	Poor	$7,000	$63,000
Landscaping (2)	21	34	13	Good	$40,000	$171,000
Pool/Amenity (2)	14	22	8	Poor	$14,000	$201,000
Signage (2)	3	35	32	Poor	$18,000	$92,000
Fencing (2)	13	35	22	Poor	$15,000	$76,000

Report generated 04/04/2023. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Findings and Opinions of Cost

Item	Location	Observed Condition	Recommended Action	Priority	Est. Cost
Stair treads	Bldg A	Worn / loose	Replace treads	Reserve	$50,000
HVAC unit	Bldg A	Beyond useful life	Replace RTU	Year 1	$76,000
Fire extinguishers	Bldg B	Expired tags	Service	Year 1	$77,000
Dumpster enclosure	Bldg B	Damaged gate	Repair	Reserve	$4,500
Water heater	Site	Corrosion	Replace	Year 2-5	$88,500
Handrail	Bldg A	Loose	Secure	Immediate	$81,000
Water heater	Bldg B	Corrosion	Replace	Year 2-5	$66,500
Roof membrane	Bldg B	Ponding / seams	Re-seal and repair	Immediate	$13,000
Asphalt paving	Roof	Alligator cracking	Mill and overlay	Year 2-5	$34,500
Roof membrane	Site	Ponding / seams	Re-seal and repair	Year 2-5	$42,500
Dumpster enclosure	Common	Damaged gate	Repair	Year 1	$50,000
Handrail	Site	Loose	Secure	Year 1	$87,000
Fire extinguishers	Mechanical	Expired tags	Service	Immediate	$40,500
Water heater	Mechanical	Corrosion	Replace	Reserve	$81,000
Dumpster enclosure	Site	Damaged gate	Repair	Immediate	$5,000
Window sealant	Site	Failed	Re-caulk	Year 2-5	$21,500
Fire extinguishers	Roof	Expired tags	Service	Year 2-5	$53,500
Fire extinguishers	Mechanical	Expired tags	Service	Year 2-5	$24,000
Stair treads	Bldg A	Worn / loose	Replace treads	Year 1	$24,000
Roof membrane	Mechanical	Ponding / seams	Re-seal and repair	Year 2-5	$51,000
Dumpster enclosure	Bldg B	Damaged gate	Repair	Reserve	$2,000
Window sealant	Common	Failed	Re-caulk	Immediate	$28,000
Asphalt paving	Bldg A	Alligator cracking	Mill and overlay	Reserve	$85,500
Window sealant	Roof	Failed	Re-caulk	Immediate	$23,000
Window sealant	Bldg A	Failed	Re-caulk	Immediate	$72,000
Handrail	Common	Loose	Secure	Year 2-5	$6,500
Handrail	Bldg A	Loose	Secure	Year 1	$25,500
Handrail	Mechanical	Loose	Secure	Year 2-5	$81,500
Sidewalk	Bldg B	Trip hazards	Grind / replace	Reserve	$10,500
Window sealant	Site	Failed	Re-caulk	Year 1	$13,500
Handrail	Bldg A	Loose	Secure	Immediate	$86,000
Fire extinguishers	Bldg A	Expired tags	Service	Reserve	$80,500
Stair treads	Site	Worn / loose	Replace treads	Immediate	$10,500
HVAC unit	Site	Beyond useful life	Replace RTU	Year 1	$34,000
Sidewalk	Roof	Trip hazards	Grind / replace	Immediate	$66,000
Fire extinguishers	Common	Expired tags	Service	Reserve	$41,500
Stair treads	Bldg A	Worn / loose	Replace treads	Year 2-5	$71,000
HVAC unit	Roof	Beyond useful life	Replace RTU	Reserve	$46,500
Stair treads	Bldg A	Worn / loose	Replace treads	Year 2-5	$56,000
Roof membrane	Site	Ponding / seams	Re-seal and repair	Reserve	$78,000
Water heater	Site	Corrosion	Replace	Reserve	$68,000

Report generated 04/04/2023. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Observed Conditions

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 2 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $366,000. Elevators were last modernized 6 years ago and are operating without deficiency.

Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 4 years ago and are operating without deficiency. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Recommendations

Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $252,000. Elevators were last modernized 6 years ago and are operating without deficiency. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 45 months.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 35 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage.

Recommendations

Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 46 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Domestic water piping is copper and PVC with no evidence of widespread leakage. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $207,000.

Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $119,000. Domestic water piping is copper and PVC with no evidence of widespread leakage. Electrical service is adequate for current demand; select panels are nearing the end of their useful life.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Building Systems

The roof is a 31-year membrane system with an estimated remaining useful life of 6 years. Pre-leasing for the coming academic year stands at 93.5% with rental rates per bed averaging $1,299. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Heritage Scholars Hall was originally constructed in 1972 and consists of 173 beds in a building of 14 stories.

The community is leased by the bed on individual lease liability with parent guaranties and furnished units. Amenities include study lounges, a rooftop terrace, 24-hour fitness and a game room. Common area interiors have been refreshed within the last 11 years and are in average to good condition. Heritage Scholars Hall was originally constructed in 1972 and consists of 173 beds in a building of 31 stories.

Recommendations

Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 4 years ago and are operating without deficiency. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

Elevators were last modernized 12 years ago and are operating without deficiency. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 6 months. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months.

Construction Details

The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Pre-leasing for the coming academic year stands at 92.0% with rental rates per bed averaging $1,299. The property is located 2 blocks from the main campus with a dedicated shuttle serving fall and spring terms. The community is leased by the bed on individual lease liability with parent guaranties and furnished units. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. Mechanical systems include rooftop package units and central plant equipment of varying age.

Amenities include study lounges, a rooftop terrace, 24-hour fitness and a game room. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. Pre-leasing for the coming academic year stands at 97.0% with rental rates per bed averaging $1,299. Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting.

Observed Conditions

Elevators were last modernized 12 years ago and are operating without deficiency. The roofing system exhibits localized ponding and sealant deterioration; spot repairs are recommended within 12 months. Electrical service is adequate for current demand; select panels are nearing the end of their useful life. ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $450,000. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 33 months. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations.

ADA observations include non-compliant slopes at two accessible routes and signage at parking; cost to cure is estimated at $304,000. Windows and exterior doors are in fair condition; sealant replacement is recommended at selected locations. Domestic water piping is copper and PVC with no evidence of widespread leakage. Elevators were last modernized 6 years ago and are operating without deficiency. Asphalt paving shows alligator cracking and should be sealcoated and restriped during the next 6 months.

Improvements Description

Life-safety systems include a fully sprinklered building, addressable fire alarm panel and emergency lighting. The community is leased by the bed on individual lease liability with parent guaranties and furnished units. The structure is of wood-frame, masonry and steel-frame construction on a slab-on-grade foundation. The roof is a 4-year membrane system with an estimated remaining useful life of 11 years.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Immediate Repairs and Replacement Reserve Schedule

System	Age (yrs)	EUL	RUL	Condition	Immediate	Reserve (10-yr)
Roof	3	16	13	Fair	$26,000	$241,000
Paving	15	37	22	Fair	$40,000	$132,000
HVAC	1	15	14	Poor	$30,000	$106,000
Plumbing	3	22	19	Poor	$22,000	$132,000
Electrical	5	12	7	Poor	$5,000	$103,000
Elevators	11	21	10	Fair	$39,000	$253,000
Fire/Life Safety	10	29	19	Fair	$13,000	$203,000
Windows	4	23	19	Fair	$30,000	$28,000
Siding/Facade	3	31	28	Fair	$18,000	$130,000
Flooring	11	33	22	Good	$24,000	$99,000
Appliances	4	14	10	Poor	$32,000	$61,000
Landscaping	9	26	17	Poor	$26,000	$200,000
Pool/Amenity	24	34	10	Fair	$9,000	$189,000
Signage	6	36	30	Good	$22,000	$74,000
Fencing	12	31	19	Fair	$9,000	$255,000
Roof (2)	11	15	4	Good	$39,000	$7,000
Paving (2)	6	11	5	Fair	$6,000	$157,000
HVAC (2)	14	18	4	Good	$5,000	$172,000
Plumbing (2)	8	35	27	Fair	$40,000	$201,000
Electrical (2)	7	15	8	Good	$8,000	$47,000
Elevators (2)	9	28	19	Fair	$34,000	$7,000
Fire/Life Safety (2)	1	34	33	Poor	$9,000	$169,000
Windows (2)	30	37	7	Good	$3,000	$77,000
Siding/Facade (2)	1	39	38	Good	$16,000	$250,000
Flooring (2)	17	32	15	Poor	$26,000	$52,000
Appliances (2)	4	11	7	Poor	$28,000	$219,000
Landscaping (2)	1	20	19	Fair	$11,000	$69,000
Pool/Amenity (2)	9	40	31	Fair	$30,000	$155,000
Signage (2)	6	19	13	Good	$36,000	$117,000
Fencing (2)	2	39	37	Fair	$9,000	$139,000

Report generated 04/04/2023. Figures are unaudited and subject to change.

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only

Certification

I certify that, to the best of my knowledge and belief, the statements of fact contained in this report are true and correct and that I have no present or prospective interest in Heritage Scholars Hall and no personal interest with respect to the parties involved.

The analyses, opinions and conclusions are limited only by the reported assumptions and limiting conditions. The inspection of the property was performed on March 21, 2023.

_____

Tina Dixon, PE

Harmon & Pike Engineering

FICTITIOUS SAMPLE DOCUMENT — all names, figures and entities are invented for classroom training use only