

3mm PRESSED GALV STEEL TOP HAT MAX CANTALEVER 400mm. CANTALEVERS OVER 400mm REQUIRE 75x75x2 PRESSED GALV ANGLE SUPPORT FIXED AS PER BGP CALCS

PROCHECK FR200 VCL.
(BY OTHERS).

VARIES

SOFFIT PLANKS. REFER TO DRG'S FS-016, FS-017 FOR DETAILS.

2mm PRESSED ALUMINIUM SUPPORT / CLOSER ANGLE, PPC TO MATCH CLADDING, TEMP RIVITED TO EVERY PURLIN.

50mm DUO SLAB FIXED USING METAL FIXINGS ONLY, IN ACCORDANCE WITH IFS REQUIREMENTS

GENIUS PRIME PANEL, 3MM ALUMINIUM, FIXED TO 50mm HELPING HAND SYSTEM. PPC TO RAL 9006 METALLIC.

SINIAT WEATHER DEFENCE BOARD FIXED TO VERTICAL TOPHAT AS PER MANUFACTURERS RECOMMENDATIONS. JOINTS SEALED USING SINIAT G-TEC WEATHER DEFENCE TAPE.

SIDERISE RH25-60/60, FIXED AS PER MANUFACTURERS RECOMMENDATIONS AS PER PROJECT SPEC CLAUSE 440X. INSTALL LOCATIONS AS SPECIFIED BYIFC (INTERNATIONAL FIRE CONSULTANTS) DATED 26TH MARCH 2021

FAST FRAME HELPING HAND SYSTEM FIXED TO GALV STEEL CHANNEL. CHANNEL FIXED AT TOPHAT LOCATIONS IN ACCORDANCE WITH FASTFRAME CALCS V7

PRESSED 3mm GALV STEEL TOP HAT FIXED TO HORIZONTAL SFS AS PER BGP DESIGN AND CALCULATIONS FOR BACKUP WALL

VERTICAL CAVITY BARRIERS
OMITTED FOR CLARITY

PRESSED 3mm GALV STEEL TOP HAT FIXED TO HORIZONTAL SFS AS PER BGP DESIGN AND CALCULATIONS FOR BACKUP WALL

CLADSEAL EPDM BONDED TO CP BOARD USING CLADSEAL FACADE PASTE ADHESIVE AND TAKEN DOWN ON TO FLASHING

ALL PANELS TO HAVE 6x25 DRAINAGE SLOTS - ONE IN EACH CORNER AND ONE IN CENTRE.

EXISTING NON ACM CILL SECTION RETAINED AND OVER CLAD WITH NEW 2mm ALUMINIUM PPC CILL TO MATCH PANELS RAL 9006 TO CLADDING AREAS

AS BUILT 19/11/21

C01	CONSTRUCTION ISSUE	RM	28/10/21
P03	UPDATED AS PER WINTech COMMENTS 16/09/21	RM	23/09/21
P02	EDPM AND INSUL'N FIXING NOTES ADDED	RM	03/09/21
P01	FIRST ISSUE	RM	02/09/21
Rev	Description	By	Date
<div><div><div><div>AJ Cladding LTD</div><div>Architectural Cladding Specialists</div></div><div><div>19A Wilson Street, Hamilton, ML3 0NH</div><div>+44 (0) 1698 339 104 ajcladding.co.uk info@ajcladding.co.uk</div></div></div></div>			
Drawn By	RM	Date Created	02/09/21
Contract No.	2020		
Contract Title	20:20 HOUSE		
Drawing Title	FIRE STRATEGY TYPICAL SECTION		
Drawing No.	2020-PHO2-DET-003	Rev	C01