
Internal Rate of Return (IRR)
Cost effective impact: 66.2 TBtu
1 (R) Best 120V HP Dryer TS
2 (R) ESTAR HPWH TS
3 (R) Ref. NG Furnace & AC & Env.
4 (R) ES HP FS (NG Frn.) & Env.
5 (C) ES HP FS (RTU, NG Ht.) & Env.
IRR (%)
2050 Site Energy Savings (Competed, TBtu)
Simple Payback
Cost effective impact: 133.3 TBtu
1 (R) Brk. HP FS (NG Frn.) & Env.++
2 (R) Brk. HPWH FS
3 (R) Best 120V HP Dryer TS
4 (R) Brk. HP FS (NG Furnace)
5 (R) Ref. NG Furnace & AC & Env.
Payback (years)
2050 Site Energy Savings (Competed, TBtu)
Cost of Conserved Energy (CCE)
Cost effective impact: 117.9 TBtu
1 (R) Brk. HP FS (NG Frn.) & Env.++
2 (R) Brk. HPWH FS
3 (R) Brk. HP FS (NG Furnace)
4 (R) Ref. NG Furnace & AC & Env.
5 (R) ES HP FS (NG Frn.) & Env.
CCE ($/MMBtu saved)
2050 Site Energy Savings (Competed, TBtu)
Cost of Conserved CO_2 (CCC)
Cost effective impact: 102.6 TBtu
1 (R) Brk. HP FS (NG Frn.) & Env.++
2 (R) Brk. HPWH FS
3 (R) Brk. HP FS (NG Furnace)
4 (R) Ref. NG Furnace & AC & Env.
5 (C) ES HP FS (RTU, NG Ht.) & Env.
CCC ($/t CO_2 avoided)
2050 Site Energy Savings (Competed, TBtu)