FIRE DRILL & EVACUATION REPORT

Specialised Treatment Centre — Doha, Qatar — Security & Safety Printed: 2026-10-11

Report	SEC-FD-2026-09
Date	30 September 2026
Areas	Wards A–C, rehabilitation wing

A scheduled **fire drill** was carried out. Full **evacuation** of the wards completed in 6 minutes 40 seconds. **CCTV** review confirmed that fire doors were closed and the assembly points were reached. One **access card** reader on the east exit did not release and has been referred to the facilities team.

Confidential — for the addressee only