HVAC MAINTENANCE & CALIBRATION LOG

Specialised Treatment Centre — Doha, Qatar — Facilities Printed: 2026-10-26

Log FAC-HVAC-2026-Q3
Period July – September 2026
Vendor CoolAir Services

Quarterly **maintenance** of the **HVAC** units serving theatres and isolation rooms was completed by the **vendor**. Temperature and humidity sensors were **calibration**-checked against the reference instrument and found within tolerance.

Unit	Area	Result
AHU-03	Theatre 1	Pass
AHU-07	Isolation rooms	Pass
FCU-22	Pharmacy store	Filter replaced

Confidential — for the addressee only