

### 03.119 TCCS Auxiliary Fan Deactivation

(03. HSS)

#### OBJECTIVE:

To deactivate the auxiliary cabin fans on the Trace Contaminant Control Subassembly (TCCS) panel.

#### NOTE

The TCCS auxiliary (aux) fans do not have variable speeds. They are used to increase air flow throughout the habitat during off-nominal operations.

GMWS

#### 1. TURN OFF AUX FANS ON HSS

1.1. Access the HSS interface on Surface Pro

1.2. Select the CDRA display

1.3. Hover over Aux Fan 1

1.3.1. Press finger to Aux fan one, the fan on the display should stop moving

1.4. Hover over Aux fan 2

1.4.1. Press finger to Aux fan two, the fan on the display should stop moving

#### 2. DEACTIVATE TCCS AUX FAN 1 AND FAN 2



**Figure 1.** Trace Contaminant Control Subassembly (TCCS) Panel

2.1. On the TCCS Panel, flip the power switch of Aux Cabin Fan 1 to “OFF” (see Figure 1).

2.2. On the TCCS Panel, flip the power switch of Aux Cabin Fan 2 to “OFF” (see Figure 1).