

AMENDED ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 3567-999KAF Issue Date: August 6, 2013

The Corporation of the Township of Huron-Kinloss 21 Queen St Ripley, P.O. Box 130

Huron-Kinloss, Ontario

N0G 2R0

Site Location: Lucknow Sewage Treatment Facility

Lot 53, 54, 55, Concession 1, Former Kinloss Twp.

Huron-Kinloss Township, County of Bruce

You have applied under section 20.2 of Part II.1 of the <u>Environmental Protection Act</u>, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

the establishment of municipal sewage treatment works for the collection, transmission, treatment and disposal of domestic sewage with with a *Rated Capacity* of 750 cubic metres per day, consisting of the following:

Sanitary Sewers

- sanitary sewers on Napier Street, William Street, Ludgard Street, Gough Street, Rose Street, Hamilton Street, Wheeler Street, Hays Street, Welsley Street, Campbell Street, Willoughby Street, Stauffer Street, Havelock Street, North Delhi Street, Inglis Street, Outram Street, Victoria Street, Alberta Street, Ross Street, Palmerston Street, Clyde Street, Canning Street, South Delhi Street, Bob Street, Elgin Street, and Walter Street;

Sewage Pumping Station

- a sanitary sewage pumping station located on Mill Site No. 3 at the South end of the southern extension of Inglis Street and consisting of a 4.70 m x 2.10 m x 10.83 m deep wet well equipped with three (3) pumps, one (1) pump rated at 8.68 L/s at 44.6 m TDH and two (2) pumps each rated at 32.5 L/s at 44.6 m TDH;
- approximately 2,600 m of 200 mm diameter forcemain along Inglis Street, Willoughby Street, Bob Street, Campbell Street and Highway No. 86, Kinloss Township Street and Access Road to sewage treatment facility;

Sewage Treatment Facility

- a three-cell aerated facultative lagoon system, with each cell having bottom dimensions of 53.7 m x 21.0 m, top-of-berm dimensions of 83.0 m x 55.3 m and total depth of 4.9 m (including 0.9 m freeboard), providing a total volume of approximately 32,000 m³;
- five (5) single-speed mechanical surface aerators, two (2) aerators in Cell No. 1, two (2) in Cell No. 2 and one (1) in Cell No. 3;
- a emergency bypass forcemain discharging raw sewage into the emergency storage lagoon having a total depth of 3.6 m (including 0.6 m freeboard) and a total operating volume of 67,500 m³;
- inlet, transfer and outlet structures and pipings;
- chemical system for phosphorus removal consisting of one (1) 27.0 m³ volume chemical storage tank, two (2) metering pumps (one standby) each rated at 30 L/h and two (2) feed lines, one discharging into the aerated facultative lagoon inlet structure and the other into the transfer structure between Cells No. 1 and 2;
- one (1) effluent pumping station equipped with two (2) pumps (one standby), each rated at 11.6 L/s and a forcemain discharging to the distribution chamber upstream of the rapid infiltration basins or into the emergency storage lagoon;

Aerated Lagoon Effluent Disposal Facility

a rapid infiltration facility to dispose of the aerated lagoon effluent at a maximum daily flow rate of 1,000 m³/d, consisting six (6) infiltration basins, each having bottom dimensions of 10.0 m x 7.0 m, top-of-berm dimensions of 16.0 m x 13.0 m, and total depth of 1.0 m and associated distribution structures, piping and appurtenances;

Contingency Groundwater Interceptor System

- an effluent groundwater interceptor system, as a contingency system to be constructed when necessary, located along the Southern part of the Western boundary of the treatment facility and approximately 300 m of interceptor sewer, including manholes and one (1) submersible pump rated at 10 L/s at a TDH of 5 m, installed in one of the manholes;
- all other controls, electrical equipment, instrumentation, piping, pumps, valves and appurtenances essential for the proper operation of the aforementioned sewage *Works*;

all in accordance with the submitted supporting documents listed in Schedule A.

For the purpose of this environmental compliance approval, the following definitions apply:

"Approval" means this entire document and any schedules attached to it, and the application;

"Average Daily Flow" means the cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year;

"BOD5" (also known as TBOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand;

"By-pass" means diversion of sewage around one or more unit processes within the Sewage Treatment Plant with the diverted sewage flows being returned to the Sewage Treatment Plant treatment train upstream of the Final effluent sampling location, and discharging to the environment through the Sewage Treatment Plant outfall;

"CBOD5" means five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample;

"Daily Concentration" means the concentration of a contaminant in the effluent discharged over any single day, as measured by a composite or grab sample, whichever is required;

"Director" means a person appointed by the Minister pursuant to section 5 of the EPA for the purposes of Part II.1 of the EPA;

"EPA" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended;

"E. Coli" refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius;

"Emergency Situation" includes a structural, mechanical or electrical failure that causes a temporary reduction in the capacity of the Sewage Treatment Plant and an unforeseen flow condition that may result in:

- a) danger to the health or safety of any person; or,
- b) injury or damage to any property, or serious risk of injury or damage to any property

"Equivalent equipment" means a substituted equipment that meets the required quality and performance standards of a named equipment;

"Event" means an action or occurrence, at a given location within the Sewage Treatment Plant that causes a Plant Bypass or Plant Overflow. An Event ends when there is no recurrence of a Bypass or Overflow in the 12-hour period following the last Bypass or Overflow. Two Events are separated by at least 12 hours during which there has been no recurrence of a Bypass or Overflow;

"Final Effluent" means sewage discharge via the Sewage Treatment Plant outfall after undergoing the full train of unit processes as listed in the Approval;

"Geometric Mean Density" is the nth root of the product of multiplication of the results of n number of samples over the period specified;

"Limited Operational Flexibility" (LOF) means the Modifications that the Owner is permitted to make to the Works under this Approval;

"Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;

"Modifications" means any addition, replacement, alteration, expansion or optimization for the Works as specified under Limited Operational Flexibility:

"Monthly Average Concentration" means the arithmetic mean of all Daily Concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month;

"Monthly Average Daily Flow" means the cumulative total sewage flow to the sewage works during a calendar month divided by the number of days during which sewage was flowing to the sewage works that month;

"Monthly Average Loading" means the value obtained by multiplying the Monthly Average Concentration of a contaminant by the Monthly Average Daily Flow over the same calendar month:

"Notice of Modifications" means the form entitled "Notice of Modifications to Sewage Works";

"Owner" means The Corporation of the Township of Huron-Kinloss and its successors and assignees;

"OWRA" means the Ontario Water Resources Act, R.S.O. 1990, c. O.40, as amended;

"Partial Treatment" means any treatment that does not include the full train of unit processes of the Sewage Treatment Plant described and approved in the Approval;

"Peak Flow Rate" means the maximum rate of sewage flow for which the plant or process unit was designed;

"Plant Overflow" means a discharge to the environment from the Sewage Treatment Plant at a location other than the plant outfall or into the plant outfall downstream of the Final Effluent sampling location;

"Rated Capacity" means the Average Daily Flow for which the Works are approved to handle;

"Regional Water Compliance Manager" means the Regional Water Compliance Manager of the Southwestern Region of the Ministry;

"Sewage Treatment Plant" means the entire sewage treatment and effluent discharge facility;

"Source Protection Plan" means a drinking water source protection plan prepared under the Clean Water Act, 2006;

"Substantial Completion" has the same meaning as "substantial performance" in the Construction Lien Act;

"Water Supervisor" means the Water Supervisor for the Owen Sound office of the Ministry; and

"Works" means the sewage works described in the Owner 's application, this Approval, including the Limited Operational Flexibility.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL PROVISIONS

- (1) The *Owner* shall ensure that any person authorized to carry out work on or operate any aspect of the *Works* is notified of this *Approval* and the conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
- (2) Except as otherwise provided by these conditions, the *Owner* shall design, build, install, operate and maintain the *Works* in accordance with the description given in this *Approval*, and the application for approval of the *Works*.
- (3) Where there is a conflict between a provision of any document in the schedule referred to in this *Approval* and the conditions of this *Approval*, the Conditions in this *Approval* shall take precedence, and where there is a conflict between the documents in the schedule, the document bearing the most recent date shall prevail.
- (4) Where there is a conflict between the documents listed in the Schedulesubmitted documents, and the application, the application shall take precedence unless it is clear that the purpose of the document was to amend the application.
- (5) The Conditions of this *Approval* are severable. If any Condition of this *Approval*, or the application of any requirement of this *Approval* to any circumstance, is held invalid or unenforceable, the application of such condition to other circumstances and the remainder of this *Approval* shall not be affected thereby.

2. EXPIRY OF APPROVAL

The approval issued by this *Approval* will cease to apply to those parts of the *Works* which have not been constructed within five (5) years of the date of this *Approval*.

3. CHANGE OF OWNER

- (1) The *Owner* shall notify the *Water Supervisor* and the *Director*, in writing, of any of the following changes within thirty (30) days of the change occurring:
 - (a) change of Owner;
 - (b) change of address of the *Owner*;
 - (c) change of partners where the *Owner* is or at any time becomes a partnership, and a copy of the most recent declaration filed under the Business Names Act, R.S.O. 1990, c.B17 shall be

included in the notification to the Water Supervisor;

- (d) change of name of the corporation where the *Owner* is or at any time becomes a corporation, and a copy of the most current information filed under the <u>Corporations Informations Act</u>, R.S.O. 1990, c. C39 shall be included in the notification to the *Water Supervisor*;
- (2) In the event of any change in ownership of the *Works*, other than a change to a successor municipality, the *Owner* shall notify in writing the succeeding owner of the existence of this *Approval*, and a copy of such notice shall be forwarded to the *Water Supervisor* and the *Director*.

4. <u>UPON THE SUBSTANTIAL COMPLETION OF THE WORKS</u>

- (1) Upon the *Substantial Completion* of the *Works*, the Owner shall prepare a statement, certified by a Professional Engineer, that the works are constructed in accordance with this *Approval*, and upon request, shall make the written statement available for inspection by Ministry personnel.
- (2) Within one (1) year of the *Substantial Completion* of the sewage works, a set of as-built drawings showing the works "as constructed" shall be prepared. These drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the *Works* for the operational life of the *Works*.

5. BY-PASSES

- (1) Any *By-pass* or *Plant Overflow* is prohibited, except:
 - (a) in an *Emergency Situation*;
 - (b) where the *Bypass / Plant Overflow* is a direct and unavoidable result of a planned maintenance procedure, the owner notified the *Director* 15 days prior to the *Bypass* and the *Director* has given written consent of the *Bypass*; and
 - (c) where the *Bypass / Plant Overflow* is planned for research or training purposes, the discharger notified the *Director* 15 days prior to the *Bypass / Plant Overflow* and the *Director* has given written consent of the *Bypass / Plant Overflow*.
- (2) The *Owner* shall forthwith notify the Spills Action Centre (SAC) and the Medical Officer of Health of all *Bypass and Plant Overflow Events*. This notice shall include, at a minimum, the following information:
 - (a) the date, time, and duration of the *Event*;
 - (b) the location of the *Event*;
 - (c) the measured or estimated volume of the *Event*;

- (d) the reason for the *Event*; and
- (d) the level of treatment the *Bypass(es)* and/or *Plant Overflow(s)* received and disinfection status of same.
- (3) The *Owner* shall ubmit *Bypass and Plant Overflow Event Reports* to the *Water Supervisor* on a quarterly basis, no later than each of the following dates for each calendar year: February 14, May 15, August 14, and November 15. Event Reports shall be in an electronic format specified by the Ministry. In each Event Report the *Owner* shall include, at a minimum, the following information on any *Events* that occurred during the preceding quarter:
 - (a) the date of the *Event(s)*;
 - (b) the measured or estimated volume of the *Event(s)*;
 - (c) the duration of the *Event(s)*;
 - (d) the location of the *Event(s)*;
 - (e) the reason for the *Event(s)*; and
 - (f) the level of treatment the *Bypass(es)* and/or *Plant Overflow(s)* received and disinfection status of same.
- (4) The Owner shall maintain a logbook of all Plant Bypasses and Plant Overflows, which shall contain, at a minimum, the types of information set out in subsection 2 (a) to 2(e) in respect of each Bypass and Plant Overflow.

6. EFFLUENT OBJECTIVES

(1) The *Owner* shall use best efforts to design, construct and operate the *Works* with the objective that the concentrations of the materials named below as effluent parameters are not exceeded in the effluent from the aerated lagoon system:

Table 1 - Aerated Lagoon Effluent Objectives		
Effluent Parameter	Average Concentration	
	(milligrams per litre unless otherwise indicated)	
Column 1	Column 2	
CBOD5	20.0	
Total Suspended Solids	20.0	
Total Phosphorus	1.0	

(2) The Owner shall use best efforts to:

- (a) maintain the pH of the effluent from the *Works* within the range of 6.5 8.5, inclusive, at all times:
- (b) operate the works within the *Rated Capacity* of the *Works*;
- (c) ensure that the effluent from the *Works* is essentially free of floating and settleable solids and does not contain oil or any other substance in amounts sufficient to create a visible film or sheen or foam or discolouration on the receiving waters.
- (3) The *Owner* shall include in all reports submitted in accordance with Conditions 9 and 10 a summary of the efforts made and results achieved under this Condition.

7. EFFLUENT LIMITS

(1) The *Owner* shall operate and maintain the *Works* such that the concentrations of the materials named below as groundwater parameters are not exceeded in the groundwater monitoring well No. GWS-3:

Table 2 - Groundwater Limits		
Effluent Parameter	Average Concentration (milligrams per litre unless otherwise indicated)	
Column 1	Column 2	
CBOD5	5.0	
Total Suspended Solids	5.0	
Total Phosphorus	0.1	
Total Ammonia Nitrogen	2.5	
Unionized Ammonia	0.1	
E. Coli	100 Organisms/100 mL	
	Monthly Geometric Mean Density	

- (2) For the purposes of determining compliance with and enforcing subsection (1):
 - (a) The *Monthly Average Concentration* of a parameter named in Column 1 of subsection (1) shall not exceed the corresponding maximum concentration set out in Column 2 of subsection (1).
- (3) In case of an exceedance for two consecutive months of any of the parameters listed in Column 1 of Table 2 in subsection (1), the *Owner* shall undertake an assessment of the performance of the entire system and, within ninety (90) days of the exceedance, submit a report to the *Water Supervisor* assessing the potential impacts of the exceedance on the environment and remedial actions recommended for preventing future exceedance.

8. OPERATION AND MAINTENANCE

- (1) The *Owner* shall exercise due diligence in ensuring that, at all times, the *Works* and the related equipment and appurtenances used to achieve compliance with this *Approval* are properly operated and maintained. Proper operation and maintenance shall include effective performance, adequate funding, adequate operator staffing and training, including training in all procedures and other requirements of this *Approval* and the *Act* and regulations, adequate laboratory facilities, process controls and alarms and the use of process chemicals and other substances used in the *Works*.
- (2) The *Owner* shall prepare an operations manual within six (6) months of *Substantial Completion* of the *Works*, that includes, but not necessarily limited to, the following information:
 - (a) operating procedures for routine operation of the Works;
 - (b) inspection programs, including frequency of inspection, for the *Works* and the methods or tests employed to detect when maintenance is necessary;
 - (c) repair and maintenance programs, including the frequency of repair and maintenance for the *Works*;
 - (d) procedures for the inspection and calibration of monitoring equipment;
 - (e) a spill prevention control and countermeasures plan, consisting of contingency plans and procedures for dealing with equipment breakdowns, potential spills and any other abnormal situations, including notification of the *Water Supervisor*; and
 - (f) procedures for receiving, responding and recording public complaints, including recording any followup actions taken.
- (3) The *Owner* shall maintain the operations manual current and retain a copy at the location of the *Works* for the operational life of the *Works*. Upon request, the *Owner* shall make the manual available to *Ministry* staff.
- (4) The *Owner* shall provide for the overall operation of the *Works* with an operator who holds a licence that is applicable to that type of facility and that is of the same class as or higher than the class of the facility in accordance with Ontario Regulation 129/04.

9. MONITORING AND RECORDING

The *Owner* shall, upon commencement of operation of the *Works*, carry out the following monitoring program:

- (1) All samples and measurements taken for the purposes of this *Approval* are to be taken at a time and in a location characteristic of the quality and quantity of the effluent stream over the time period being monitored.
- (2) For the purposes of this condition, the following definitions apply:

- (a) Weekly means once each week;
- (b) Monthly means once every month;
- (c) Quarterly means once every three months;
- (3) Samples shall be collected at the following sampling points, at the frequency specified, by means of the specified sample type and analyzed for each parameter listed and all results recorded:

Table 3 - Raw Sewage Monitoring - Inlet to Sewage Treatment Facility		
Parameters	Sample Type	Frequency
BOD5	Grab	Quarterly
Total Suspended Solids	Grab	Quarterly
Total Phosphorus	Grab	Quarterly
Total Kjeldahl Nitrogen	Grab	Quarterly

Table 4 - Aerated Lagoon Effluent Monitoring - Effluent Pumping Station			
Parameters	Sample Type	Frequency	
$CBOD_{_{5}}$	Grab	Monthly	
Total Suspended Solids	Grab	Monthly	
Total Phosphorus	Grab	Monthly	
Total Ammonia Nitrogen	Grab	Monthly	
E. Coli	Grab	Monthly	
рН	Grab	Monthly	
Temperature	Grab	Monthly	
Unionized Ammonia	Calculated	Monthly	

Table 5 - Groundwater Monitoring - Groundwater Monitoring Location No. GWS-3		
Parameters	Sample Type	Frequency
$CBOD_{5}$	Grab	Weekly
Total Suspended Solids	Grab	Weekly
Total Phosphorus	Grab	Weekly
Total Ammonia Nitrogen	Grab	Weekly
E. Coli	Grab	Weekly
рН	Grab	Weekly
Temperature	Grab	Weekly
Unionized Ammonia	Calculated	Weekly

(4) The methods and protocols for sampling, analysis and recording shall conform, in order of precedence, to the methods and protocols specified in the following:

- (a) the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works (Liquid Waste Streams Only), as amended from time to time by more recently published editions;
- (b) the Ministry's publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater" (January 1999), ISBN 0-7778-1880-9, as amended from time to time by more recently published editions;
- (c) the publication "Standard Methods for the Examination of Water and Wastewater" (21st edition), as amended from time to time by more recently published editions;
- (5) The temperature and pH of the effluent from the *Works* shall be determined in the field at the time of sampling for Total Ammonia Nitrogen. The concentration of un-ionized ammonia shall be calculated using the total ammonia concentration, pH and temperature using the methodology stipulated in "Ontario's Provincial Water Quality Objectives" dated July 1994, as amended, for ammonia (un-ionized).
- (6) The measurement frequencies specified in subsection (2) in respect to any parameter are minimum requirements which may be modified by the *Water Supervisor* in writing from time to time.
- (7) The *Owner* shall install and maintain (a) continuous flow measuring device(s), to measure the flowrate of the effluent from the *Works* with an accuracy to within plus or minus 15 per cent (+/- 15%) of the actual flowrate for the entire design range of the flow measuring device, and record the flowrate at a daily frequency.

10. REPORTING

- (1) One week prior to the start up of the operation of the *Works*, the *Owner* shall notify the *Water Supervisor* (in writing) of the pending start up date.
- (2) Ten (10) days prior to the date of a planned *By-pass* being conducted pursuant to Condition 5 and as soon as possible for an unplanned *By-pass*, the *Owner* shall notify the *Water Supervisor* (in writing) of the pending start date, in addition to an assessment of the potential adverse effects on the environment and the duration of the *By-pass*.
- (3) The *Owner* shall report to the *Water Supervisor* or designate, any exceedence of any parameter specified in Condition 7 orally, as soon as reasonably possible, and in writing within seven (7) days of the exceedence.
- (4) In addition to the obligations under Part X of the Environmental Protection Act, the Owner shall, within ten (10) working days of the occurrence of any reportable spill as defined in Ontario Regulation 675/98, bypass or loss of any product, by-product, intermediate product, oil, solvent, waste material or any other polluting substance into the environment, submit a full written report of the occurrence to the Water Supervisor describing the cause and discovery of the spill or loss, clean-up and recovery measures

taken, preventative measures to be taken and schedule of implementation.

- (5) The *Owner* shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to *Ministry* staff.
- (6) The *Owner* shall prepare, and submit to the *Director* and the *Water Supervisor*, a performance report, on an annual basis, within ninety (90) days following the end of the period being reported upon. The first such report shall cover the first annual period following the commencement of operation of the *Works* and subsequent reports shall be submitted to cover successive annual periods following thereafter. The reports shall contain, but shall not be limited to, the following information:
 - (a) a summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Condition 7, including an overview of the success and adequacy of the *Works*;
 - (b) a description of any operating problems encountered and corrective actions taken;
 - (c) a summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the *Works*;
 - (d) a summary of any effluent quality assurance or control measures undertaken in the reporting period;
 - (e) a summary of the calibration and maintenance carried out on all effluent monitoring equipment;
 - (f) a description of efforts made and results achieved in meeting the Effluent Objectives of Condition 6:
 - (g) a tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed;
 - (h) a summary of any complaints received during the reporting period and any steps taken to address the complaints;
 - (i) a summary of all *By-pass*, spill or abnormal discharge events;
 - (j) a copy of all *Notice of Modifications* submitted to the *Water Supervisor*, with a status report on the implementation of *Limited Operational Flexibility*; and
 - (k) any other information the *Water Supervisor* requires from time to time.

11. SOURCE WATER PROTECTION

The Owner shall, within sixty (60) calendar days of the Minister of the Environment posting approval of

a Source Protection Plan on the environmental registry established under the Environmental Bill of Rights, 1993 for the area in which this Approval is applicable, apply to the Director for an amendment to this Approval that includes the necessary measures to conform with all applicable policies in the approved Source Protection Plan.

12. LIMITED OPERATIONAL FLEXIBILITY

- (1) The *Owner* may make *Modifications* to the *Works* in accordance with the terms and conditions of this *Approval* and subject to the Ministry's "Limited Operational Flexibility Criteria for Modifications to Sewage Works", included under Schedule B of this *Approval*.
- (2) Sewage works under *Limited Operational Flexibility* shall adhere to the design guidelines contained within the Ministry's publication "Design Guidelines for Sewage Works 2008", as amended.
- (3) The *Owner* shall ensure at all times, the *Works* and related equipment and appurtenances which are installed or used to achieve compliance are operated in accordance with all terms and conditions of this *Approval*.
- (4) For greater certainty, the following are <u>not</u> permitted as part of *Limited Operational Flexibility*:
 - (a) Modifications to the Works that result in an increase of the Rated Capacity of the Works;
 - (b) *Modifications* to the *Works* that adversely affect the approved effluent quality criteria or the location of the discharge/outfall;
 - (c) Modifications to the Works approved under s.9 of the EPA, and
 - (d) *Modifications* to the *Works* pursuant to an order issued by the *Ministry*.
- (5) Implementation of *Limited Operational Flexibility* is not intended to be used for piecemeal measures that result in major alterations or expansions.
- (6) If the implementation of *Limited Operational Flexibility* requires changes to be made to the Emergency Response, Spill Reporting and Contingency Plan, the *Owner* shall provide a revised copy of this plan for approval to the local fire services authority prior to implementing *Limited Operational Flexibility*.
- (7) For greater certainty, any alteration made under the *Limited Operational Flexibility* may only be carried out after other legal obligations have been complied with including those arising from the *Environmental Protection Act*, *Niagara Escarpment Planning and Development Act*, *Oak Ridges Moraine Conservation Act*, *Lake Simcoe Protection Act* and *Greenbelt Act*.
- (8) Prior to implementing *Limited Operational Flexibility*, the *Owner* shall complete a *Notice of Modifications* describing any proposed *Modifications* to the *Works* and submit it to the *Water Supervisor*.

The reasons for the imposition of these terms and conditions are as follows:

- 1. Condition 1 is imposed to ensure that the *Works* are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the precedence of Conditions in the *Approval* and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. The condition also advises the Owners their responsibility to notify any person they authorized to carry out work pursuant to this *Approval* the existence of this *Approval*.
- 2. Condition 2 is included to ensure that the *Works* are constructed in a timely manner so that standards applicable at the time of Approval of the *Works* are still applicable at the time of construction, to ensure the ongoing protection of the environment.
- 3. Condition 3 is included to ensure that the *Ministry* records are kept accurate and current with respect to the approved works and to ensure that subsequent owners of the *Works* are made aware of the *Approval* and continue to operate the *Works* in compliance with it.
- 4. Condition 4 is included to ensure that the *Works* are constructed in accordance with the approval and that record drawings of the *Works* "as constructed" are maintained for future references.
- 5. Condition 5 is included to indicate that by-passes of untreated sewage to the receiving watercourse is prohibited, save in certain limited circumstances where the failure to *By-pass* could result in greater injury to the public interest than the *By-pass* itself where a *By-pass* will not violate the approved effluent requirements, or where the *By-pass* can be limited or otherwise mitigated by handling it in accordance with an approved contingency plan. The notification and documentation requirements allow the *Ministry* to take action in an informed manner and will ensure the *Owner* is aware of the extent and frequency of *By-pass* events.
- 6. Condition 6 is imposed to establish non-enforceable effluent quality objectives which the *Owner* is obligated to use best efforts to strive towards on an ongoing basis. These objectives are to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs and before the compliance limits of Condition 7 are exceeded.
- 7. Condition 7 is imposed to ensure that the effluent discharged from the *Works* to the reveiver meets the *Ministry* 's effluent quality requirements thus minimizing environmental impact on the receiver and to protect water quality, fish and other aquatic life in the receiving water body.
- 8. Condition 8 is included to require that the *Works* be properly operated, maintained, funded, staffed and equipped such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented. As well, the inclusion of a comprehensive operations manual governing all significant areas of operation, maintenance and repair is prepared, implemented and kept up-to-date by the owner and made available to the *Ministry*. Such a manual is an integral part of the operation of the *Works*. Its compilation and use should assist the *Owner* in staff training, in proper plant operation and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a benchmark for *Ministry* staff when reviewing the *Owner'* s operation of the work.

- 9. Condition 9 is included to enable the *Owner* to evaluate and demonstrate the performance of the *Works*, on a continual basis, so that the *Works* are properly operated and maintained at a level which is consistent with the design objectives and effluent limits specified in the *Approval* and that the *Works* does not cause any impairment to the receiving watercourse.
- 10. Condition 10 is included to provide a performance record for future references, to ensure that the *Ministry* is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this *Approval*, so that the *Ministry* can work with the *Owner* in resolving any problems in a timely manner.
- 11. Condition 11 is included to ensure that the works covered by this *Approval* will conform to the significant threat policies and designated Great Lakes policies in the *Source Protection Plan*.
- 12. Condition 12 is included to ensure that the *Works* are operated in accordance with the application and supporting documentation submitted by the *Owner*, and not in a manner which the *Director* has not been asked to consider. These conditions are also included to ensure that a Professional Engineer has reviewed the proposed *Modifications* and attests that the *Modifications* are in line with that of *Limited Operational Flexibility*, and provide assurance that the proposed *Modifications* comply with the Ministry's requirements stipulated in the terms and conditions of this *Approval*, MOE policies, guidelines, and industry engineering standards and best management practices.

Schedule A

- 1. Application for Approval of Sewage Works received on July 20, 1988 submitted by B.M. Ross & Associates Limited, including Environmental Study Report dated May 30, 1988 and final engineering plans and specifications submitted subsequently;
- 2. <u>Application for Approval of Municipal and Private Sewage Works</u> received on May 5, 2003 along with 2002 Lucknow Sewage Works Performance Report prepared by B.M. Ross and Associates Limited:
- 3. <u>Application for Environmental Compliance Approval</u> submitted by Andrew Garland of B.M. Ross & Associates Limited received on April 20, 2013 for amendment to monitoring requirements.

Schedule B

Limited Operational Flexibility Criteria for Modifications to Sewage Works

The *Modifications* to sewage works approved under an Environmental Compliance Approval (ECA) that are permitted under the *Limited Operational Flexibility*, are outlined below. For clarity proposes, *Modifications* of equipment **does not** include process equipment where treatment unit operations occur, including but not limited to: screens, grit separators, blowers, oxygen diffusers, sludge thickeners and dewatering equipment, UV systems, chlorine contact tanks, bio-disks, digester gas handling systems, and process reactors.

Modifications of sewage works that are exempt from section 53 of the OWRA by O. Reg. 525/98 including

minor maintenance and/or repair activities will continue to be exempt and are not required to follow the notification process under this *Limited Operational Flexibility*.

The following sewage works are permitted under *Limited Operational Flexibility*, and as per the conditions in the *Approval*:

1.0 Sewage Pumping Stations

- 1.1 Alter pumping capacity by adding or replacing equipment where new equipment is located within an existing sewage treatment plant site or an existing sewage pumping station site, where the facility rated capacity is not exceeded and while maintaining the existing flow process and/or treatment train, if applicable.
- 1.2 Replacing existing minor equipment with *Equivalent equipment* of different make and model, provided that there are no treatment process changes as a result of the replacement.

2.0 Inlet Works

2.1 Replacing existing minor equipment with *Equivalent equipment* of different make and model.

3.0 Sewage Treatment Process

- 3.1 Install or replace instrumentation or chemical dosage equipment for operational or maintenance purposes including replacing chemicals for pH adjustment or coagulants (non-toxic polymers) provided that there are no *Modifications* of treatment processes or other *Modifications* that may alter the intent of operations and may have negative impacts on *Works'* effluent quantity and quality.
- 3.2 Expansion of buffer zone between a sanitary sewage lagoon facility or land treatment area and adjacent uses where the buffer zone is entirely on the proponent's land.
- 3.3 Optimize existing sanitary sewage lagoons with the purpose to increase efficiency of treatment operations provided that existing sewage treatment plant rated capacity is not exceeded and where no land acquisition is required.
- 3.4 Replacing existing minor equipment with *Equivalent equipment* of different make and model, provided that there are no treatment process changes as a result of the replacement.
- 3.5 No *Modifications* are allowed for equipment approved under section 9 of the EPA.

4.0 Sewage Treatment Process Outfall

4.1 Replacement of discharge pipe with similar pipe size provided that the outfall location is not changed.

5.0 Sanitary Sewers

- 5.1 Pipe relining and replacement with similar pipe size to the approved site location's existing sanitary sewers and forcemains sewage collection system. The sewer main addition, modification, replacement and extensions **do not** include **combined sewers**.
- 5.2 Sanitary gravity sewers and forcemains within the approved site location.
- 5.3 No *Modifications* are allowed for sanitary sewers with a nominal diameter greater than 1,200mm and sanitary pipe twining.

6.0 **Pilot Systems**

- 6.1 Installation of pilot systems for new or existing technologies provided that:
 - a) any effluent from the pilot system is discharged to the inlet of the main sewage treatment plant or hauled off-site for proper disposal,
 - b) any effluent from the pilot system discharged to the inlet of the main sewage treatment plant does not significantly alter the composition/concentration of the influent sewage to be treated in the downstream process; and that it does not add any inhibiting substances to the downstream process, and
 - c) the pilot system's duration be of up to a maximum of **two years**; and a report with results is submitted to the *Director* and *Water Supervisor* **three months** after completion of the pilot project.



Notice of Modification to Sewage Works

Issuance Date

(mm/dd/yy)

Notice number

Ministry of the Environment

RETAIN COPY OF COMPLETED FORM AS PART OF THE ECA AND SEND A COPY TO THE WATER SUPERVISOR (FOR MUNICIPAL PLANTS) OR DISTRICT MANAGER (FOR INDUSTRIAL PLANTS)

(Insert the ECA's owner, number and issuance date and notice number, which should start with "01" and consecutive numbers thereafter)

Part 1 - Environmental Compliance Approval (ECA) with Limited Operational Flexibility

Part 2 - Description of the modifications as part of the Limited Operational Flexibility

ECA number

e sewage works (e.g. sewage work component, location, size,
ents required by this ECA that are affected by the modifications prevention plan, etc.
his modification and confirm that the design: ensed to practice in the Province of Ontario; ility as described in the ECA; ering to engineering standards, industry's best management
tario Water Resources Act; and other appropriate regulations. the information contained in this form is complete and accurat
PEO License Number
Date (mm/dd/yy)
vith the Limited Operational Flexibility as described in the ECA. tal Assessment Act. the information contained in this form is complete and accurat
Owner representative's title (Print)
o mer representative o title (i mit)

Upon issuance of the environmental compliance approval, I hereby revoke Approval No(s). 1180-5QCNEW issued on October 16, 2003.

In accordance with Section 139 of the Environmental Protection Act, you may by written Notice served upon me and the Environmental Review Tribunal within 15 days after receipt of this Notice, require a hearing by the Tribunal. Section 142 of the Environmental Protection Act provides that the Notice requiring the hearing shall state:

- 1. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- 2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

Pursuant to subsection 139(3) of the Environmental Protection Act, a hearing may not be required with respect to any terms and conditions in this environmental compliance approval, if the terms and conditions are substantially the same as those contained in an approval that is amended or revoked by this environmental compliance approval.

The Notice should also include:

- 3. The name of the appellant;
- 4. The address of the appellant;
- 5. The environmental compliance approval number;
- 6. The date of the environmental compliance approval;
- 7. The name of the Director, and;
- 8. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary*
Environmental Review Tribunal
655 Bay Street, Suite 1500
Toronto, Ontario
M5G 1E5

AND

The Director appointed for the purposes of Part II.1 of the Environmental Protection Act Ministry of the Environment 2 St. Clair Avenue West, Floor 12A Toronto, Ontario M4V 11.5

* Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 314-4506 or www.ert.gov.on.ca

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 6th day of August, 2013



Edgardo Tovilla
Director
appointed for the purposes of Part II.1 of the
Environmental Protection Act

FL/

c: DWMD Supervisor, MOE Owen Sound Andrew Garland, B.M. Ross and Associates Limited