



NOTICE

The Corporation of the Township of St. Edmunds
P.O. Box 79
Tobermory, Ontario
N0H 2R0

You are hereby notified that the approval issued under Certificate of Approval No. 3-0046-93-006 dated February 24, 1993 for expansion of sewage treatment works in the Township of St. Edmunds is hereby amended to include the following:

Condition No. 16 of the Certificate is hereby amended to permit the construction of the following works for which final plans and specifications have now been received:

Sewage Pumping Station

Upgrading of existing sewage pumping station located on Lot 7, Carlton Street - South Side, Townplot of Bury, in the Township of St. Edmunds as follows:

- Construction of a wet well with normal operating volume of 5.7 m³ and two (2) submersible sewage pumps each rated at 17.0 L/s at 50.5 m TDH including, manual screen, ultrasonic level control and float backup;
- Retrofit of the existing generator/control building by the installation of a new motor control centre and a 150 kW diesel generator set including automatic transfer switch, 1135 L fuel tank and appurtenances;
- Construction of a new odour control building housing 188.8 L/s odour control unit and appurtenances;
- Construction of a new metering chamber including a magnetic flowmeter and accessories;

Replacing the existing 150mm diameter forcemain with a 200mm diameter forcemain as follows:

<u>Street</u>	<u>From</u>	<u>To</u>
Bay Street	Sewage Pumping Station	Highway No. 6
Highway No. 6	Bay Street	Approx. 775 m S of Bay Street

Including all associated site sanitary sewers and appurtenances, valves, meters, electrical and control systems.

Reason

The reason for this amendment is to approve the construction of the above mentioned works for which final plans and specifications, prepared by KMK Consultants Limited, Consulting Engineers, were received and found to be satisfactory.

This Notice shall constitute part of the approval issued under Certificate of Approval No. 3-0046-93-006 dated February 24, 1993.

You may by written notice served upon me and the Environmental Appeal Board within 15 days after receipt of this Notice, require a hearing by the Board. Section 101 of the Ontario Water Resources Act, R.S.O. 1990, Chapter O.40, provides that the Notice requiring the hearing shall state:

1. The portions of the approval or each term or condition in the approval in respect of which the hearing is required, and;
2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The Certificate of Approval number;
6. The date of the Certificate of Approval;
7. The name of the Director;
8. The municipality within which the sewage works are located;

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary,
Environmental Appeal Board,
112 St. Clair Avenue West,
Suite 502,
Toronto, Ontario.
M4V 1N3

AND

The Director,
Section 53, Ontario Water Resources Act,
Ministry of Environment and Energy,
250 Davisville Avenue, 3rd Floor,
Toronto, Ontario.
M4S 1H2

The above noted sewage works are approved under Section 53 of the Ontario Water Resources Act.

DATED AT TORONTO this 16th day of May 1994

THIS IS A TRUE COPY OF THE
ORIGINAL NOTICE OF AMENDMENT
SIGNED BY

M. DHALLA, P. ENG.

MAILED ON

BY

MAY 17 1994
[Signature]

NS/pm

Attn-C. Wyonch, Clerk, Twp of St. Edmunds
cc -MOEE, Owen Sound District Manager
-KMK Cons. Ltd.