



NOTICE

The Corporation of the Township of St. Edmunds
P.O. Box 70
Tobermory, Ontario
N0H 2R0

You are hereby notified that the approval issued to you under Certificate of Approval No. 3-0046-93-006 dated February 24, 1993, for expansion of sewage treatment works in the Township of St. Edmunds is hereby amended to include the following:

Condition No. 16 of the Certificate is hereby amended to permit the construction of the following works for which final plans and specifications have now been received:

Expansion of the existing Tobermory Sewage Treatment Facility located in Lot 49, Concession 1, West of Bury Road in the Township of St. Edmunds to treat an average summer day design flow of 625 m³/d as follows:

- Construction of two (2) 0.4 hectare aeration lagoons with tapered coarse bubble diffused aeration and a quiescent settling zone in the secondary aeration lagoon including an effluent recycle submersible pump rated at 8.6 L/s at a T.D.H. of 2.9 m;
- Construction of three (3) exfiltration lagoons rated at 510 m³/d, two of which are 1.5 hectares in area each while the third of 1.9 hectares is located at the site of the existing lagoons (to be demolished);
- R.J.* Construction of one (1) 1.3 hectare storage lagoon and one (1) 1.5 hectare overflow lagoon;
- Construction of six (6) concrete flow distribution chambers;
- Construction of a 65 m² control building to house, three (3) blowers (two duty and one standby) each rated at 164 L/s at approximately 50 kPa, ancillary equipment and an office;
- All associated yard piping, appurtenances and perimeter swale.

REASON

The reason for this amendment is to approve the construction of the above mentioned works for which final plans and specifications, prepared by KMK Consultants Limited, Consulting Engineers, were received and found to be satisfactory.

This Notice shall constitute part of the approval issued under Certificate of Approval No. 3-0046-93-006 dated February 24, 1993.

AMENDMENT TO CERTIFICATE OF APPROVAL
SEWAGE

NUMBER 3-0046-93-006

Page 2 of 2

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary,
Environmental Appeal Board,
112 St. Clair Avenue West,
Suite 502,
Toronto, Ontario.
M4V 1N3

AND

The Director,
Section 53, Ontario Water Resources Act,
Ministry of Environment and Energy,
250 Davisville Avenue, 3rd Floor,
Toronto, Ontario.
M4S 1H2

The above noted sewage works are approved under Section 53 of the Ontario Water Resources Act.

DATED AT TORONTO this 7th day of September 1994

THIS IS A TRUE COPY OF
THE ORIGINAL NOTICE OF AMENDMENT
SIGNED BY
M. DHALLA, P. ENG.

MAILED ON SEP 8 1994

BY 

NS/pm

Attn: C. Wyonch, Clerk, Twp of St. Edmunds
cc District Manager, MOEE Owen Sound District Office
KMK Consultants Ltd.