



ISOMETRIC VIEW

Q'ty 1 PC(s) REQUIRED MARKED DWID-R2

VOGT POWER INTERNATIONAL
V17494-DWID-7035-04
28-Apr-2016

5	22/04/16	REV. AS PES VPL DESIGN (DWG.V17494-DWID-0008 Rev.3)	S.KOSIN		
4	05/04/16	REV. AS PES VPL DESIGN (DWG.V17494-dwid-0052-SKND-001 Rev.2)	S.KOSIN		
3	25/12/15	CHANGE DESCRIPTION	W.Tawalchal		
2	21/11/15	REVISED REF. DWG.(V17494-DWID-0008_REV.02)	W.Tawalchal		
1	17/12/15	CHANGE DIMENSION	S.KOSIN		
0	01/12/15	FIRST ISSUE	S.KOSIN		
REV.	DATE.	DESCRIPTION	DRAWN	CHKD.	APPROD.

MATERIAL LIST FOR ASSEMBLY MK'D				DWID-R2-1		Q'TY : 1		No. Required	
Part No.	Description	Width	Length	Q'ty	Material	Weight	Area		
1a-10	L-90X90X10		8097	1	G3101 SS400	108.07	2.92		
1a-16	L-90X90X10		1441	1	G3101 SS400	19.23	0.52		
1a-17	L-90X90X10		1427	1	G3101 SS400	19.05	0.52		
1a-20	L-90X90X10		1724	1	G3101 SS400	23.01	0.62		
1a-33	L-75X75X6		779	4	G3101 SS400	21.34	0.94		
1m-10	H-568X300X12X20		10176	1	G3101 SS400	1537.72	23.97		
1m-30	C-200X80X7.5X11		427	7	G3101 SS400	73.50	1.67		
1m-46	C-200X80X7.5X11		1291	6	G3101 SS400	190.44	4.84		
1m-49	C-200X80X7.5X11		1413	6	G3101 SS400	208.43	5.79		
1m-58	C-200X80X7.5X11		707	1	G3101 SS400	17.40	0.41		
1m-82	C-380X100X10.5X16		6489	1	G3101 SS400	353.46	7.40		
1m-110	PIPE 1" SCH.40 (OD.33.4 X 3.38 THK.)		934	1	A-312 TP304	2.36	0.10		
1m-154	PIPE 6" SCH.40 (OD.168.3 X 7.11 THK.)		136	1	A-312 TP304	3.88	0.08		
1m-155	PIPE 6" SCH.40 (OD.168.3 X 7.11 THK.)		207	1	A-106 Gr.B	5.85	0.11		
1p-3	PL-38	457	762	1	A572-GR.50	103.88	0.79		
1p-13	PL-12	138	536	8	G3101 SS400	55.74	1.27		
1p-24	PL-10	81	164	3	G3101 SS400	3.13	0.09		
1p-28	PL-10	102	102	4	A-240 TP304	3.30	0.07		
1p-37	PL-10	108	7485	1	G3101 SS400	63.47	1.77		
1p-49	PL-10	140	165	4	G3101 SS400	7.25	0.21		
1p-53	PL-10	108	291	2	G3101 SS400	4.93	0.08		
1p-65	PL-3	15	122	16	G3101 SS400	0.69	0.07		
1p-66	PL-12	120	120	4	G3101 SS400	5.43	0.14		
1m-167	STUD 1/2" 13 UNC T.P.I.		373	1	A-479 TP304*	0.35	0.02		
1p-50	CASING PL-10	3105	8070	1	G3101 SS400	1685.91	21.58		
1a-1	BL-90X90X10	169	2448	1	G3101 SS400	32.43	0.84		
1m-125	M20 NUT		-	10	A-563	1.29	0.04		
1m-165	HEX NUT 1/2"		-	2	F594 TP304*	0.05	0.00		
1m-168	INSULATION, 2" THK, 8# DENSITY		OD.156	3	SUPERWOOL PLUS	0.02	0.18		
1m-190	40Mesh Wire Dia: 0.22mm		-	1	Stainless steel	0.00	0.06		
1m-81	1"NB-150# GASKET 3 THK.		-	2	NON-METALLIC	4.40	0.02		
1m-107	6" NB-150# RF.SLIP ON FLANGE		-	1	ASTM A105	10.80	0.13		
1m-108	6" NB 150# BLIND FLANGE		-	1	ASTM A105	12.00	0.14		
1m-109	6"NB-150# GASKET 3 THK.		-	1	NON-METALLIC	0.00	0.07		
1m-111	1" NB-150# RF.SLIP ON FLANGE		-	2	A-105	3.60	0.05		
1m-112	1"NB-150# BLIND FLANGE		-	2	A-105	4.40	0.04		
1m-110	PIPE 1" SCH.40 (OD.33.4 X 3.38 THK.)		934	1	A-312 TP304	2.36	0.10		
1m-166	WASHER PL-12 GA. (3mm)	ID.14	OD.151	2	A-240 TP409	0.82	0.07		
SB2080	HEX BOLT M20x80 WITH NUT			8	A307	2.89	0.00		
Total						4592.91	77.72		

UNIT 1

Project Owner's : Gemma Power System,LLC
Project Name: Middletown Energy Center Project
Vogt Power International Job No./Cost symbol: V17494 / DW
Vogt Power International Doc. No. :
Vogt Power International P.O. No.V0009490

This drawing contains Visavakit Patana Corp., Ltd.'s confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, except with the express written permission of Visavakit Patana Corp., Ltd.

© Visavakit Patana Corp., Ltd. all rights reserved as an unpublished work.



VISAVAKIT PATANA CORPORATION LIMITED
OFFICE : 215/148-149 Prachard 1 Road , Bangkok 10800 Tel. : 0-2585-2558-8 Fax : 0-2587-5068
PLANT 1 : 28/2 Moo 4 , Soi Chai Uo , Pathumthani 12000 Tel.:0-2975-2811-4 Fax: 0-2975-2815
PLANT 2 : 52 Moo7 , Kubangluang , Ladumkaew , Pathumthani 12140 Tel.:0-2979-4001-9 Fax: 0-2979-4010
www.vipco-thai.com Email : vipco@vipco-thai.com

TITLE
VOGT POWER INTERNATIONAL
MIDDLTOWN ENERGY CENTER PROJECT
INLET DUCT
RIGHT SIDE PANEL

REF.DWG.NO. Y15-1711-E0101-E0107
VIPCO DWG.NO. Y15-1711- DWID-R2-01

ISO-A (pt)
JOB NO.
1711
REV
5