


VOGT POWER INTERNATIONAL
Released, Work May Proceed
Bell, Milton Jun-21-2016



(DWCO/SCR-L3) LEFT LINER ISOMETRIC VIEW

MATERIAL LIST FOR ASSEMBLY MK'D DWCO/SCR-L3 Q'TY: 1 No. Required									
PartNo	Description	Width	ID	Length	OD	Qty	Mat Grade	Weight	Area
01	PL-2	838		1219		1	A-1011	16.04	1.02
02	PL-2	1042		1219		1	A-1011	19.94	1.27
03	PL-2	1219		1219		1	A-1011	23.33	1.49
04	PL-2	661		1219		1	A-1011	12.65	0.81
05	PL-2	838		1219		1	A-1011	16.04	1.02
06	PL-2	1042		1219		1	A-1011	19.94	1.27
07	PL-2	1219		1219		1	A-1011	23.33	1.49
08	PL-2	661		1219		1	A-1011	12.65	0.81
09	PL-2	838		1219		1	A-1011	16.04	1.02
10	PL-2	1042		1219		1	A-1011	19.94	1.27
11	PL-2	1219		1219		1	A-1011	23.33	1.49
12	PL-2	661		1219		1	A-1011	12.65	0.81
13	PL-2	838		1219		1	A-1011	16.04	1.02
14	PL-2	1042		1219		1	A-1011	19.94	1.27
15	PL-2	1219		1219		1	A-1011	23.33	1.49
16	PL-2	661		1219		1	A-1011	12.65	0.81
17	PL-2	838		1219		1	A-1011	16.04	1.02
18	PL-2	1042		1219		1	A-1011	19.94	1.27
19	PL-2	838		1219		1	A-1011	16.04	1.02
20	PL-2	661		838		1	A-1011	8.70	0.55
21	PL-2	504		838		1	A-1011	6.63	0.42
22	PL-2	504		1042		1	A-1011	8.25	0.53
48	PL-2	64	ID	165	OD	4	A-1011	0.66	0.04
49	PL-2	30	ID	131	OD	1	A-1011	0.06	0.00
M1	EXP METAL 3/4" No 16	34		2083		5	CS GALV	10.16	0.71
M01A	STUD 3/8"-16 UNC T.P.I.			90		186	A-108 TP1010	10.36	0.53
N12	3/8" NUT					372	A-563 GR A	6.32	-
SU	C-150x75x6.5x10			166		6	CS101 SS400	-	-
W01A	WASHER 12 GA (3mm)	11	ID	76	OD	372	A-1011	51.57	2.15
INSUL1	INSULATION 1" THK 8# DENSITY (5 ROLLS)					1	Superwool Plus	70.82	22.13 m2
INSUL2	INSULATION 2" THK 8# DENSITY (10 ROLLS)					1	Superwool Plus	133.38	20.84 m2
Total								648.78	69.55

VOGT POWER INTERNATIONAL
V17494-DWXD-7534-01
17-Jun-2016

This drawing contains Visavakit-Patana Corp., Ltd.'s confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, except with the express written permission of Visavakit Patana Corp., Ltd.
© Visavakit Patana Corp., Ltd. all rights reserved as an unpublished work.



VISAVAKIT PATANA CORPORATION LIMITED
OFFICE 215/148-149 Pracharad 1 Road, Bangnae, Bangkok 10800 Tel: 0-2585-2556-8 Fax: 0-2587-6068
PLANT 1 :28/2 Moo4, Soi Chai Ua, Pathumthani 12000 Tel: 0-2975-2811-4 Fax: 0-2975-2815
PLANT 2 :52 Moo7, Kubanglung, Ladlumbang, Pathumthani 12140 Tel: 0-2979-4001-9 Fax: 0-2979-4010
www.vipco-thai.com Email : vipco@vipco-thai.com

TITLE		ISO-A (3rd)	
VOGT POWER INTERNATIONAL MIDLETOWN ENERGY CENTER PROJECT *		JOB NO.	
CO/SCR DUCT (LINER)		1711	
LEFT SIDE PANEL		REV	
REF.DWG.NO.		Y15-1711-E0201~E0203	
VIPCO DWG.NO.		Y15-1711-DWCO/SCR-L3-05	
1		1	

REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED
1	08/06/16	CHANGE WEIGHT & AREA	Sanguanchai		
0	27/02/16	FIRST ISSUE	S.KOSIN		