


VOGT POWER INTERNATIONAL  
Released, Work May Proceed  
Bell, Milton Jun-21-2016



**(DWCO/SCR-R3) LEFT LINER ISOMETRIC VIEW**

MATERIAL LIST FOR ASSEMBLY MK'D DWCO/SCR-R3 Q'TY: 1 No. Required									
PartNo	Description	Width	ID	Length	OD	Qty	Mat. Grade	Weight	Area
01	PL-2	838		1219		1	A-1011	16.04	1.02
02	PL-2	1042		1219		1	A-1011	19.94	1.27
03	PL-2	1219		1219		1	A-1011	23.33	1.49
04	PL-2	661		1219		1	A-1011	12.65	0.81
05	PL-2	838		1219		1	A-1011	16.04	1.02
06	PL-2	1042		1219		1	A-1011	19.94	1.27
07	PL-2	1219		1219		1	A-1011	23.33	1.49
08	PL-2	661		1219		1	A-1011	12.65	0.81
09	PL-2	838		1219		1	A-1011	16.04	1.02
10	PL-2	1042		1219		1	A-1011	19.94	1.27
11	PL-2	1219		1219		1	A-1011	23.33	1.49
12	PL-2	661		1219		1	A-1011	12.65	0.81
13	PL-2	838		1219		1	A-1011	16.04	1.02
14	PL-2	1042		1219		1	A-1011	19.94	1.27
15	PL-2	1219		1219		1	A-1011	23.33	1.49
16	PL-2	661		1219		1	A-1011	12.65	0.81
17	PL-2	838		1219		1	A-1011	16.04	1.02
18	PL-2	1042		1219		1	A-1011	19.94	1.27
19	PL-2	838		1219		1	A-1011	16.04	1.02
20	PL-2	661		838		1	A-1011	8.70	0.55
21	PL-2	504		838		1	A-1011	6.63	0.42
22	PL-2	504		1042		1	A-1011	8.25	0.53
48	PL-2	64	ID	165	OD	4	A-1011	0.66	0.04
M1	EXP.METAL 3/4" No.16	34		2083		5	CS.GALV	10.16	0.71
M01A	STUD 3/8"-16 UNC T.P.I.			90		186	A-108 TP1010	10.38	0.53
N12	3/8" NUT					372	A-563 GRA	6.32	-
SU	C-150x75x6.5x10			186		6	G3101 SS400	-	-
W01A	WASHER 12 GA. (3mm)	11	ID	78	OD	372	A-1011	51.57	2.15
INSUL1	INSULATION 1" THK. 8# DENSITY (5 ROLLS)					1	Superwool Plus	70.82	22.13 m2
INSUL2	INSULATION 2" THK. 8# DENSITY (10 ROLLS)					1	Superwool Plus	133.38	20.84 m2
Total								646.72	69.54

VOGT POWER INTERNATIONAL  
V17494-DWXD-7564-01  
17-Jun-2016

This drawing contains Visavakit Patana Corp., Ltd.'s confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, except with the express written permission of Visavakit Patana Corp., Ltd.  
© Visavakit Patana Corp., Ltd. all rights reserved as an unpublished work.



**VISAVAKIT PATANA CORPORATION LIMITED**  
OFFICE :215/148-149 Prachanod 1 Road, Bangsue, Bangkok 10800 Tel: 0-2585-2556-8 Fax: 0-2587-6068  
PLANT 1 :28/2 Moo4, Soi Chai Ua, Pathumthani 12000 Tel: 0-2975-2811-4 Fax: 0-2975-2815  
PLANT 2 :52 Moo7, Kubanglung, Ladlumbangk, Pathumthani 12140 Tel: 0-2979-4001-9 Fax: 0-2979-4010  
www.vipco-thai.com Email : vipco@vipco-thai.com

TITLE		ISO-A (3rd)
VOGT POWER INTERNATIONAL MIDLETOWN ENERGY CENTER PROJECT CO/SCR DUCT (LINER) RIGHT SIDE PANEL		
JOB NO.		1711
REF.DWG.NO.	VIPCO DWG.NO.	
Y15-1711-E0201~E0203	Y15-1711-DWCO/SCR-R3-05	
REV.		1

1	08/06/16	CHANGE WEIGHT & AREA	Sanguanchai		
0	29/02/16	FIRST ISSUE	S.KOSIN		
REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED