



ISOMETRIC VIEW

MATERIAL LIST FOR ASSEMBLY MK'D				DWCO/SCR-T1-1		Q'TY : 1		No. Required	
Part No.	Description	Width	Length	Q'ty	Material	Weight	Area		
2a-15	L-75X75X6		1191	1	G3101 SS400	8.16	0.36		
2a-16	L-75X75X9		11389	1	G3101 SS400	113.46	3.42		
2m-4	C-150X75X6.5X10		3402	8	G3101 SS400	506.55	15.89		
2m-11	C-150X75X6.5X10		192	8	G3101 SS400	28.59	0.94		
2m-23	BH-915X300X16X25		11370	1	A-572 Gr.50	2574.10	34.12		
2m-28	PIPE 3" SCH.40 (OD.88.9 X 5.49 THK.)		238	16	A-108 Gr.B	43.00	1.08		
2p-1	PL-10	95	95	1	G3101 SS400	0.71	0.02		
2p-19	PL-16	160	280	4	G3101 SS400	22.51	0.25		
2p-27	PL-28	300	1235	2	G3101 SS400	162.87	1.65		
2p-38	PL-12	120	120	4	G3101 SS400	5.43	0.14		
2p-46	PL-2	107	208	1	A-1011	0.35	0.05		
2p-47	INSULATION, 2" THK, 8# DENSITY	107	208	2	SUPERWOOL PLUS	0.01	0.14		
2p-8	CASING PL-6	3439	11389	1	G3101 SS400	1844.76	39.26		
2p-45	PL-10	241	648	1	G3101 SS400	12.19	0.33		
3m-31	3"-3000# THREADED PIPE CAP			16	A-105	73.57	0.64		
Total						5396.25	98.28		

VOGT POWER INTERNATIONAL
V17494-DWXD-7342-01
25-Feb-2016

UNIT 1

Project Owner's : Gemma Power System,LLC
Project Name: Middletown Energy Center Project
Vogt Power International Job No./Cost symbol: V17494 / DW
Vogt Power International Doc. No. :
Vogt Power International P.O. No.V0009490

This drawing contains Visavakit Patana Corp., Ltd.'s confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, except with the express written permission of Visavakit Patana Corp., Ltd.

© Visavakit Patana Corp., Ltd. all rights reserved as an unpublished work.



VISAVAKIT PATANA CORPORATION LIMITED
OFFICE : 215/148-149 Pracharad 1 Road, Bangkok 10800 Tel. : 0-2585-2556-8 Fax : 0-2587-8068
PLANT 1 : 28/2 Moo 4, Sol Chai Uo, Pathumthani 12000 Tel.:0-2975-2811-4 Fax: 0-2975-2815
PLANT 2 : 52 Moo7, Kubangluang, Ladlumkaew, Pathumthani 12140 Tel.:0-2979-4001-9 Fax: 0-2979-4010
www.vipco-thai.com Email : vipco@vipco-thai.com

TITLE		VOGT POWER INTERNATIONAL MIDDLTOWN ENERGY CENTER PROJECT CO / SCR DUCT (CASING) TOP PANEL		ISO-A (Unit)
REF.DWG.NO.	Y15-1711-E0201-E0203	VIPCO DWG.NO.	Y15-1711- DWCO/SCR-T1-01	JOB NO. 1711
REV.	DATE.	DESCRIPTION	DRAWN	CHKD.
1	23/02/20	REV. REF. V17494-DWNO-0033 (REV.0)	S.Kitsana	Chatchai
0	01/02/20	FIRST ISSUE	S.Kitsana	Y
1				

VOGT POWER INTERNATIONAL
Review Waived
Bell, Milton Mar-03-2016

Q'ty 1 PC(s) REQUIRED MARKED DWCO/SCR-T1