[illegible]


- GENERAL NOTES:
1. ALL WELDING TO BE IN ACCORDANCE WITH LATEST STANDARDS OF AMERICAN WELDING SOCIETY STANDARD D.1.1 USING E70XX ELECTRODES.
  2. QUANTITIES SHOWN ARE FOR (1) ONE UNIT:  
(1) ONE UNIT REQUIRED FOR MIDDLETOWN PROJECT  
(1) ONE UNIT REQUIRED FOR KINGS MOUNTAIN PROJECT
  3. ALL WELDS ARE TO BE P1-P1 U.N.O.

REFERENCE DRAWINGS:  
V17494-ERND-0001- FIELD CONNECTIONS LOCAL MAP.  
V17494-ERND-0201- FIELD CONNECTIONS DRUM  
SADDLE SUPPORT BEAM DETAILS.  
"ER90"

00	FIRST ISSUE	17-FEB-16	TA	BJD	--		FRY
Rev.	Description	Date	Drawn	Chkd. 1	Chkd. 2		Appr.

This drawing contains Vogt Power International's confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, except with the express written permission of Vogt Power International. EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING THE WARRANTIES OF MERCHANTABILITY AND FITNESS, ARE DISCLAIMED.

© Vogt Power International, Inc. All rights reserved as an unpublished work.

<p>MIDDLETOWN ENERGY CENTER and KINGS MOUNTAIN ENERGY CENTER for NTE ENERGY and GEMMA POWER SYSTEMS</p>	<p>3rd ANGLE PROJECTION</p> 
<p>VOGT POWER PROJECTS V17494 &amp; V17495</p>	<p>Scale: 3/4" = 1'-0"</p>

Title	FIELD CONNECTIONS DRUM SADDLE SUPPORT BEAM INSTALLATION ER90
-------	--

**Voot Power**  
International

13551 Triton Park Blvd  
Suite 2000  
Louisville, Ky. 40223 USA  
[www.VootPower.com](http://www.VootPower.com)

Internal Drawing Status <b>FOR RECORD</b>	Size <b>D</b>	Drawing No. <b>V17494-ERND-0200</b>	Rev. <b>00</b>
--	------------------	--	-------------------