

# Air Compressor Mode Identification Using Real-Time Clustering Methods for Efficiency Degradation Detection

Seán Martin Hayes · D.T.J. O'Sullivan

Received: date / Accepted: date

**Abstract** Insert your abstract here. Include keywords, PACS and mathematical subject classification numbers as needed.

**Keywords** First keyword · Second keyword · More

## 1 Introduction

In 2012 industry consumed 2,542 Mtoe of energy globally, which represented over 28% of the 8,980 Mtoe of global final energy consumption IEA (2012). In an Irish context, industry consumed 2.26 Mtoe of energy in 2012, representing almost 22% of Ireland's 10.3 Mtoe of final energy consumption. Within the category of industrial energy, compressed air is recognised as an energy intensive utility, accounting for 10% of industrial electricity in the European Union Saidur et al (2010). Energy costs typically account for 78% of the total life cycle cost of a compressed air system Radgen (2006). Compressed air is known colloquially in industry as the fourth fuel, due to the high electrical cost associated with generation. Compressed air systems are typically running at 19% overall system efficiency Saidur et al (2010), due to energy losses largely due to lost heat of generation and leakages.

Compressed air has been recognised as having significant energy saving potential in the food industry Wang (2014), not least through measures such as retrofitting of variable speed drives, inlet air temperature reduction, waste heat re-

covery, and pressure and leakage reduction (cite Wang 2008 from Wang 2014 paper).

## 2 Thermodynamics of Air Compression

The thermodynamics of air compression are outlined in Figure 1.


## 3 Determining the operational performance of an air compressor

A wide range of configurations and types of compressed air systems are installed in industry. In many cases there exist systems which are running sub-optimally, either due to unsuitability for the task at hand or running in a faulty condition. Given that compressed air represents such a dense form of energy transport, it is beneficial in terms of long and short term overall energy efficiency goals to manage the performance of air compressors. Performance management is typically achieved through means such as those in Table 1. The key disadvantages of existing methods are either that they are manual and periodic in nature, or that they require the intervention of a human expert in compressed air systems to be effective. In the case of maintenance contracts and periodic audits, there is also the potential for unnecessary work to be carried out, as both these measures are typically carried out on a timescale basis. The intervention of a human expert also lends itself to an inefficient method of performance measurement. An expert may be particularly well versed with one type of system, but not another. The disparate range of compressed air systems can lead to an expert restricting themselves to one type of system, preventing possible lessons learned to be applied in other suitable cases.

In order to analyse a particular compressed air system it is useful to understand how it might relate to other instal-

---

Seán Martin Hayes · D.T.J. O'Sullivan  
School of Engineering  
University College Cork  
Ireland  
Tel.: +353-21-4902913  
Fax: +353-21-4276648  
E-mail: sean.m.hayes@umail.ucc.ie



**Fig. 1** Thermodynamics of Air Compression

**Table 1** Existing Compressed Air System Performance Management Methods

Performance Management Method	Advantages	Disadvantages
Maintenance Contracts Periodic Audits	Security of asset reliability Likely to pick up on common opportunities for improvement	Potential for unnecessary work Dependent on skill level of auditor
Sequence Controllers	Can draw on manufacturer knowledge of system operation	Initial configuration may not be maintained due to system changes
BMS Monitoring	Desk-based site wide monitoring capability	Dependent on skill level of BMS reviewer. Unable to pick up on sensor errors


lations. The system analysed in this paper consists of two rotary tooth air compressors with a heated desiccant dryer, with the layout given in Figure 2. These machines are rotary tooth type machines, which are widely deployed across industry for applications with medium pressure and capacity requirements, as shown in Figure 3 SEAI (2007). The various types of compressors typically used in industry are shown in Figure 4. Reciprocating and rotary machines are both positive displacement type machines. They work through isolation of a quantity of air in a space which is then reduced in volume. Centrifugal machines are aerodynamic machines, which operate by imparting kinetic energy to air, which is then converted to pressure energy by stopping the moving air. The three most common types of compressor in industry are rotary, reciprocating and centrifugal machines. The application ranges of these types are shown in Figure 3 SEAI (2007).

Research is being carried out to define the future of compressed air system performance management. In this review the research considered is that of ongoing analysis of compressed air system data. This ongoing analysis could be designated as having any of the goals outlined in Table 2.


### 3.1 Current research into performance management

Figure 5.


Quantitative model based methods are summarised in ...



**Fig. 2** Test Site Compressed Air System Layout



**Fig. 4** Compressor Types



**Fig. 5** Current research into performance management methods

**Table 3** Quantitative model based methods

Method	Description	Benefits	Disadvantages	Examples
Kalman Filters	A Kalman filter allows the combination of observed and predicted parameters to more accurately predict future parameters than with a physical model alone. It also allows for the reduction of the effects of noisy data on models.	Very accurate  Transients may be modelled	Computationally expensive  Complex to create  Typically require many inputs from system	Surge control for axial compressors Backi et al (2013) Fault detection for gas turbine compressors Salar et al (2010) State estimation of a thermal power plant Nair et al (2011)) Leakage detection of a pneumatic network Krichel and Sawodny (2011)
Diagnostic Observers	Employing state observers, typically one for each fault, which represent a different output from a model, in order that observed differences in outputs may be attributed to faults to how to change a model to remove deviations from expected behaviour	Accurate isolation of individual faults possible	Observers required for each individual potential fault state	Fault detection of a steam boiler feed water preheater Tarantino et al (2000) Estimation of a steam boilers pressure given fuel and feed water conditions Ramezanifar et al (2006) Surge control for axial compressors Backi et al (2013)
Parity Relations	Rearranging and transforming input-output models of a system in order to highlight individual fault conditions	Accurate isolation of individual faults possible	Less effective at identifying multiplicative faults	Fault diagnosis of a wind farm using interval non-linear parameter-varying parity equations Blesa et al (2014)
Parameter Estimation	Comparison of modelled data, normally using ordinary and partial differential equations, with measured data, with analysis of any residuals to diagnose faults	High level of confidence in modelled data	Detailed physical model required for accuracy	Optimisation of the modelling of a multi-stage compressor using parameter estimation to determine the surge line Dapeng Niu et al (2011)

**Table 4** Qualitative model based methods

Method	Description	Benefits	Disadvantages	Examples
Expert Systems	Using if-then-else rules derived from engineering knowledge of a systems operation to flag when and why a fault is present in operation	Quick deployment potential	Potential that knowledge remains undiscovered/undocumented	Fault diagnosis assistance using IF-THEN rules for an air compressor Liu (2001)
Physical Redundancy	Installing parallel sensors in order that site personnel be notified of an error if sensor values do not match	Simple in concept	Cost and space constraints may limit additional sensor placement	Analysis framework of fault detection schemes based on redundant sensors for aircraft Wheeler et al (2011)
Analytical Hierarchy Process	Decision support for selection of a particular approach, e.g. for maintenance strategy, over another based on pairwise comparisons of suitability toward various goals	Allows documentation of expert decision making in formal manner	Limited real-time performance analysis potential	Maintenance strategy selection for equipment at an oil refinery Bevilacqua and Braglia (2000)
Spectrum Analysis	Analysis of compressor drive and vibrational frequency response to alert when response drifts from normal	Allows for discovery of faults which may be difficult to postulate from first principles	Detailed analysis required for each potential spectrum case	Vibration analysis of reciprocating compressors for valve failure diagnosis Ruilin Lin et al (2010)
Fault Tree Analysis	Postulation of potential areas of failure in equipment	Allows formal documentation of human expert knowledge	Scope of fault detection is as limited as human experts knowledge and expertise	Reliability assessment of an anti-surge control system for a centrifugal compressor Ren et al (2012)
FMEA / FMECA	Analysis of site equipment potential areas of failure and potential effect on other equipment	Critical analysis of most risk-prone areas of a system	Time consuming for development	Compressor safety evaluation model Zhu et al (2013)
Qualitative Physics Based	Derivation of qualitative equations from fundamental physical equations governing system operation to allow for analysis without explicit requirement for numerical values	No requirement for numerically accurate measurement of system variables	Requires initial understanding of physical processes governing system operation	Fault Detection for an AHU Glass et al (1995)
Digraphs	Representation of qualitative models using directed graphs to efficiently incorporate system behaviour for effective analysis	Allows visual representation of qualitative physical equations	Requires considerable domain expertise for creation	FDD for a typical industrial process using SDG for model decomposition Shin et al (2007)
Limits and Alarms	Implementation of user defined limits on key parameters which flag when exceeded or are not met	With correct identification of thresholds can quickly highlight issues with systems	Little diagnosis and isolation potential Correct selection of thresholds dependent on user expertise	Incorporated into modern compressor PLCs



Table 5 – continued from previous page

Method	Description	Benefits	Disadvantages	Examples
Table 5: Process history based methods				
Support Vector Machine / Relevance Vector Machine	A supervised learning technique which when given a sample data set which is labelled according to which class each point belongs in, can determine the optimal plane which splits classes allowing accurate future classification of variables	Can accurately classify non-linear data	Can be computationally expensive in implementation	Compressed air load forecasting for large flows Liu et al (2013); Fault diagnosis for reciprocating air compressor valves Wang et al (2010), Cui et al (2009), Qin et al (2012), James Li and Yu (1995); Fault diagnosis for reciprocating air compressors Verma et al (2011)
PCA	Analysis of a population of variables to determine the population extremes in a given number of directions or components, allowing categorisation of each data point in terms of its position in each direction	Decreased sensitivity of data analysis to noise  Reduced dimensionality increases data understanding	Training data must explicitly demonstrate variance in data	Sensor fault detection, diagnosis and estimation for centrifugal chillers Wang and Cui (2005) Fault detection and isolation for a centrifugal compressor Zanolli and Astolfi (2013) Sensor and actuator fault diagnosis for a centrifugal compressor Zanolli et al (2010a)
Artificial Neural Networks	Creation of a network of elements or neurons which may determine output values based on interconnected element's response to external inputs. Networks may be supervised where instances of faulty operation are labelled, allowing the network to generate expected outputs for arbitrary unknown inputs. Networks may also be unsupervised, in which case the topology is adaptively determined based on the inputs.	Can effectively predict non-linear relationships in data	Structure of neural network requires intuitive development	Valve failure detection for reciprocating compressors (Namdeo et al. 2008) Neural network based fault diagnosis of a reciprocating compressor employing genetic algorithms for initial parameter identification Jinru et al (2008)




Table 5 – continued from previous page

Method	Description	Benefits	Disadvantages	Examples
				Performance prediction of a centrifugal air compressor employing artificial neural networks and genetic algorithms Luo Fangqiong and Huang Shengzhong (2011) Generation of a gas generators compressor performance characteristic map Ghorbanian and Gholamrezaei (2009) Yu et al (2007)
Genetic Algorithms	Determining the optimum point a system can operate at, by selecting random members of a population of samples and using them as parents of successive samples, which tend toward the optimal sample	Easily transferred to existing simulations and models	No assurance that optimal application will indeed be the global optimum	Noise minimisation of a hermetic compressor Dasilva (2004) Neural network based fault diagnosis of a reciprocating compressor employing genetic algorithms for initial parameter identification Jinru et al (2008) Performance prediction of a centrifugal air compressor employing artificial neural networks and genetic algorithms Luo Fangqiong and Huang Shengzhong (2011) Parameter identification for a centrifugal compressor model Xi-aogang et al (2013)
Decision Tree Learning	Automatic classification of output variables by organising data into subsets, generating rules in a tree like structure	Require reasonably low data preparation effort	Highly unstable when perturbations in training data are present	Fault diagnosis for a modular production system Demetgul (2013)

Table 5 – continued from previous page

Method	Description	Benefits	Disadvantages	Examples
Deep Belief Networks	Stacked Restricted Boltzmann Machines (RBMs), which are themselves simple unsupervised neural networks	Allow more complex understanding of data relationships than with lower level machine learning techniques	Complex to initially understand structure	Reciprocating compressor valve fault diagnosis Tran et al (2014)
Clustering	Grouping data readings into different groups where intragroup similarity is greater than intergroup similarity	Relatively simple to deploy	Some qualitative assessment for optimal number of clusters may be required	Fault detection and isolation for a centrifugal compressor based on PCA and Clustering Zanolli et al (2010b) Adaptive clustering for pneumatic system fault detection Petković et al (2012)
Bayesian Networks	Creation by learning or using prior knowledge of graphical probabilistic models which give relationships between variables	Can provide an excellent interpolation to real world simulations	Calculation of parameters for Bayesian models can be initially difficult	Fault diagnosis of a pneumatic air braking system Lingling (2010) Fault detection via classification of compressor variables compressed dimensionally via PCA Liu and Chen (2009)
Regression Modelling	Statistical estimation of the relationship between two or more variables	Reasonably low effort required for deployment with concept simple to understand	Requires strongly defined relationships between variables to be of any use	Optimisation of a network of compressors in parallel Kopanos et al (2015)



**Fig. 3** Compressor Application Suitability

**Table 2** Goals of Performance Management

Goal	Description	Example Work
Fault Detection and Diagnosis	Monitor system parameters to determine when system is in fault condition and the potential reasons for the identified fault	Using vibration, pressure and current signals to diagnose valve faults for a reciprocating compressor Tran et al (2014)
Prognostics	Monitoring system parameters to determine when a component of a system will no longer perform its intended function Vachtsevanos et al (2006)	Determining the remaining useful life of a gaseous circuit breaker based on gas pressure and ambient temperature Catterson and Costello (2013)
Analytics	Monitoring system parameters to discover meaningful patterns which may advise on potential improvements to system operation	Determining abnormal appliance power consumption based on analysis of individual appliances acoustic noise Pathak et al (2015)
Automated Commissioning	Achieving, verifying and documenting that the performance of a system satisfies the current user requirement	Automatically carrying out the normal testing procedure for an air compressor by replicating the tasks normally carried out during commissioning Mazid and Martin (2008)
Optimisation	Improving system operation or design as measured against some defined criteria	Development of a tool which delivers an optimal design for a compressed air system based on energy and life cycle costing Friden et al (2012)
Control	Managing the operation of a system in order that operating conditions remain in line with design states and undesirable states are avoided	Development of a control algorithm for fixed speed compressors that provides the pressure control capabilities of a variable speed system while limiting energy consumption Facchinetti et al (???)

Lorem ipsum dolor sit amet, consectetur adipiscing elit. Ut purus elit, vestibulum ut, placerat ac, adipiscing vitae, felis. Curabitur dictum gravida mauris. Nam arcu libero, nonummy eget, consectetur id, vulputate a, magna. Donec vehicula augue eu neque. Pellentesque habitant morbi tristique senectus et netus et malesuada fames ac turpis egestas. Mauris ut leo. Cras viverra metus rhoncus sem. Nulla et lectus vestibulum urna fringilla ultrices. Phasellus eu tellus sit amet tortor gravida placerat. Integer sapien est, iaculis in, pretium quis, viverra ac, nunc. Praesent eget sem vel leo ultrices bibendum. Aenean faucibus. Morbi dolor nulla, malesuada eu, pulvinar at, mollis ac, nulla. Curabitur auctor semper nulla. Donec varius orci eget risus. Duis nibh mi, congue eu, accumsan eleifend, sagittis quis, diam. Duis eget orci sit amet orci dignissim rutrum.

Nam dui ligula, fringilla a, euismod sodales, sollicitudin vel, wisi. Morbi auctor lorem non justo. Nam lacus libero, pretium at, lobortis vitae, ultricies et, tellus. Donec aliquet, tortor sed accumsan bibendum, erat ligula aliquet magna, vitae ornare odio metus a mi. Morbi ac orci et nisl hendrerit mollis. Suspendisse ut massa. Cras nec ante. Pellentesque a nulla. Cum sociis natoque penatibus et magnis dis parturient montes, nascetur ridiculus mus. Aliquam tincidunt urna. Nulla ullamcorper vestibulum turpis. Pellentesque cursus luctus mauris.

Nulla malesuada porttitor diam. Donec felis erat, congue non, volutpat at, tincidunt tristique, libero. Vivamus viverra fermentum felis. Donec nonummy pellentesque ante. Phasellus adipiscing semper elit. Proin fermentum massa ac quam. Sed diam turpis, molestie vitae, placerat a, molestie nec, leo. Maecenas lacinia. Nam ipsum ligula, eleifend at, accumsan nec, suscipit a, ipsum. Morbi blandit ligula feugiat magna. Nunc eleifend consequat lorem. Sed lacinia nulla vitae enim. Pellentesque tincidunt purus vel magna. Integer non enim. Praesent euismod nunc eu purus. Donec bibendum quam in tellus. Nullam cursus pulvinar lectus. Donec et mi. Nam vulputate metus eu enim. Vestibulum pellentesque felis eu massa.

Quisque ullamcorper placerat ipsum. Cras nibh. Morbi vel justo vitae lacus tincidunt ultrices. Lorem ipsum dolor sit amet, consectetur adipiscing elit. In hac habitasse platea dictumst. Integer tempus convallis augue. Etiam facilisis. Nunc elementum fermentum wisi. Aenean placerat. Ut imperdiet, enim sed gravida sollicitudin, felis odio placerat quam, ac pulvinar elit purus eget enim. Nunc vitae tortor. Proin tempus nibh sit amet nisl. Vivamus quis tortor vitae risus porta vehicula.

Fusce mauris. Vestibulum luctus nibh at lectus. Sed bibendum, nulla a faucibus semper, leo velit ultricies tellus, ac venenatis arcu wisi vel nisl. Vestibulum diam. Aliquam pellentesque, augue quis sagittis posuere, turpis lacus congue quam, in hendrerit risus eros eget felis. Maecenas eget erat in sapien mattis porttitor. Vestibulum porttitor. Nulla facil-

isi. Sed a turpis eu lacus commodo facilisis. Morbi fringilla, wisi in dignissim interdum, justo lectus sagittis dui, et vehicula libero dui cursus dui. Mauris tempor ligula sed lacus. Duis cursus enim ut augue. Cras ac magna. Cras nulla. Nulla egestas. Curabitur a leo. Quisque egestas wisi eget nunc. Nam feugiat lacus vel est. Curabitur consectetur.

Suspendisse vel felis. Ut lorem lorem, interdum eu, tincidunt sit amet, laoreet vitae, arcu. Aenean faucibus pede eu ante. Praesent enim elit, rutrum at, molestie non, nonummy vel, nisl. Ut lectus eros, malesuada sit amet, fermentum eu, sodales cursus, magna. Donec eu purus. Quisque vehicula, urna sed ultricies auctor, pede lorem egestas dui, et convallis elit erat sed nulla. Donec luctus. Curabitur et nunc. Aliquam dolor odio, commodo pretium, ultricies non, pharetra in, velit. Integer arcu est, nonummy in, fermentum faucibus, egestas vel, odio.

Sed commodo posuere pede. Mauris ut est. Ut quis purus. Sed ac odio. Sed vehicula hendrerit sem. Duis non odio. Morbi ut dui. Sed accumsan risus eget odio. In hac habitasse platea dictumst. Pellentesque non elit. Fusce sed justo eu urna porta tincidunt. Mauris felis odio, sollicitudin sed, volutpat a, ornare ac, erat. Morbi quis dolor. Donec pellentesque, erat ac sagittis semper, nunc dui lobortis purus, quis congue purus metus ultricies tellus. Proin et quam. Class aptent taciti sociosqu ad litora torquent per conubia nostra, per inceptos hymenaeos. Praesent sapien turpis, fermentum vel, eleifend faucibus, vehicula eu, lacus.

Pellentesque habitant morbi tristique senectus et netus et malesuada fames ac turpis egestas. Donec odio elit, dictum in, hendrerit sit amet, egestas sed, leo. Praesent feugiat sapien aliquet odio. Integer vitae justo. Aliquam vestibulum fringilla lorem. Sed neque lectus, consectetur at, consectetur sed, eleifend ac, lectus. Nulla facilisi. Pellentesque eget lectus. Proin eu metus. Sed porttitor. In hac habitasse platea dictumst. Suspendisse eu lectus. Ut mi mi, lacinia sit amet, placerat et, mollis vitae, dui. Sed ante tellus, tristique ut, iaculis eu, malesuada ac, dui. Mauris nibh leo, facilisis non, adipiscing quis, ultrices a, dui.

Morbi luctus, wisi viverra faucibus pretium, nibh est placerat odio, nec commodo wisi enim eget quam. Quisque libero justo, consectetur a, feugiat vitae, porttitor eu, libero. Suspendisse sed mauris vitae elit sollicitudin malesuada. Maecenas ultricies eros sit amet ante. Ut venenatis velit. Maecenas sed mi eget dui varius euismod. Phasellus aliquet volutpat odio. Vestibulum ante ipsum primis in faucibus orci luctus et ultrices posuere cubilia Curae; Pellentesque sit amet pede ac sem eleifend consectetur. Nullam elementum, urna vel imperdiet sodales, elit ipsum pharetra ligula, ac pretium ante justo a nulla. Curabitur tristique arcu eu metus. Vestibulum lectus. Proin mauris. Proin eu nunc eu urna hendrerit faucibus. Aliquam auctor, pede consequat laoreet varius, eros tellus scelerisque quam, pellentesque hendrerit ipsum dolor sed augue. Nulla nec lacus.

Suspendisse vitae elit. Aliquam arcu neque, ornare in, ullamcorper quis, commodo eu, libero. Fusce sagittis erat at erat tristique mollis. Maecenas sapien libero, molestie et, lobortis in, sodales eget, dui. Morbi ultrices rutrum lorem. Nam elementum ullamcorper leo. Morbi dui. Aliquam sagittis. Nunc placerat. Pellentesque tristique sodales est. Maecenas imperdiet lacinia velit. Cras non urna. Morbi eros pede, suscipit ac, varius vel, egestas non, eros. Praesent malesuada, diam id pretium elementum, eros sem dictum tortor, vel consectetur odio sem sed wisi.

#### 4 Rule base development and testing

One of the approaches for performance management of air compressors outlined in subsection 3.1 is that of Expert Systems. This is a qualitative method which can use rule sets to encode expert knowledge about a system for flagging when a fault in operation is present. This method has been used with success in the case of HVAC (Bruton et al (2014), House et al (2001)) and the area of air compressors (Liu (2001)). Rules for system analysis are typically derived by taking a fundamental engineering overview of the system, and hypothesising potential rules to determine particular faults.

Figure 6 shows a high level overview of the test site air compressor, which is a two-stage rotary tooth machine. The figure highlights the expected temperature changes as the compressed air is operated on y each fundamental component. These expected operations form the basis for an initial set of rules to flag when the machine is not operating as expected. To illustrate this point the first element of compression is analysed in detail.

Element 1 of the air compressor compresses air from atmospheric pressure (101 325 Pa) to 250 000 Pa. When the compressor is at minimum loading, it is designed to produce  $41 \text{ L s}^{-1}$  of free air. It is useful to analyse the thermodynamics of compressing air at this point. Figure 1 shows the relevant thermodynamic diagrams for the compression of this volume of air isothermally, adiabatically and polytropically. The air is compressed in a space which is surrounded by ambient air, which is not an ideal heat reservoir. Therefore the isothermal compression case is not valid. The air is not however thermally isolated from its surroundings, therefore the adiabatic case is also not valid. Actual air compression typically follows the polytropic process model, with the polytropic exponent of Equation 1 ranging between 1 and 1.4.

$$P_1 V_1^n = P_2 V_2^n \quad (1)$$

where  $P$  = Absolute pressure (Pa)

$V$  = Absolute volume ( $\text{m}^3$ )

$n$  = Polytropic exponent

Given that the compression process taking place is not isothermal, it is logical to expect that the temperature of the compressed air will increase through the first element of compression, in accordance with Figure 1. If a decrease in temperature is observed, then either a failure in the first stage of compression or in a temperature sensor can be determined. This forms the basis for the first rule of the rule set created for compressor performance analysis, which is summarised in INSERT TABLE REF.

Equation for rule 1

Lorem ipsum dolor sit amet, consectetur adipiscing elit. Ut purus elit, vestibulum ut, placerat ac, adipiscing vitae, felis. Curabitur dictum gravida mauris. Nam arcu libero, nonummy eget, consectetur id, vulputate a, magna. Donec vehicula augue eu neque. Pellentesque habitant morbi tristique senectus et netus et malesuada fames ac turpis egestas. Mauris ut leo. Cras viverra metus rhoncus sem. Nulla et lectus vestibulum urna fringilla ultrices. Phasellus eu tellus sit amet tortor gravida placerat. Integer sapien est, iaculis in, pretium quis, viverra ac, nunc. Praesent eget sem vel leo ultrices bibendum. Aenean faucibus. Morbi dolor nulla, malesuada eu, pulvinar at, mollis ac, nulla. Curabitur auctor semper nulla. Donec varius orci eget risus. Duis nibh mi, congue eu, accumsan eleifend, sagittis quis, diam. Duis eget orci sit amet orci dignissim rutrum.

Nam dui ligula, fringilla a, euismod sodales, sollicitudin vel, wisi. Morbi auctor lorem non justo. Nam lacus libero, pretium at, lobortis vitae, ultricies et, tellus. Donec aliquet, tortor sed accumsan bibendum, erat ligula aliquet magna, vitae ornare odio metus a mi. Morbi ac orci et nisl hendrerit mollis. Suspendisse ut massa. Cras nec ante. Pellentesque a nulla. Cum sociis natoque penatibus et magnis dis parturient montes, nascetur ridiculus mus. Aliquam tincidunt urna. Nulla ullamcorper vestibulum turpis. Pellentesque cursus luctus mauris.

Nulla malesuada porttitor diam. Donec felis erat, congue non, volutpat at, tincidunt tristique, libero. Vivamus viverra fermentum felis. Donec nonummy pellentesque ante. Phasellus adipiscing semper elit. Proin fermentum massa ac quam. Sed diam turpis, molestie vitae, placerat a, molestie nec, leo. Maecenas lacinia. Nam ipsum ligula, eleifend at, accumsan nec, suscipit a, ipsum. Morbi blandit ligula feugiat magna. Nunc eleifend consequat lorem. Sed lacinia nulla vitae enim. Pellentesque tincidunt purus vel magna. Integer non enim. Praesent euismod nunc eu purus. Donec bibendum quam in tellus. Nullam cursus pulvinar lectus. Donec et mi. Nam vulputate metus eu enim. Vestibulum pellentesque felis eu massa.

Quisque ullamcorper placerat ipsum. Cras nibh. Morbi vel justo vitae lacus tincidunt ultrices. Lorem ipsum dolor sit amet, consectetur adipiscing elit. In hac habitasse platea dictumst. Integer tempus convallis augue. Etiam facilisis. Nunc elementum fermentum wisi. Aenean placerat. Ut im-

perdiet, enim sed gravida sollicitudin, felis odio placerat quam, ac pulvinar elit purus eget enim. Nunc vitae tortor. Proin tempus nibh sit amet nisl. Vivamus quis tortor vitae risus porta vehicula.

Fusce mauris. Vestibulum luctus nibh at lectus. Sed bibendum, nulla a faucibus semper, leo velit ultricies tellus, ac venenatis arcu wisi vel nisl. Vestibulum diam. Aliquam pellentesque, augue quis sagittis posuere, turpis lacus congue quam, in hendrerit risus eros eget felis. Maecenas eget erat in sapien mattis porttitor. Vestibulum porttitor. Nulla facilisi. Sed a turpis eu lacus commodo facilisis. Morbi fringilla, wisi in dignissim interdum, justo lectus sagittis dui, et vehicula libero dui cursus dui. Mauris tempor ligula sed lacus. Duis cursus enim ut augue. Cras ac magna. Cras nulla. Nulla egestas. Curabitur a leo. Quisque egestas wisi eget nunc. Nam feugiat lacus vel est. Curabitur consectetur.

Suspendisse vel felis. Ut lorem lorem, interdum eu, tincidunt sit amet, laoreet vitae, arcu. Aenean faucibus pede eu ante. Praesent enim elit, rutrum at, molestie non, nonummy vel, nisl. Ut lectus eros, malesuada sit amet, fermentum eu, sodales cursus, magna. Donec eu purus. Quisque vehicula, urna sed ultricies auctor, pede lorem egestas dui, et convallis elit erat sed nulla. Donec luctus. Curabitur et nunc. Aliquam dolor odio, commodo pretium, ultricies non, pharetra in, velit. Integer arcu est, nonummy in, fermentum faucibus, egestas vel, odio.

Sed commodo posuere pede. Mauris ut est. Ut quis purus. Sed ac odio. Sed vehicula hendrerit sem. Duis non odio. Morbi ut dui. Sed accumsan risus eget odio. In hac habitasse platea dictumst. Pellentesque non elit. Fusce sed justo eu urna porta tincidunt. Mauris felis odio, sollicitudin sed, volutpat a, ornare ac, erat. Morbi quis dolor. Donec pellentesque, erat ac sagittis semper, nunc dui lobortis purus, quis congue purus metus ultricies tellus. Proin et quam. Class aptent taciti sociosqu ad litora torquent per conubia nostra, per inceptos hymenaeos. Praesent sapien turpis, fermentum vel, eleifend faucibus, vehicula eu, lacus.

Pellentesque habitant morbi tristique senectus et netus et malesuada fames ac turpis egestas. Donec odio elit, dictum in, hendrerit sit amet, egestas sed, leo. Praesent feugiat sapien aliquet odio. Integer vitae justo. Aliquam vestibulum fringilla lorem. Sed neque lectus, consectetur at, consectetur sed, eleifend ac, lectus. Nulla facilisi. Pellentesque eget lectus. Proin eu metus. Sed porttitor. In hac habitasse platea dictumst. Suspendisse eu lectus. Ut mi mi, lacinia sit amet, placerat et, mollis vitae, dui. Sed ante tellus, tristique ut, iaculis eu, malesuada ac, dui. Mauris nibh leo, facilisis non, adipiscing quis, ultrices a, dui.

Morbi luctus, wisi viverra faucibus pretium, nibh est placerat odio, nec commodo wisi enim eget quam. Quisque libero justo, consectetur a, feugiat vitae, porttitor eu, libero. Suspendisse sed mauris vitae elit sollicitudin malesuada. Maecenas ultricies eros sit amet ante. Ut venenatis velit. Maecenas

sed mi eget dui varius euismod. Phasellus aliquet volutpat odio. Vestibulum ante ipsum primis in faucibus orci luctus et ultrices posuere cubilia Curae; Pellentesque sit amet pede ac sem eleifend consectetur. Nullam elementum, urna vel imperdiet sodales, elit ipsum pharetra ligula, ac pretium ante justo a nulla. Curabitur tristique arcu eu metus. Vestibulum lectus. Proin mauris. Proin eu nunc eu urna hendrerit faucibus. Aliquam auctor, pede consequat laoreet varius, eros tellus scelerisque quam, pellentesque hendrerit ipsum dolor sed augue. Nulla nec lacus.


Suspendisse vitae elit. Aliquam arcu neque, ornare in, ullamcorper quis, commodo eu, libero. Fusce sagittis erat at erat tristique mollis. Maecenas sapien libero, molestie et, lobortis in, sodales eget, dui. Morbi ultrices rutrum lorem. Nam elementum ullamcorper leo. Morbi dui. Aliquam sagittis. Nunc placerat. Pellentesque tristique sodales est. Maecenas imperdiet lacinia velit. Cras non urna. Morbi eros pede, suscipit ac, varius vel, egestas non, eros. Praesent malesuada, diam id pretium elementum, eros sem dictum tortor, vel consectetur odio sem sed wisi.

Figure 7 shows the mechanical layout of a two stage air compressor.

**Table 7** Rule set naming convention

Reference	Item
T1	Plant Room Temperature
T2	Element 1 Outlet Temperature
T3	Element 2 Inlet Temperature
T4	Element 2 Outlet Temperature
T5	Final Delivery Temperature
P1	Compressed Air Pressure in Intercooler
P2	Compressed Air Final Delivery Pressure
P3	Compressed Air Receiver Pressure
N1	Motor starts per 5 minutes
P10	Oil Pressure
P11	Ambient Pressure
C1	Element 1
C2	Intercooler
C3	Element 2
C4	After Cooler
C5	Motor
C6	Oil Pump
C7	Load/Unload Valve

Lorem ipsum dolor sit amet, consectetur adipiscing elit. Ut purus elit, vestibulum ut, placerat ac, adipiscing vitae, felis. Curabitur dictum gravida mauris. Nam arcu libero, nonummy eget, consectetur id, vulputate a, magna. Donec vehicula augue eu neque. Pellentesque habitant morbi tristique senectus et netus et malesuada fames ac turpis egestas. Mauris ut leo. Cras viverra metus rhoncus sem. Nulla et lectus vestibulum urna fringilla ultrices. Phasellus eu tellus sit amet tortor gravida placerat. Integer sapien est, iaculis in, pretium quis, viverra ac, nunc. Praesent eget sem vel leo ultrices bibendum. Aenean faucibus. Morbi dolor nulla, male-



**Fig. 6** Two stage compressor air flow

**Table 6** Compressor performance assessment rule set

Rules		Potential Faults															
ID	Description	T1	T2	T3	T4	T5	P1	P2	N1	P10	C1	C2	C3	C4	C5	C6	C7
1	Element 1 Temperature Decrease	X	X								X						
2	Intercooler Temperature Increase		X	X								X					
3	Element 2 Temperature Decrease			X									X				
4	Aftercooler Temperature Increase				X	X								X			
5	Plant Room Temperature High	X															
6	Element 1 Outlet Temperature High		X								X						
7	Element 2 Inlet Temperature High			X								X					
8	Element 2 Outlet Temperature High				X								X				
9	Final Outlet Temperature High					X								X			
10	Expected Intercooler Pressure not Achieved						X				X						
11	Increase in Outlet Pressure when Unloaded							X									X
12	High Stop-Start Frequency of Motor Observed								X						X		
13	Failure of Oil Pressure to Rise under Loading									X						X	
14	Theoretical Element 1 Temperature Rise Exceeded		X								X						
15	Theoretical Element 2 Temperature Rise Exceeded				X								X				


suada eu, pulvinar at, mollis ac, nulla. Curabitur auctor semper nulla. Donec varius orci eget risus. Duis nibh mi, congue eu, accumsan eleifend, sagittis quis, diam. Duis eget orci sit amet orci dignissim rutrum.

Nam dui ligula, fringilla a, euismod sodales, sollicitudin vel, wisi. Morbi auctor lorem non justo. Nam lacus libero, pretium at, lobortis vitae, ultricies et, tellus. Donec aliquet, tortor sed accumsan bibendum, erat ligula aliquet magna, vitae ornare odio metus a mi. Morbi ac orci et nisl hendrerit

mollis. Suspendisse ut massa. Cras nec ante. Pellentesque a nulla. Cum sociis natoque penatibus et magnis dis parturient montes, nascetur ridiculus mus. Aliquam tincidunt urna. Nulla ullamcorper vestibulum turpis. Pellentesque cursus luctus mauris.

Nulla malesuada porttitor diam. Donec felis erat, congue non, volutpat at, tincidunt tristique, libero. Vivamus viverra fermentum felis. Donec nonummy pellentesque ante. Phasellus adipiscing semper elit. Proin fermentum massa ac quam.





**Fig. 7** Mechanical drive two stage compressor

Sed diam turpis, molestie vitae, placerat a, molestie nec, leo. Maecenas lacinia. Nam ipsum ligula, eleifend at, accumsan nec, suscipit a, ipsum. Morbi blandit ligula feugiat magna. Nunc eleifend consequat lorem. Sed lacinia nulla vitae enim. Pellentesque tincidunt purus vel magna. Integer non enim. Praesent euismod nunc eu purus. Donec bibendum quam in tellus. Nullam cursus pulvinar lectus. Donec et mi. Nam vulputate metus eu enim. Vestibulum pellentesque felis eu massa.

Quisque ullamcorper placerat ipsum. Cras nibh. Morbi vel justo vitae lacus tincidunt ultrices. Lorem ipsum dolor sit amet, consectetur adipiscing elit. In hac habitasse platea dictumst. Integer tempus convallis augue. Etiam facilisis. Nunc elementum fermentum wisi. Aenean placerat. Ut imperdiet, enim sed gravida sollicitudin, felis odio placerat quam, ac pulvinar elit purus eget enim. Nunc vitae tortor. Proin tempus nibh sit amet nisl. Vivamus quis tortor vitae risus porta vehicula.

Fusce mauris. Vestibulum luctus nibh at lectus. Sed bibendum, nulla a faucibus semper, leo velit ultricies tellus, ac venenatis arcu wisi vel nisl. Vestibulum diam. Aliquam pellentesque, augue quis sagittis posuere, turpis lacus congue quam, in hendrerit risus eros eget felis. Maecenas eget erat in sapien mattis porttitor. Vestibulum porttitor. Nulla facilisi. Sed a turpis eu lacus commodo facilisis. Morbi fringilla,

wisi in dignissim interdum, justo lectus sagittis dui, et vehicula libero dui cursus dui. Mauris tempor ligula sed lacus. Duis cursus enim ut augue. Cras ac magna. Cras nulla. Nulla egestas. Curabitur a leo. Quisque egestas wisi eget nunc. Nam feugiat lacus vel est. Curabitur consectetur.

Suspendisse vel felis. Ut lorem lorem, interdum eu, tincidunt sit amet, laoreet vitae, arcu. Aenean faucibus pede eu ante. Praesent enim elit, rutrum at, molestie non, nonummy vel, nisl. Ut lectus eros, malesuada sit amet, fermentum eu, sodales cursus, magna. Donec eu purus. Quisque vehicula, urna sed ultricies auctor, pede lorem egestas dui, et convallis elit erat sed nulla. Donec luctus. Curabitur et nunc. Aliquam dolor odio, commodo pretium, ultricies non, pharetra in, velit. Integer arcu est, nonummy in, fermentum faucibus, egestas vel, odio.

Sed commodo posuere pede. Mauris ut est. Ut quis purus. Sed ac odio. Sed vehicula hendrerit sem. Duis non odio. Morbi ut dui. Sed accumsan risus eget odio. In hac habitasse platea dictumst. Pellentesque non elit. Fusce sed justo eu urna porta tincidunt. Mauris felis odio, sollicitudin sed, volutpat a, ornare ac, erat. Morbi quis dolor. Donec pellentesque, erat ac sagittis semper, nunc dui lobortis purus, quis congue purus metus ultricies tellus. Proin et quam. Class aptent taciti sociosqu ad litora torquent per conubia nostra,

per inceptos hymenaeos. Praesent sapien turpis, fermentum vel, eleifend faucibus, vehicula eu, lacus.

Pellentesque habitant morbi tristique senectus et netus et malesuada fames ac turpis egestas. Donec odio elit, dictum in, hendrerit sit amet, egestas sed, leo. Praesent feugiat sapien aliquet odio. Integer vitae justo. Aliquam vestibulum fringilla lorem. Sed neque lectus, consectetur at, consectetur sed, eleifend ac, lectus. Nulla facilisi. Pellentesque eget lectus. Proin eu metus. Sed porttitor. In hac habitasse platea dictumst. Suspendisse eu lectus. Ut mi mi, lacinia sit amet, placerat et, mollis vitae, dui. Sed ante tellus, tristique ut, iaculis eu, malesuada ac, dui. Mauris nibh leo, facilisis non, adipiscing quis, ultrices a, dui.

Morbi luctus, wisi viverra faucibus pretium, nibh est placerat odio, nec commodo wisi enim eget quam. Quisque libero justo, consectetur a, feugiat vitae, porttitor eu, libero. Suspendisse sed mauris vitae elit sollicitudin malesuada. Maecenas ultricies eros sit amet ante. Ut venenatis velit. Maecenas sed mi eget dui varius euismod. Phasellus aliquet volutpat odio. Vestibulum ante ipsum primis in faucibus orci luctus et ultrices posuere cubilia Curae; Pellentesque sit amet pede ac sem eleifend consectetur. Nullam elementum, urna vel imperdiet sodales, elit ipsum pharetra ligula, ac pretium ante justo a nulla. Curabitur tristique arcu eu metus. Vestibulum lectus. Proin mauris. Proin eu nunc eu urna hendrerit faucibus. Aliquam auctor, pede consequat laoreet varius, eros tellus scelerisque quam, pellentesque hendrerit ipsum dolor sed augue. Nulla nec lacus.

Suspendisse vitae elit. Aliquam arcu neque, ornare in, ullamcorper quis, commodo eu, libero. Fusce sagittis erat at erat tristique mollis. Maecenas sapien libero, molestie et, lobortis in, sodales eget, dui. Morbi ultrices rutrum lorem. Nam elementum ullamcorper leo. Morbi dui. Aliquam sagittis. Nunc placerat. Pellentesque tristique sodales est. Maecenas imperdiet lacinia velit. Cras non urna. Morbi eros pede, suscipit ac, varius vel, egestas non, eros. Praesent malesuada, diam id pretium elementum, eros sem dictum tortor, vel consectetur odio sem sed wisi.

**Table 8** Please write your table caption here

first	second	third
number	number	number
number	number	number

**5 Operational mode identification**

**6 Fault detection effectiveness**

**7 Conclusions and future work**

**8 Background: Air Compressor Operational Concerns**

**9 Variable Speed Compressor Operational Modes**

**10 Clustering for Mode Identification**

**11 Real-Time Analysis Implementation**

**12 Results**

**13 Discussion**

**14 Conclusions**

**15 Section title**

Your text comes here. Separate text sections with

**16 Section X**

Text with citations ? and ?.

16.1 Subsection title

as required. Don’t forget to give each section and subsection a unique label (see Sect. 8).

*Paragraph headings* Use paragraph headings as needed.


$$a^2 + b^2 = c^2 \tag{2}$$



**Fig. 9** Please write your figure caption here

## References

- Backi CJ, Gravdahl JT, Grøtli EI (2013) Nonlinear observer design for a Greitzer compressor model pp 1457–1463
- Bevilacqua M, Braglia M (2000) The analytic hierarchy process applied to maintenance strategy selection. *Reliability Engineering & System Safety* 70(1):71–83, DOI 10.1016/S0951-8320(00)00047-8
- Blesa J, Jimenez P, Rotondo D, Nejari F, Puig V (2014) An Interval NLPV Parity Equations Approach for Fault Detection and Isolation of a Wind Farm. *IEEE Transactions on Industrial Electronics* 0046(c):1–1, DOI 10.1109/TIE.2014.2386293, URL <http://ieeexplore.ieee.org/articleDetails.jsp?arnumber=6998858>
- Bruton K, Raftery P, O'Donovan P, Aughney N, Keane MM, O'Sullivan D (2014) Development and alpha testing of a cloud based automated fault detection and diagnosis tool for Air Handling Units. *Automation in Construction* 39:70–83, DOI 10.1016/j.autcon.2013.12.006, URL <http://linkinghub.elsevier.com/retrieve/pii/S0926580513002276>
- Catterson V, Costello J (2013) Increasing the Adoption of Prognostic Systems for Health Management in the Power Industry. *Chemical Engineering Transactions* 33:271–276, DOI 10.3303/CET1333046, URL <http://www.aidic.it/cet/13/33/046.pdf>
- Cui H, Zhang L, Kang R, Lan X (2009) Research on fault diagnosis for reciprocating compressor valve using information entropy and SVM method. *Journal of Loss Prevention in the Process Industries* 22(6):864–867, DOI 10.1016/j.jlp.2009.08.012, URL <http://dx.doi.org/10.1016/j.jlp.2009.08.012>
- Dapeng Niu, Aiping Shi, Yuqing Chang, Fuli Wang (2011) Modelling of multistage centrifugal compressor. In: *Proceedings of 2011 International Conference on Computer Science and Network Technology*, IEEE, vol 973, pp 1144–1147, DOI 10.1109/ICCSNT.2011.6182163, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=6182163>
- Dasilva AR (2004) Controlling the radiation of hermetic compressors by means of minimization of power through



**Fig. 8** Please write your figure caption here

- discharge pipes using genetic algorithms.2004.pdf. In: International Compressor Engineering Conference
- Demetgul M (2013) Fault diagnosis on production systems with support vector machine and decision trees algorithms. *The International Journal of Advanced Manufacturing Technology* 67(9-12):2183–2194, DOI 10.1007/s00170-012-4639-5, URL <http://link.springer.com/10.1007/s00170-012-4639-5>
- Facchinetti T, Benetti G, Vedova MLD (???) Modeling and real-time control of an industrial air multi-compressor system
- Friden H, Bergfors L, Bjork A, Mazharsolook E (2012) Energy and LCC Optimised Design of Compressed Air Systems: A Mixed Integer Optimisation Approach with General Applicability. 2012 UKSim 14th International Conference on Computer Modelling and Simulation (Lcc):491–496, DOI 10.1109/UKSim.2012.74, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=6205496>
- Ghorbanian K, Gholamrezaei M (2009) An artificial neural network approach to compressor performance prediction. *Applied Energy* 86(7-8):1210–1221, DOI 10.1016/j.apenergy.2008.06.006, URL <http://dx.doi.org/10.1016/j.apenergy.2008.06.006>
- Glass aS, Gruber P, Roos M, Todtli J (1995) Qualitative model-based fault detection in air-handling units. *IEEE Control Systems Magazine* 15(4):11–22, DOI 10.1109/37.408465, URL <http://www.scopus.com/inward/record.url?eid=2-s2.0-0029359274&partnerID=40&md5=190fc8710ebf04754f9055cc492f4691>
- House JM, Vaezi-Nejad H, Whitcomb JM (2001) An expert rule set for fault detection in air-handling units / Discussion. In: *ASHRAE Transactions*, American Society of Heating, Refrigeration and Air Conditioning Engineers, Inc., Atlanta, vol 107, p 858, URL <http://search.proquest.com/docview/192523824?accountid=14504http://godot.lib.sfu.ca/GODOT/hold{ }tab.cgi?url{ }ver=Z39.88-2004{&rft{ }val{ }fmt=info:ofi/fmt:kev:mtx:journal{&genre=proceeding{&sid=ProQ:ProQ:sciencejournals{&atitle=An+expert+rule+set+for+fault+detection+in+air-handling+units+}/+Discussion{&title=ASHRAE+Transactions{&issn=00012505{&date=2001-01-01{&volume=107{&issue={&page=858{&au=House,+John+M;Vaezi-Nejad,+Hossein;Whitcomb,+J+Michael{&isbn={&jtitle=ASHRAE+Transactions{&bttitle={&rft{ }id=inf>
- IEA (2012) International Energy Agency. URL <http://www.iea.org>
- James Li C, Yu X (1995) High pressure air compressor valve fault diagnosis using feedforward neural networks. *Mechanical Systems and Signal Processing* 9(5):527–536, DOI 10.1006/mssp.1995.0040, URL <http://www.sciencedirect.com/science/article/pii/S0888327085700404>
- Jinru L, Yibing L, Keguo Y (2008) Fault diagnosis of piston compressor based on Wavelet Neural Network and Genetic Algorithm. 2008 7th World Congress on Intelligent Control and Automation pp 6006–6010, DOI 10.1109/WCICA.2008.4592852, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=4592852>
- Kopanos GM, Xenos DP, Ciccotti M, Pistikopoulos EN, Thornhill NF (2015) Optimization of a network of compressors in parallel: Operational and maintenance planning The air separation plant case. *Applied Energy* 146:453–470, DOI 10.1016/j.apenergy.2015.01.080, URL <http://linkinghub.elsevier.com/retrieve/pii/S0306261915001166>
- Krichel SV, Sawodny O (2011) Analysis and optimization of compressed air networks with model-based approaches. *Pneumatica* pp 334–341
- Lingling H (2010) Fault diagnosis model of the diesel locomotive air brake system based on Bayesian network pp 0–2
- Liu C, Kong D, Fan Z, Yu Q, Cai M (2013) Large flow compressed air load forecasting based on Least Squares Support Vector Machine within the Bayesian evidence framework. *IECON Proceedings (Industrial Electronics Conference)* (2011):7886–7891, DOI 10.1109/IECON.2013.6700450
- Liu J, Chen DS (2009) Fault Detection and Identification Using Modified Bayesian Classification on PCA Subspace. *Industrial & Engineering Chemistry Re-*

- search 48(6):3059–3077, DOI 10.1021/ie801243z, URL <http://www.scopus.com/inward/record.url?eid=2-s2.0-65349135893&partnerID=tZ0tx3y1>
- Liu SYSC (2001) An Efficient Expert System for Air Compressor Troubleshooting. *Expert Systems* 18(4):203–214, DOI 10.1111/1468-0394.00175, URL <http://doi.wiley.com/10.1111/1468-0394.00175>
- Luo Fangqiong, Huang Shengzhong (2011) Research and Application of Wavelet Neural Network Based on the Optimization of Genetic Algorithm in Centrifugal Compressor's Performance Prediction. 2011 Third International Conference on Measuring Technology and Mechatronics Automation 9:1027–1030, DOI 10.1109/ICMTMA.2011.538, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=5721364>
- Mazid AM, Martin R (2008) Automation of compressor test procedure using advantech data acquisition module. In: 2008 10th International Conference on Control, Automation, Robotics and Vision, IEEE, December, pp 2266–2271, DOI 10.1109/ICARCV.2008.4795885, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=4795885>
- Nair AT, Radhakrishnan TK, Srinivasan K, Rominus Valsalam S (2011) Kalman Filter Based State Estimation of a Thermal Power Plant. 2011 International Conference on Process Automation, Control and Computing pp 1–5, DOI 10.1109/PACC.2011.5978971, URL [http://ieeexplore.ieee.org/xpls/abs/\\_all.jsp?arnumber=5978971&delimiter=026E30F&nhttp://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=5978971](http://ieeexplore.ieee.org/xpls/abs/_all.jsp?arnumber=5978971&delimiter=026E30F&nhttp://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=5978971)
- Pathak N, Khan M, Roy N (2015) Acoustic based appliance state identifications for fine-grained energy analytics. *IEEE International Conference on Pervasive Computing and Communications (PerCom)* pp 63–70, URL [http://ieeexplore.ieee.org/xpls/abs/\\_all.jsp?arnumber=7146510](http://ieeexplore.ieee.org/xpls/abs/_all.jsp?arnumber=7146510)
- Petković M, Rapaić MR, Jeličić ZD, Pisano A (2012) On-line adaptive clustering for process monitoring and fault detection. *Expert Systems with Applications* 39(11):10,226–10,235, DOI 10.1016/j.eswa.2012.02.150
- Qin Q, Jiang ZN, Feng K, He W (2012) A novel scheme for fault detection of reciprocating compressor valves based on basis pursuit, wave matching and support vector machine. *Measurement: Journal of the International Measurement Confederation* 45(5):897–908, DOI 10.1016/j.measurement.2012.02.005, URL <http://dx.doi.org/10.1016/j.measurement.2012.02.005>
- Radgen P (2006) Efficiency through compressed air energy audits. In: *Energy Audit Conference*, www.audit06.fi
- Ramezanifar a, Afshar a, Nikravesh SKY (2006) State Estimation of a Boiler Using Nonlinear Observer. *Information and Control*
- Ren Y, Zhang L, Ye Y, Liang W, Yang H (2012) Reliability Assessment of Anti-surge Control System in Centrifugal Compressor. 2012 Fourth International Conference on Computational and Information Sciences pp 1240–1243, DOI 10.1109/ICCIS.2012.218, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=6301343>
- Ruilin Lin, Boyun Liu, Qi Liu (2010) Study of the non-liner dynamic system theory for reciprocating compressor fault diagnosis. In: 2010 International Conference on Computer Application and System Modeling (ICCASM 2010), IEEE, Iccasm, pp V9–245–V9–248, DOI 10.1109/ICCASM.2010.5623041, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=5623041>
- Saidur R, Rahim N, Hasanuzzaman M (2010) A review on compressed-air energy use and energy savings. *Renewable and Sustainable Energy Reviews* 14(4):1135–1153, DOI 10.1016/j.rser.2009.11.013, URL <http://www.sciencedirect.com/science/article/pii/S1364032109002755>
- Salar A, Hosseini SM, Zangmolk BR, Sedigh AK (2010) Improving Model-Based Gas Turbine Fault Diagnosis Using Multi-Operating Point Method. 2010 Fourth UKSim European Symposium on Computer Modeling and Simulation (2):240–247, DOI 10.1109/EMS.2010.47, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=5703690>
- SEAI (2007) Special Working Group HVAC (SPIN I) 2007. Tech. Rep. Spin I, URL [http://www.seai.ie/Your/\\_Business/Large/\\_Energy/\\_Users/Special/\\_Initiatives/Special/\\_Working/\\_Groups/HVAC/\\_SWG/\\_07/](http://www.seai.ie/Your/_Business/Large/_Energy/_Users/Special/_Initiatives/Special/_Working/_Groups/HVAC/_SWG/_07/)
- Shin Bs, Lee CJ, Lee G, Yoon ES (2007) Application of fault diagnosis based on signed digraphs and PCA with linear fault boundary. 2007 International Conference on Control, Automation and Systems pp 984–987, DOI 10.1109/ICCAS.2007.4407067, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=4407067>
- Tarantino R, Szigeti F, Colina-Morles E (2000) Generalized Luenberger observer-based fault-detection filter design: An industrial application. *Control Engineering Practice* 8(6):665–671, DOI 10.1016/S0967-0661(99)00181-1
- Tran VT, Althobiani F, Ball A (2014) An approach to fault diagnosis of reciprocating compressor valves using Teager-Kaiser energy operator and deep belief networks. *Expert Systems with Applications* 41(9):4113–4122, DOI 10.1016/j.eswa.2013.12.026, URL <http://dx.doi.org/10.1016/j.eswa.2013.12.026>
- Vachtsevanos G, Lewis F, Roemer M, Hess A, Wu B (2006) *Intelligent Fault Diagnosis and Prognosis for Engineering Systems*. John Wiley & Sons, Inc., Hoboken, NJ,

- USA, DOI 10.1002/9780470117842, URL <http://doi.wiley.com/10.1002/9780470117842>
- Verma NK, Roy A, Salour A (2011) An optimized fault diagnosis method for reciprocating air compressors based on SVM. *Proceedings - 2011 IEEE International Conference on System Engineering and Technology, ICSET 2011* pp 65–69, DOI 10.1109/ICSEngT.2011.5993422
- Wang F, Song L, Zhang L, Li H (2010) Fault Diagnosis for Reciprocating Air Compressor Valve Using P-V Indicator Diagram and SVM. *2010 Third International Symposium on Information Science and Engineering (109047)*:255–258, DOI 10.1109/ISISE.2010.91, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=5945097>
- Wang L (2014) Energy efficiency technologies for sustainable food processing. *Energy Efficiency* 7(5):791–810, DOI 10.1007/s12053-014-9256-8, URL <http://link.springer.com/10.1007/s12053-014-9256-8>
- Wang S, Cui J (2005) Sensor-fault detection, diagnosis and estimation for centrifugal chiller systems using principal-component analysis method. *Applied Energy* 82(3):197–213, DOI 10.1016/j.apenergy.2004.11.002, URL <http://linkinghub.elsevier.com/retrieve/pii/S0306261904001953>
- Wheeler TJ, Seiler P, Packard AK, Balas GJ (2011) Performance analysis of fault detection systems based on analytically redundant linear time-invariant dynamics. *Proceedings of the American Control Conference* pp 214–219, URL <http://www.scopus.com/inward/record.url?eid=2-s2.0-80053146995&partnerID=tZ0tx3y1>
- Xiaogang W, Xueliang B, Bo J (2013) Adaptive genetic algorithm for parameter identification of centrifugal compressor. *2013 25th Chinese Control and Decision Conference (CCDC)* pp 2982–2986, DOI 10.1109/CCDC.2013.6561456, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=6561456>
- Yu Y, Chen L, Sun F, Wu C (2007) Neural-network based analysis and prediction of a compressor's characteristic performance map. *Applied Energy* 84(1):48–55, DOI 10.1016/j.apenergy.2006.04.005
- Zanoli SM, Astolfi G (2013) Application of a Fault Detection and Isolation System on a Rotary Machine. *International Journal of Rotating Machinery* 2013:1–11, DOI 10.1155/2013/189359, URL <http://www.hindawi.com/journals/ijrm/2013/189359/>
- Zanoli SM, Astolfi G, Barboni L (2010a) Applications of fault diagnosis techniques for a multishaft centrifugal compressor. *18th Mediterranean Conference on Control and Automation, MED'10 - Conference Proceedings* pp 64–69, DOI 10.1109/MED.2010.5547615
- Zanoli SM, Astolfi G, Barboni L (2010b) FDI of process faults based on PCA and cluster analysis. *2010 Conference on Control and Fault-Tolerant Systems (SysTol)* pp 197–202, DOI 10.1109/SYSTOL.2010.5676023, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=5676023>
- Zhu Xp, Zhang LB, Liang W, Shi Gn (2013) A quantitative comprehensive safety evaluation method for centrifugal compressors using FMEA-fuzzy operations. In: *2013 2nd International Symposium on Instrumentation and Measurement, Sensor Network and Automation (IMSNA)*, IEEE, pp 202–206, DOI 10.1109/IMSNA.2013.6743251, URL <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=6743251>