



Harco Fittings LLC

P.O. BOX 10335 • LYNCHBURG, VIRGINIA 24506 • PHONE: (434) 845-7094
FAX: (434) 845-8562

MOLDED PVC GASKETED C907 PRESSURE FITTINGS

LETTER OF COMPLIANCE

Scope:

This letter of compliance covers the requirements for 4" through 12" PVC **Blue Brute®** Gasketed Pressure Fittings manufactured by IPEX Inc. and supplied by Harco Fittings LLC for use with PVC only, cast iron outside diameter pipe. These products meet or exceed performance standards set by the American National Standards Institute (ANSI), the American Society for Testing and Materials (ASTM), the American Water Works Association (AWWA), Underwriters Laboratories Inc. (UL), Factory Mutual (FM), NSF International (NSF), and the Uni-Bell PVC Pipe Association.

Blue Brute® Gasketed Pressure Fittings supplied by Harco Fittings LLC are suitable for conveyance of potable water in municipal distribution systems, fire lines, sewer force mains, industrial process lines, irrigation piping, and other pressure applications.

Materials:

PVC (Poly Vinyl Chloride) used in the manufacturing of **Blue Brute®** Gasketed Pressure Fittings complies with ASTM D1784, *Standard Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds*, having a cell classification 12454. The material also has a hydrostatic design basis of 4,000 psi (27.6 MPa). The compound is listed with NSF for potable water service.

Gasket materials used in the manufacturing of **Blue Brute®** Gasketed Pressure Fittings comply with the requirements of ASTM F477 "*Standard Specification for Elastomeric Seals (Gaskets) for Joining Plastic Pipe*" for high-head applications.

Molded Fittings:

Molded **Blue Brute®** Gasketed Pressure Fittings, PC 235 psi, conform to the following standards;

ANSI/NSF 61 "*Drinking Water System Components – Health Effects*"

AWWA C907 "*Injection Molded Polyvinyl Chloride (PVC) Pressure Fittings 4 in. through 12 in. (100 mm – 300 mm) for Water, Wastewater and Reclaimed Wastewater Service*"

FM Approval Standard "*Polyvinyl Chloride (PVC) Pipe and Fittings for Underground Fire Protection Service - Class Number 1612*". FM rating is PC 185.

UL1285 "*Pipe and Couplings (PVC), and (PVC) for Underground Fire Service*"

UNI-BELL Standard UNI-B-12-87 - "*Recommended Standard for Polyvinyl Chloride (PVC) Pressure Fittings*"

Gasket Joints:

Blue Brute® Gasketed Pressure Fittings have a gasket joint design that meets the requirements of ASTM D3139 "*Standard Specification for Joints for Plastic Pressure Pipes Using Flexible Elastomeric Seals*". All **Blue Brute®** Gasketed Pressure Fittings can be supplied with either a standard gasket or a nitrile gasket. Nitrile gaskets are to be used when a more chemically resistant gasket is necessary because of ground contaminants.

Replacement gaskets are available to allow **Blue Brute®** fittings to also be installed on IPS-OD PVC pipe.

Lubricant:

All **Blue Brute®** Gasketed Pressure Fittings must be assembled with the manufacturer's nontoxic, water-soluble, NSF-listed lubricant.

Markings:

Blue Brute® Gasketed Pressure Fittings are marked as prescribed in the above applicable standards to indicate size of fittings, material designation, compliance to standard, and manufacturer's name or trademark.

Color Coding:

Blue Brute® Gasketed Pressure Fittings are color-coded blue.

Note: Modifications to products may occur at any time without notice. Should you require that a product meets a given standard or application, you must ensure that the information provided herein is current by consulting with a Harco Fittings LLC representative.

Note: The 4" and 6" Gasket x Spigot 45° Elbows are manufactured by Harco Fittings LLC, a division of IPEX Inc. These fittings comply with AWWA C907 when qualification is completed and are NSF 61 listed. They are not FM or UL listed.

Sincerely,

A handwritten signature in black ink that reads "John E. Riordan". The signature is written in a cursive, flowing style.

John E. Riordan
Vice President
Harco Fittings LLC