

"Program" Completion Report

User: Administrator
System Time: 27/09/2022 9:54:36 a.m.
System Time Zone: (UTC-05:00) Bogota, Lima, Quito, Rio Branco

Account: 02860557, <Factory Serial Num>

Meter ID: 02860557, <Factory Serial Num>

Program - A3/A1800 Task

Task succeeded.

Program ID:	A1800R - 001 - BIDIRECCIONAL
Meter Time Zone:	(UTC-05:00) Bogota, Lima, Quito, Rio Branco, <System Setting>
Custom Display String 1:	EPSA
Custom Display String 2:	BDMS
Factory Ke:	0,025
Metering Application:	Secondary
CT Ratio:	1,00
VT Ratio:	1,00
Register Multiplier:	1,0
KYZ Divisor:	1
Service Test Component:	<Program Value>
PQM Component:	<Do Not Change>
Instrumentation Profiling Component:	<Program Value>
Special Dates Component:	<Program Value>
Remote Component:	<Program Value>
Port 1 Device ID:	1
Pulse Interval Data Recording:	ENABLED, configured to record 85 days
Instrumentation Set 1 Interval Data Recording:	ENABLED, configured to record 85 days
Instrumentation Set 2 Interval Data Recording:	ENABLED, configured to record 0 days
Power Quality Monitoring:	ENABLED, feature is ON