

MAINTENANCE WORK ORDER

Work Order Details

Work Order ID	WO-489
Equipment Tag	Pump-101
Work Performed	Mechanical seal replacement
Date Completed	May 17, 2025
Status	Closed

Technician Notes

The mechanical seal showed signs of wear consistent with normal operation. Replaced with OEM-spec part. Tested for leaks post-installation; zero leakage detected. Motor alignment verified.