

MAINTENANCE WORK ORDER

Work Order Details

Work Order ID	WO-501
Equipment Tag	Pump-204
Work Performed	Mechanical seal replacement due to seal failure (leakage detected during routine inspection).
Date Completed	May 1, 2026
Status	Closed

Technician Notes

Note: This is the second seal failure on a centrifugal pump in this unit group within the last quarter. Replaced the failed mechanical seal and cleaned the surrounding casing. Unit restored to operation.