

EQUIPMENT INSPECTION RECORD

Inspection Details

Work Order ID	WO-552
Equipment Tag	Pump-101
Inspection Type	Routine operational inspection
Date Completed	June 25, 2026
Status	Closed

Findings

Operating pressure measured at 12 bar (within spec). No visible leakage around the casing or piping joints. The mechanical seal is in acceptable condition. Recommend continued monitoring during regular rounds.