NAMA PEMILIK PROYEK : **PT PERTAMINA EP**

NAMA PROYEK : **JASA PEMBANGUNAN FASILITAS PRODUKSI STASIUN PENGUMPUL (SP) TANJUNG MIRING BARAT & KARANGAN TIMUR**

LOKASI : **SP TANJUNG MIRING BARAT & KARANGAN TIMUR - FIELD LIMAU**

NO. KONTRAK : **SA02035383B**

REV.	TGL.	DESKRIPSI	DISIAPKAN	DIPERIKSA	DISETUJUI	DIPERIKSA	DISETUJUI
A	09/01/2026	Issued For Review	MHP	AS	MR		
			PT. PROSYMPAC OIL & GAS			PT. PERTAMINA EP	

TABEL REVISI

Rev.	Tanggal	Deskripsi

COMMENT RESPONSE SHEET

No.	Page	PERUSAHAAN's Comment	Contractor's Response	Remarks

DAFTAR ISI

TABEL REVISI **2**
COMMENT RESPONSE SHEET **3**
DAFTAR ISI **4**
1. DATA SHEET FOR PRESSURE / D/P INDICATOR **5**
1.1 PRESSURE / D/P INDICATOR LIST 6

skkmigas PERTAMINA EP	**PERTAMINA EP** **REGIONAL 1 ZONA 4**	PGG

DATA SHEET FOR PRESSURE / D/P INDICATOR	No. Dok. : TMBP-SP001-IN-DST-D106 Rev. : A Halaman : 5 dari 7

Tag Number	: See List	Service	: See List
P&ID No.	: See List	Equip./Line No.	: See List

PROCESS CONDITION	1	Fluid	State	See Pressure Indicator List	-
	2	Operating Pressure	Design Pressure	See Pressure Indicator List	See Pressure Indicator List
	3	Operating Temperature	Design Temperature	See Pressure Indicator List	See Pressure Indicator List
GAUGE	4	Type		Pressure Indicator, Direct Reading	
	5	Enclosure Class		IP 65	
	6	Hazardous Area Classification		Zone 2	
	7	Scale Range		See Pressure Indicator List	
	8	Accuracy		1% of full span	
	9	Mounting		Direct	
	10	Dial Size		100 mm	
	11	Dial Color		Black figure on White background	
	12	Case Material		316 SS	
	13	Ring Type		Screwed	
	14	Blow Out Protection		Yes (at Backside)	
	15	Window Material/ Lens		Shatterproof Safety Glass	
	16	Pressure Element Type		Bourdon Tube	
	17	Pressure Element Material		316 SS	
	18	Socket Material		316 SS	
	19	Connection Size | Location		1/2" NPTM	Bottom
	20	Movements Material		316 SS	
	21	Overrange Protection		150% of maximum range	
	22	Liquid Filling		See Pressure Indicator List	
	23	Zero Adjustable, Span Adjustable		Yes	
	24	Pointer Micrometer		Yes	
DIAPHRAGM SEALED	25	Diaphragm Sealed		N/A	
	26	Process Connection		N/A	
	27	Diaphragm Material		N/A	
	28	Bottom Housing Material		N/A	
	29	Capillary Material		N/A	
	30	Capillary Length		N/A	
	31	Fill Fluid		N/A	
	32	Allowable Over Temperature		N/A	
OPTIONS	33	Syphon		N/A	
	34	Snubber		See Pressure Indicator List	
	35	Pulsation Damper		N/A	
	36	Pressure Limit Valve		N/A	
	37	Valve Manifold		2-Way, 3/4"NPTM x 1/2" NPTF, 316 SS	
	38	Mounting Bracket		N/A	
OTHERS	39	2 Years Spare Part		Yes	
REMARKS	40	Manufacture		As per AML / PML	(2)
	41	Model No.		By VENDOR	(3)
	42	Name Plate (Tagging Number)		Yes, 316 SS	(1)

Notes:

1. All instrument shall be tagged with 316 SS nameplate showing tag no.
2. VENDOR shall be refer to PT. PERTAMINA HULU ROKAN Approved Manufacturers List (AML) / Preferred Manufacturer List (PML)
3. VENDOR shall submit proper model number on bid proposal

DATA SHEET FOR PRESSURE / D/P INDICATOR

PRESSURE / D/P INDICATOR LIST

No.	Tag Number	P&ID No.	Service	Fluid	Equip./Line Number	Temperature (°F)		Pressure (Psig)		Scale Range (Psig)	Liquid Filling	Snubber	Remarks
						Oper.	Design	Oper.	Design				
1	PG-TMB-001	TMBP-SP001-PR-PID-D101	LP PROD MANIFOLD TMB	PRODUCTION FLUID	PF-001-AA-6"	88	138	50	70	0-100	GLYCERYN	N/A	
2	PG-TMB-002	TMBP-SP001-PR-PID-D101	TEST MANIFOLD TMB	PRODUCTION FLUID	PF-002-AA-3"	88	138	50	70	0-100	GLYCERYN	N/A	
3	PG-V-001-001	TMBP-SP001-PR-PID-D101	PRODUCTION SEPARATOR TIAS	PROCESS GAS	V-001	66.5	117	119	143	0-200	GLYCERYN	N/A	
4	PG-V-003-001	TMBP-SP001-PR-PID-D101	TEST SEPARATOR TMB	PROCESS GAS	V-003	226	276	85	105	0-150	GLYCERYN	N/A	
5	PG-KRG-001	TMBP-SP001-PR-PID-D102	LP PROD MANIFOLD KRG	PRODUCTION FLUID	PF-005-AA-6"	50	70	84	134	0-200	GLYCERYN	N/A	
6	PG-KRG-002	TMBP-SP001-PR-PID-D102	TEST MANFOLD KRG	PRODUCTION FLUID	PF-006-AA-3"	50	70	84	134	0-200	GLYCERYN	N/A	
7	PG-V-002-001	TMBP-SP001-PR-PID-D102	PRODUCTION SEPARATOR KRG	PROCESS GAS	V-002	273	323	114	137	0-200	GLYCERYN	N/A	
8	PG-V-004-001	TMBP-SP001-PR-PID-D102	TEST SEPARATOR KRG	PROCESS GAS	V-004	69	119	85	105	0-150	GLYCERYN	N/A	
9	PG-T-003-001	TMBP-SP001-PR-PID-D103	TEST TANK TMB	PROCESS GAS	T-003	88	138	60	80	0-100	GLYCERYN	N/A	
10	PG-P-002-001B	TMBP-SP001-PR-PID-D103	TEST PUMP TMB	PROCESS LIQUID	PL-007-AA-6"	88	138	60	80	0-100	GLYCERYN	N/A	
11	PG-P-002-002B	TMBP-SP001-PR-PID-D103	TEST PUMP TMB	PROCESS LIQUID	PL-009-AA-3"	88	138	60	80	0-100	GLYCERYN	N/A	
12	PG-P-002-001A	TMBP-SP001-PR-PID-D103	TEST PUMP TMB	PROCESS LIQUID	PL-006-AA-6"	88	138	60	80	0-100	GLYCERYN	N/A	
13	PG-P-002-002A	TMBP-SP001-PR-PID-D103	TEST PUMP TMB	PROCESS LIQUID	PL-010-AA-3"	88	138	60	80	0-100	GLYCERYN	N/A	
14	PG-P-002-003	TMBP-SP001-PR-PID-D103	DISCHARGE TEST PUMP TMB	PROCESS LIQUID	PL-011-AA-2"	88	138	60	80	0-100	GLYCERYN	N/A	
15	PG-T-004-001	TMBP-SP001-PR-PID-D104	TEST TANK KRG	PROCESS LIQUID	T-004	88	138	60	80	0-100	GLYCERYN	N/A	
16	PG-P-003-001B	TMBP-SP001-PR-PID-D104	TEST PUMP KRG	PROCESS LIQUID	PL-016-AA-4"	88	138	60	80	0-100	GLYCERYN	N/A	
17	PG-P-003-002B	TMBP-SP001-PR-PID-D104	TEST PUMP KRG	PROCESS LIQUID	PL-018-AA-3"	88	138	60	80	0-100	GLYCERYN	N/A	
18	PG-P-003-001	TMBP-SP001-PR-PID-D104	TEST PUMP KRG	PROCESS LIQUID	PL-017-AA-4"	88	138	60	80	0-100	GLYCERYN	N/A	
19	PG-P-003-002A	TMBP-SP001-PR-PID-D104	TEST PUMP KRG	PROCESS LIQUID	PL-019-AA-3"	88	138	60	80	0-100	GLYCERYN	N/A	
20	PG-P-003-001A	TMBP-SP001-PR-PID-D104	DISCHARGE TEST PUMP KRG	PROCESS LIQUID	PL-020-AA-2"	88	138	60	80	0-100	GLYCERYN	N/A	
21	**PG-T-001-001**	TMBP-SP001-PR-PID-D105	WASH TANK TMB	PROCESS LIQUID	T-001	88	138	0.15	50	0-5	GLYCERYN	N/A	
22	**PG-T-001-002**	TMBP-SP001-PR-PID-D105	WASH TANK TMB TO FLARE HEADER	PROCESS LIQUID	T-001	90	140	0.15	50	0-5	GLYCERYN	N/A	
23	PG-T-005-001A	TMBP-SP001-PR-PID-D105	STORAGE TANK TMB	PROCESS LIQUID	T-005A	90	150	0.15	50	0-5	GLYCERYN	N/A	
24	PG-T-005-001B	TMBP-SP001-PR-PID-D105	STORAGE TANK TMB (EXISTING)	PROCESS LIQUID	T-005B	90	150	0.15	50	0-5	GLYCERYN	N/A	
25	**PG-T-002-001**	TMBP-SP001-PR-PID-D106	WASH TANK KRG	PROCESS LIQUID	T-002	90	150	0.15	50	0-5	GLYCERYN	N/A	
26	**PG-T-002-002**	TMBP-SP001-PR-PID-D106	WASH TANK KRG TO FLARE HEADER	PROCESS LIQUID	F-009-AA-3"	90	140	0.15	50	0-5	GLYCERYN	N/A	
27	PG-T-006-001A	TMBP-SP001-PR-PID-D106	STORAGE TANK KRG	PROCESS LIQUID	T-006A	90	150	0.15	50	0-5	GLYCERYN	N/A	
28	PG-T-006-001B	TMBP-SP001-PR-PID-D106	STORAGE TANK KRG	PROCESS LIQUID	T-006B	90	150	0.15	50	0-5	GLYCERYN	N/A	
29	PG-P-001-001A	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP	PROCESS LIQUID	PL-046-BA-10"	88	138	-0,39	50	(-5)-5	GLYCERYN	N/A	
30	PG-P-001-002A	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP	PROCESS LIQUID	PL-048-BA-6"	88	138	250	303	0-350	GLYCERYN	N/A	
31	PG-P-001-001B	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP	PROCESS LIQUID	PL-047-BA-10"	88	138	-0,39	50	(-5)-5	GLYCERYN	N/A	
32	PG-P-001-002B	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP	PROCESS LIQUID	PL-048-BA-6"	88	138	250	303	0-350	GLYCERYN	N/A	
33	PG-P-001-003	TMBP-SP001-PR-PID-D107	DISCHARGE GROSS TRANSFER PUMP	PROCESS LIQUID	PL-085-AA-4"	88	138	250	303	0-350	GLYCERYN	N/A	
34	**PG-P-004-001A**	TMBP-SP001-PR-PID-D108	FEED WATER PUMP	PROCESS WATER	PW-018-A-6"	80	130	0.15	50	0-100	GLYCERYN	N/A	
35	**PG-P-004-002A**	TMBP-SP001-PR-PID-D108	FEED WATER PUMP	PROCESS WATER	PW-020-AA-6"	80	130	100	125	0-150	GLYCERYN	N/A	
36	**PG-P-004-001B**	TMBP-SP001-PR-PID-D108	FEED WATER PUMP	PROCESS WATER	PW-019-AA-6"	80	130	0.15	50	0-100	GLYCERYN	N/A	
37	**PG-P-004-002B**	TMBP-SP001-PR-PID-D108	FEED WATER PUMP	PROCESS WATER	PW-021-AA-6"	80	130	100	125	0-150	GLYCERYN	N/A	
38	**PG-P-004-001**	TMBP-SP001-PR-PID-D108	DISCHARGE FEED WATER PUMP	PROCESS WATER	PW-023-AA-3"	80	130	100	125	0-150	GLYCERYN	N/A	
39	**PG-P-TMB-PB3-025A**	TMBP-SP001-PR-PID-D111	MANIFOLD INJECTION INJECTION TMB	PROCESS WATER	PW-016-CA-3"	85	136	1025	1258	0-200	GLYCERYN	N/A	
40	**PG-P-TMB-PB3-025B**	TMBP-SP001-PR-PID-D111	MANIFOLD INJECTION TMB	PROCESS WATER	PW-016-CA-3"	86	135	1025	1258	0-200	GLYCERYN	N/A	
41	**PG-TMBP-02-027A**	TMBP-SP001-PR-PID-D111	MANIFOLD INJECTION TMB	PROCESS WATER	PW-015-CA-3"	86	136	1025	1258	0-200	GLYCERYN	N/A	
42	**PG-TMBP-02-027B**	TMBP-SP001-PR-PID-D111	MANIFOLD INJECTION TMB	PROCESS WATER	PW-015-CA-3"	85	136	1025	1258	0-200	GLYCERYN	N/A	
43	**PG-KRG-PA-027A**	TMBP-SP001-PR-PID-D111	MANIFOLD INJECTION KRG	PROCESS WATER	PW-014-CA-3"	86	138	1025	1258	0-200	GLYCERYN	N/A	

PRESSURE / D/P INDICATOR LIST

No.	Tag Number	P&ID No.	Service	Fluid	Equip./Line Number	Temperature (°F)		Pressure (Psig)		Scale Range (Psig)	Liquid Filling	Snubber	Remarks
						Oper.	Design	Oper.	Design				
44	PG-KRG-PA-027B	TMBP-SP001-PR-PID-D111	MANIFOLD INJECTION KRG	PROCESS WATER	PW-014-CA-3"	86	136	1025	1258	0-200	GLYCERYN	N/A	
45	PG-KRG-PC-028A	TMBP-SP001-PR-PID-D111	MANIFOLD INJECTION KRG	PROCESS WATER	PW-013-CA-3"	85	136	1025	1258	0-200	GLYCERYN	N/A	
46	PG-KRG-PC-028B	TMBP-SP001-PR-PID-D111	MANIFOLD INJECTION KRG	PROCESS WATER	PW-013-CA-3"	85	136	1025	1258	0-200	GLYCERYN	N/A	
47	PI-P-005-003	TMBP-SP001-PR-PID-D113	DISCHARGE INJECTION PUMP	PROCESS WATER	PW-011-CA-2"	85	135	1025	1258	0-200	GLYCERYN	N/A	
48	PI-P-005-001A	TMBP-SP001-PR-PID-D113	INJECTION PUMP	PROCESS WATER	PW-005-CA-4"	85	136	0.15	50	0-200	GLYCERYN	N/A	
49	PI-P-005-002A	TMBP-SP001-PR-PID-D113	INJECTION PUMP	PROCESS WATER	PW-009-CA-3"	86	138	1025	1258	0-200	GLYCERYN	N/A	
50	PI-P-005-001B	TMBP-SP001-PR-PID-D113	INJECTION PUMP	PROCESS WATER	PW-006-CA-4"	85	138	0.15	50	0-200	GLYCERYN	N/A	
51	PI-P-005-002B	TMBP-SP001-PR-PID-D113	INJECTION PUMP	PROCESS WATER	PW-010-CA-3"	86	136	1025	1258	0-200	GLYCERYN	N/A	
52	PI-V-005-001	TMBP-SP001-PR-PID-D113	PRODUCTION SCRUBBER	PROCESS GAS	V-005	90	150	32	100	0-200	GLYCERYN	N/A	
53	PI-V-006-001	TMBP-SP001-PR-PID-D115	FROM INSTRUMENT AIR SUPPLY	FLARE	IA-007-AC-2"	80	130	100	120	0-200	GLYCERYN	N/A	
54	PI-V-006-002	TMBP-SP001-PR-PID-D115	FROM FUEL GAS PACKAGE (Z-002)	FLARE	GF-004-AA-2"	80	130	100	120	0-200	GLYCERYN	N/A	
55	PI-V-006-001	TMBP-SP001-PR-PID-D115	KNOCK OUT DRUM VESSEL	PROCESS LIQUID	V-006	243	293	2.57	50	0-200	GLYCERYN	N/A	
56	PI-P-006-001A	TMBP-SP001-PR-PID-D115	KOD PUMP	PROCESS LIQUID	PL-040-AA-3"	68.17	118.7	0.68	20.68	0-200	GLYCERYN	N/A	
57	PI-P-006-002A	TMBP-SP001-PR-PID-D115	KOD PUMP	PROCESS LIQUID	PL-038-AA-2"	68.17	118.7	0.68	20.68	0-200	GLYCERYN	N/A	
58	PI-P-006-001B	TMBP-SP001-PR-PID-D115	KOD PUMP	PROCESS LIQUID	PL-041-A-2"	68.17	118.7	30	50	0-200	GLYCERYN	N/A	
59	PI-P-006-002B	TMBP-SP001-PR-PID-D115	KOD PUMP	PROCESS LIQUID	PL-042-A-2"	68.17	118.7	30	50	0-200	GLYCERYN	N/A	
60	PI-V-007-001	TMBP-SP001-PR-PID-D116	CLOSED DRAIN VESSEL	PROCESS LIQUID	V-007	150	190	0.5	50	0-200	GLYCERYN	N/A	
61	PI-P-007-001A	TMBP-SP001-PR-PID-D116	CLOSED DRAIN PUMP	PROCESS LIQUID	PL-043-AA-3"	83.6	113.6	0.68	20.68	0-200	GLYCERYN	N/A	
62	PI-P-007-002A	TMBP-SP001-PR-PID-D116	CLOSED DRAIN PUMP	PROCESS LIQUID	PL-043-AA-2"	83.6	113.6	35	55	0-200	GLYCERYN	N/A	
63	PI-P-007-001B	TMBP-SP001-PR-PID-D116	CLOSED DRAIN PUMP	PROCESS LIQUID	PL-044-AA-3"	83.6	113.6	83.6	113.6	0-200	GLYCERYN	N/A	
64	PI-P-007-002B	TMBP-SP001-PR-PID-D116	CLOSED DRAIN PUMP	PROCESS LIQUID	PL-045-AA-2"	83.6	113.8	35	55	0-200	GLYCERYN	N/A	
65	PI-P-020-001	TMBP-SP001-PR-PID-D117	SLURRY PUMP	SLUDGE	SL-001-AA-3"	80.6	110.6	20	40	0-200	GLYCERYN	N/A	
66	PI-P-019-001	TMBP-SP001-PR-PID-D117	WATER SUMP PUMP	SLUDGE	WW-001-AA-3"	95	126	30	50	0-200	GLYCERYN	N/A	
67	PI-P-022-001	TMBP-SP001-PR-PID-D117	OIL SUMP PUMP	SLUDGE	OW-001-AA-3"	95	126	30	50	0-200	GLYCERYN	N/A	
68	PI-FG-001-001	TMBP-SP001-PR-PID-D118	GAS FROM TALANG JIMAR TO RECEIVING HEADER	GAS	GF-002-AA-4"	80	120	100	130	0-200	GLYCERYN	N/A	
69	PI-F-006-001A	TMBP-SP001-PR-PID-D119	FUEL GAS TO GEG PACKAGE A	GAS	GF-003-AA-3"	80	120	100	130	0-200	GLYCERYN	N/A	
70	PI-F-006-001B	TMBP-SP001-PR-PID-D119	FUEL GAS TO GEG PACKAGE B	GAS	GF-006-AA-3"	90	120	80	110	0-200	GLYCERYN	N/A	
71	PI-V-009-003	TMBP-SP001-PR-PID-D120	INSTRUMENT AIR RECEIVER TO INSTRUMENT AIR DISTRIBUTION	GAS	UA-003-AC-2"	100	120	120	170	0-200	GLYCERYN	N/A	
72	PI-V-010-003	TMBP-SP001-PR-PID-D120	AIR RECEIVER TO INSTRUMENT AIR DISTRIBUTION	GAS	UA-002-AC-2"	100	120	120	170	0-200	GLYCERYN	N/A	
73	PI-P-017-001A	TMBP-SP001-PR-PID-D121	WATER DISTRIBUTION PUMP	UTILITY WATER	UW-002-AC-2"	80	130	0.15	50	0-200	GLYCERYN	N/A	
74	PI-P-017-002A	TMBP-SP001-PR-PID-D121	WATER DISTRIBUTION PUMP	UTILITY WATER	UW-004-AC-2"	80	130	25	45	0-200	GLYCERYN	N/A	
75	PI-P-017-001B	TMBP-SP001-PR-PID-D121	WATER DISTRIBUTION PUMP	UTILITY WATER	UW-005-AC-2"	80	130	0.15	50	0-200	GLYCERYN	N/A	
76	PI-P-017-002B	TMBP-SP001-PR-PID-D121	WATER DISTRIBUTION PUMP	UTILITY WATER	UW-006-AC-2"	80	130	25	45	0-200	GLYCERYN	N/A	
77	PI-P-016-002A	TMBP-SP001-PR-PID-D121	BOOSTER PUMP	UTILITY WATER	WR-006-AC-2"	80	130	40	130	0-200	GLYCERYN	N/A	
78	PI-P-016-001A	TMBP-SP001-PR-PID-D121	BOOSTER PUMP	UTILITY WATER	WR-006-AC-2"	80	130	120	130	0-200	GLYCERYN	N/A	
79	PI-P-016-002B	TMBP-SP001-PR-PID-D121	BOOSTER PUMP	UTILITY WATER	WR-006-AC-2"	80	130	40	130	0-200	GLYCERYN	N/A	
80	PI-P-016-001B	TMBP-SP001-PR-PID-D121	BOOSTER PUMP	UTILITY WATER	WR-006-AC-2"	80	130	120	130	0-200	GLYCERYN	N/A	
81	PI-P-008-001A	TMBP-SP001-PR-PID-D121	BOOSTER PUMP	UTILITY WATER	WR-001-AC-2"	80	130	120	177	0-200	GLYCERYN	N/A	
82	PI-P-008-001B	TMBP-SP001-PR-PID-D121	BOOSTER PUMP	UTILITY WATER	WR-002-AC-2"	80	130	120	177	0-200	GLYCERYN	N/A	