NAMA PEMILIK PROYEK : **PT PERTAMINA EP**

NAMA PROYEK : **JASA PEMBANGUNAN FASILITAS PRODUKSI STASIUN PENGUMPUL (SP) TANJUNG MIRING BARAT & KARANGAN TIMUR**

LOKASI : **SP TANJUNG MIRING BARAT & KARANGAN TIMUR - FIELD LIMAU**

NO. KONTRAK : **SA02035383B**

REV.	TGL.	DESKRIPSI	DISIAPKAN	DIPERIKSA	DISETUJUI	DIPERIKSA	DISETUJUI
A	09/01/2026	Issued For Review	MHP	AS	MR		
			PT. PROSYMPAC OIL & GAS			PT. PERTAMINA EP	

TABEL REVISI

Rev.	Tanggal	Deskripsi

COMMENT RESPONSE SHEET

No.	Page	PERUSAHAAN's Comment	Contractor's Response	Remarks

DAFTAR ISI

TABEL REVISI **2**
COMMENT RESPONSE SHEET **3**
DAFTAR ISI **4**
1. DATA SHEET FOR PRESSURE TRANSMITTER **5**
1.1 PRESSURE TRANSMITTER LIST 6
2. DATA SHEET FOR PRESSURE TRANSMITTER (D/P TYPE) **7**
2.1 PRESSURE TRANSMITTER (D/P TYPE) LIST 8
3. DATA SHEET FOR FLOW TRANSMITTER (D/P TYPE) **9**
3.1 FLOW TRANSMITTER (D/P TYPE) LIST 10
4. DATA SHEET FOR LEVEL TRANSMITTER (D/P TYPE) **11**
4.1 LEVEL TRANSMITTER (D/P TYPE) LIST 12

skkmigas PERTAMINA EP	**PERTAMINA EP** **REGIONAL 1 ZONA 4**	PGG

DATA SHEET FOR PRESSURE TRANSMITTER	No. Dok. : TMBP-SP001-IN-DST-D107 Rev. : A Halaman : 5 dari 12

Tag Number	: See List	Service	: See List
P&ID No.	: See List	Equip./Line No.	: See List

PROCESS DATA	1	Fluid		See List		
	2	Fluid State		See List		
	3	Op. Pressure	Design Pressure	See List	psig	See List psig
	4	Op. Temperature	Design Temperature	See List	degF	See List degF
	5					
TRANSMITTER	6	Instrument Type		Pressure Transmitter		
	7	Element Type		Diaphragm		
	8	Element Material		316SS		
	9	Wetted Body Material		316SS		
	10	Case Material & Colour		Manufacture Standard/Epoxy Coated Copper Free Alm.		
	11	Process Connection Size		½" NPTM		
	12	Electrical Connection		½" NPTF		
	13	Output Signal		4-20 mA DC, HART Protocol		
	14	Power Supply		24 VDC, Two Wire Loop Powered		
	15	Scale Type		Linear		
	16	Scale Unit		psig		
	17	Accuracy	Repeatability	± 0.1% of Span		± 0.5% of Span
	18	Calibration Range		See List		
	19	Instrument Range		See List		
	20	Zero-Span Adjustment		Yes, Required		
	21	Lightning Protection	Transcient Protector	Yes, Built in		YES
	22	Overpressure Protection		Yes, 1.5x Max. Element Rating		
	23	Indication Display		LCD		
	24	Hazardous Area Classification		Zone 2		
	25	Enclosure Protection Class		IP65		
	26	Certification		Eex"d"		
	27					
OPTIONS	28	Mounting Bracket c/w Bolts & Nuts		See List		(6)
	29	Valve Manifold		2-way manifold, ½" NPTF, 316SS		
	30	Condensate Pot		N/A		
	31	Diaphragm Seal		N/A		
	32	Capillary Length		N/A		
	33	SIL 2 Requirement		YES		
	34	Packing Material		Teflon		(5)
	35					
REMARKS	36	Name Plate (Tagging Number)		YES, 316SS		(1)
	37	Manufacture		As per AML / PML		(2)
	38	Model No.		By VENDOR		(3)

Notes:

1. All instrument shall be tagged with 316 SS nameplate showing tag no.
2. VENDOR shall be refer to PERTAMINA HULU ROKAN Approved Manufacturers List (AML).
3. VENDOR shall submit proper model number on bid proposal.
4. Process data refer to P&ID and Hysys data.
5. VTA; VENDOR to Advise.
6. For Manifod Injection direct mounted
7. Vendor shall be add hand held HARTcommunicator Emerson 475 or Equivalent

PRESSURE TRANSMITTER LIST

No.	Tag Number	P&ID No.	Service	Equip./Line Number	Fluid	State	Mounting	Temperature (°F)		Pressure (Psig)		Calibration Range (Psig)	Instrument Range (Psig)
								Oper.	Design	Oper.	Design		
1	PIT-TMB-001	TMBP-SP001-PR-PID-D101	LP PRODUCTION MANIFOLD TMB	PF-001-A-6"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	50	70	0-90	0-100
2	PIT-TMB-002	TMBP-SP001-PR-PID-D101	TEST MANIFOLD TMB	PF-002-A-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	101	138	50	70	0-90	0-100
3	PIT-V-001-001	TMBP-SP001-PR-PID-D101	PRODUCTION SEPARATOR TMB	V-001	PROCESS GAS	GAS	2" Pipe Mounting	100.68	150	50	100	0-175	0-200
4	PIT-V-001-002	TMBP-SP001-PR-PID-D101	PRODUCTION SEPARATOR TMB	V-001	PROCESS GAS	GAS	2" Pipe Mounting	100.68	150	50	100	0-175	0-200
5	PIT-V-003-001	TMBP-SP001-PR-PID-D101	TEST SEPARATOR TMB	V-003	PROCESS GAS	GAS	2" Pipe Mounting	100	150	50	100	0-125	0-200
6	PIT-V-003-002	TMBP-SP001-PR-PID-D101	TEST SEPARATOR TMB	V-003	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	100	150	50	100	0-125	0-200
7	PIT-KRG-001	TMBP-SP001-PR-PID-D102	LP PRODUCTION MANIFOLD TMB	PF-005-A-6"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	49	70	0-165	0-200
8	PIT-KRG-002	TMBP-SP001-PR-PID-D102	TEST MANIFOLD TMB	PF-006-A-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	45	70	0-165	0-200
9	PIT-V-002-001	TMBP-SP001-PR-PID-D102	PRODUCTION SEPARATOR KRG	V-002	PROCESS GAS	GAS	2" Pipe Mounting	90	200	50	230	0-250	0-300
10	PIT-V-002-002	TMBP-SP001-PR-PID-D102	PRODUCTION SEPARATOR KRG	V-002	PROCESS GAS	GAS	2" Pipe Mounting	90	200	50	230	0-250	0-300
11	PIT-V-004-001	TMBP-SP001-PR-PID-D102	TEST SEPARATOR KRG OUTLET	V-004	PROCESS GAS	GAS	2" Pipe Mounting	81	150	50	100	0-125	0-200
12	PIT-V-004-002	TMBP-SP001-PR-PID-D102	TEST SEPARATOR KRG OUTLET	V-004	PROCESS GAS	GAS	2" Pipe Mounting	81	119	50	100	0-125	0-200
13	PIT-P-002-001A	TMBP-SP001-PR-PID-D103	TEST PUMP A INLET TMB	PL-008-A-4"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	101	138	0.15	80	0-96	0-100
14	PIT-P-002-002A	TMBP-SP001-PR-PID-D103	TEST PUMP A OUTLET TMB	PL-010-A-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	39	80	0-96	0-100
15	PIT-P-003-001A	TMBP-SP001-PR-PID-D104	TEST TANK KRG	PL-016-A-4"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	0.15	80	0-96	0-100
16	PIT-P-003-002A	TMBP-SP001-PR-PID-D104	TEST TANK KRG	PL-018-A-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	39	80	0-96	0-100
17	PIT-P-003-001B	TMBP-SP001-PR-PID-D104	TEST TANK KRG	PL-017-A-4"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	0.15	80	0-96	0-100
18	PIT-P-003-002B	TMBP-SP001-PR-PID-D104	TEST TANK KRG	PL-019-A-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	39	80	0-96	0-100
19	PIT-P-001-001A	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP A INLET	PL-063-BA-10"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	0.15	50	0-60	0-100
20	PIT-P-001-002A	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP A OUTLET	PL-048-BA-8"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	82	138	285.6	303	0-350	0-400
21	PIT-P-001-001B	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP A INLET	PL-064-BA-2"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	138	0.15	50	0-60	0-100
22	PIT-P-001-002B	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP A OUTLET	PL-072-BA-8"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	82	138	265	303	0-350	0-400
23	PIT-V-005-001	TMBP-SP001-PR-PID-D114	PRODUCTION SCRUBBER	V-005	PROCESS GAS	GAS	2" Pipe Mounting	90	150	32	100	0-120	0-200
24	PIT-V-006-001	TMBP-SP001-PR-PID-D115	KNOCK OUT DRUM VESSEL	V-006	FLARE	GAS	2" Pipe Mounting	253.2	300	4.63	50	0-60	0-100
25	PIT-V-006-002	TMBP-SP001-PR-PID-D115	FLARE FROM KNOCK OUT DRUM VESSEL TO FLARE STACK	F-011-AA-6"	FLARE	GAS	2" Pipe Mounting	243.2	293	3.82	50	0-60	0-100
26	PIT-P-006-001A	TMBP-SP001-PR-PID-D115	KNOCKOUT PUMP A	PL-040-AA-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	65	118.7	1.65	20.68	0-25	0-100
27	PIT-P-006-002A	TMBP-SP001-PR-PID-D115	KNOCKOUT PUMP A	PL-038-AA-2"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	65	118.7	30	50	0-60	0-100
28	PIT-P-006-001B	TMBP-SP001-PR-PID-D115	KNOCKOUT PUMP B	PL-044-AA-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	65	118.7	1.65	20.68	0-25	0-100
29	PIT-P-006-002B	TMBP-SP001-PR-PID-D115	KNOCKOUT PUMP B	PL-045-AA-2"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	65	118.7	30	50	0-60	0-100
30	PIT-V-007-001	TMBP-SP001-PR-PID-D116	CLOSE DRAIN VESSEL	V-007	PROCESS GAS	GAS	2" Pipe Mounting	90	155	0.5	50	0-60	0-100
31	PIT-P-007-001A	TMBP-SP001-PR-PID-D116	CLOSE DRAIN PUMP A	PL-043-AA-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	133.6	1.57	20.68	0-25	0-100
32	PIT-P-007-002A	TMBP-SP001-PR-PID-D116	CLOSE DRAIN PUMP A	PL-039-AA-2"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	133.6	35	55	0-66	0-100
33	PIT-P-007-001B	TMBP-SP001-PR-PID-D116	CLOSE DRAIN PUMP B	PL-044-AA-3"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	133.6	1.57	20.68	0-25	0-100
34	PIT-P-007-002B	TMBP-SP001-PR-PID-D116	CLOSE DRAIN PUMP B	PL-045-AA-2"	PRODUCTION FLUID	LIQUID	2" Pipe Mounting	81	133.6	35	55	0-66	0-100
35	**PIT-P-019-001**	TMBP-SP001-PR-PID-D117	WATER SUMP PUMP	WW-001-AA-3"	WASTE WATER	LIQUID	2" Pipe Mounting	95	115	30	50	0-65	0-100
36	PIT-FG-001-003	TMBP-SP001-PR-PID-D118	FUEL GAS FROM TALANG JIMAR TO TRUNKLINE	GF-002-AA-4"	FUEL GAS	GAS	2" Pipe Mounting	81	110	100	150	0-165	0-200
37	PIT-P-017-002B	TMBP-SP001-PR-PID-D121	WATER DISTRIBUTION PUMP B	UW-004-AC-2"	UTILITY WATER	LIQUID	2" Pipe Mounting	95	115	25	55	0-66	0-100

skkmigas PERTAMINA EP	**PERTAMINA EP** **REGIONAL 1 ZONA 4**	POG

DATA SHEET FOR PRESSURE TRANSMITTER (D/P TYPE)	No. Dok. : TMBP-SP001-IN-DST-D107 Rev. : A Halaman : 7 dari 12

Tag Number	: See List	Service	: See List
P&ID No.	: See List	Equip./Line No.	: See List

PROCESS DATA	1	Fluid		Process Liquid		
	2	Fluid State		Liquid		
	3	Op. Pressure	Design Pressure	See List psig	See List psig	
	4	Op. Temperature	Design Temperature	See List degF	See List degF	
	5	Op. Pressure Differential	Design Differential Pressure	See List psig	See List psig	
	6					
TRANSMITTER	7	Instrument Type		Differential Pressure Measurement		
	8	Element Type		Diaphragm/Capacitance		
	9	Element Material		316SS		
	10	Wetted Body Material		316SS		
	11	Case Material & Colour		Manufacture Standard/Epoxy Coated Copper Free Alm.		
	12	Process Connection Size		½" NPTM		
	13	Electrical Connection		½" NPTF		
	14	Output Signal		4-20 mA DC, HART Protocol		
	15	Power Supply		24 VDC, Two Wire Loop Powered		
	16	Scale Type		Linear		
	17	Scale Unit		psig		
	18	Accuracy | Repeatability		± 0.1% of Span	± 0.5% of Span	
	19	Calibration Range		0-5 psig		
	20	Instrument Range		0-5 psig		(4)
	21	Zero-Span Adjustment		Yes, Required		
	22	Lightning Protection	Transcient Protector	Yes, Built in	YES	
	23	Overpressure Protection		Yes, 130% of maximum range		
	24	Indication Display		LCD		
	25	Hazardous Area Classification		Zone 2		
	26	Enclosure Protection Class		IP65		
	27	Certification		Eex"d"		
	28					
OPTIONS	29	Mounting Bracket c/w Bolts & Nuts		YES, 2" Pipe Mounting, 304SS		
	30	Valve Manifold		5-way manifold, ½" NPTF, 316SS		
	31	Condensate Pot		N/A		
	32	Diaphragm Seal		N/A		
	33	Capillary Length		N/A		
	34	SIL 2 Requirement		N/A		
	35	Packing Material		Teflon		(5)
	36					
REMARKS	37	Name Plate (Tagging Number)		YES, 316SS		(1)
	38	Manufacture		As per AML / PML		(2)
	39	Model No.		By VENDOR		(3)

Notes:

1. All instrument shall be tagged with 316 SS nameplate showing tag no.
2. VENDOR shall be refer to PT. PERTAMINA HULU ROKAN Approved Manufacturers List (AML)
3. VENDOR shall submit proper model number on bid proposal.
4. The valve manifold shall be assembled & tested at factory as integral unit
5. VTA; VENDOR to Advise.
6. Manufacturer standard

PRESSURE TRANSMITTER (D/P TYPE) LIST

No.	Tag Number	P&ID No.	Service	Equip./Line Number	Fluid	State	Temperature (°F)		Pressure (Psig)		Pressure Diff. (Psig)	
							Oper.	Design	Oper.	Design	Oper.	Design
1	PDIT-T-003-001	TMBP-SP001-PR-PID-D103	TEST PUMP B INLET TMB	PL-006-AA-6"	Process Liquid	Liquid	101	138	0.15	80	0	0
2	PDIT-T-004-001	TMBP-SP001-PR-PID-D104	TEST TANK KRG TO TEST PUMP KARANGAN	PL-016-AA-6"	Process Liquid	Liquid	81	138	0.15	80	0	0
3	PDIT-P-001-001	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP INLET	PL-029-A-10"	Process Liquid	Liquid	81	138	0.15	50	0	0
4	PDIT-T-003-001	TMBP-SP001-PR-PID-D107	FEED WATER PUMP INLET	PL-029-AA-10"	Process Liquid	Liquid	81	138	0.15	50	0	0

skkmigas PERTAMINA EP	**PERTAMINA EP REGIONAL 1 ZONA 4**	POG

DATA SHEET FOR FLOW TRANSMITTER (D/P TYPE)	No. Dok. : TMBP-SP001-IN-DST-D107 Rev. : A Halaman : 9 dari 12

Tag Number	: See List	Service	: See List
P&ID No.	: See List	Equip./Line No.	: See List

PROCESS CONDITION	1	Fluid		See List		
	2	Fluid State		See List		
	3	Op. Pressure	Design Pressure	See List psig	See List	psig
	4	Op. Temperature	Design Temperature	See List degF	See List	degF
	5	Op. Flow	Design Flow	See List	See List	
	6	Molecular Weight / Specific Gravity		See List		
	7					
	8					
GENERAL	9	Type		Differential Pressure		
	10	Function		Flow Transmitter, Indication		
	11	Mounting		2" Pipe Mounting Stanchion		
	12	Enclosure Class		IP65		
	13	Certification (Explosion Protective Type)		Eex"d"		
	14	Hazardous Area Classification Requirment		Zone 2		
	15					
TRANSMITTER	16	Element Type		Diaphragm		
	17	Element Material		316SS		
	18	Wetted Body Material		316SS		
	19	Case Material & Colour		Manufacture Standard/Epoxy Coated Copper Free Alm.		
	20	Process Connection		½" NPTF		
	21	Electrical Connection		½" NPTF		
	22	Output Signal		4-20 mA DC, HART Protocol		
	23	Power Supply		24 VDC, Two Wire Loop Powered		
	24	Scale Unit		See List		
	25	Accuracy		± 0.1% of Span		
	26	Calibration Range		See List		
	27	Instrument Range		See List		(5)
	28	Zero-Span Adjustment		YES		
	29	Lightning Protection	Transcient Protector	YES	YES	
	30	Indication Display		LCD		
	31	Overrange Protection		YES		
	32					
	33					
OPTIONS	34	Mounting Bracket c/w Bolts & Nuts		YES, Manufacture Standard		
	35	Valve Manifold		5-way manifold, ½" NPTF, 316SS		
	36	Condensate Pot		N/A		
	37	Diaphragm Seal		N/A		
	38	Capillary Length		N/A		
	39	Flushing Ring		N/A		
	40					
REMARKS	41	Manufacture		As per AML / PML		(2)
	42	Model No.		By VENDOR		(3)
	43	Name Plate (Tagging Number)		YES, 316SS		(1)

Notes:

1. All instrument shall be tagged with 316 SS nameplate showing tag no.
2. VENDOR shall be refer to PT. PERTAMINA HULU ROKAN Approved Manufacturers List (AML)
3. VENDOR shall submit proper model number on bid proposal.
4. The valve manifold shall be assembled & tested at factory as integral unit
5. Manufacturer standard

FLOW TRANSMITTER (D/P TYPE) LIST

No.	Tag Number	P&ID No.	Service	Equip./Line Number	Fluid	State	Temperature (°F)		Pressure (Psig)		Flow			Specific Gravity	Scale Unit	Calibration Range	Instrument Range	Unit
							Oper.	Design	Oper.	Design	Oper.	Design	Unit					
1	FT-V-001-001	TMBP-SP001-PR-PID-D101	PRODUCTION SEPARATOR TMB TO WASH TANK TMB	PL-001-AA-3"	Gross (Oil & Water)	Liquid	81	150	44.96	100	886	975	BPD	22.56	MMSCFD	0-100 mmH_2O	-(10) - 5000	BPD
2	FT-V-003-001	TMBP-SP001-PR-PID-D101	TEST SEPARATOR TMB TO TANK TEST TMB	PL-002-AA-2"	Gross (Oil & Water)	Liquid	101	151	44.25	100	745	820	BPD	22.56	MMSCFD	0-100 mmH_2O	-(10) - 1000	BPD
3	FT-V-002-001	TMBP-SP001-PR-PID-D102	PRODUCTION SEPARATOR TO WASH TANK KRG	PL-003-A-4"	Gross (Oil & Water)	Liquid	81	150	43.97	100	5561	6117	BPD	22.6	MMSCFD	0-100 mmH_2O	-(10) - 11000	BPD
4	FT-V-004-001	TMBP-SP001-PR-PID-D102	TEST SEPARATOR KRG TO TANK TEST KRG	PL-004-A-2"	Gross (Oil & Water)	Liquid	81	150	40.1	100	810	891	BPD	21.62	MMSCFD	0-100 mmH_2O	-(10) - 1100	BPD
5	FIT-P-001-001	TMBP-SP001-PR-PID-D107	GROSS TRANSFER PUMP TO SP TMT	PL-052-A-12"	Gross (Oil & Water)	Liquid	82	150	265.6	725	11995	12000	BPD	-	MMSCFD	0-100 mmH_2O	-(10) - 15000	BPD
6	FT-FG-001-001	TMBP-SP001-PR-PID-D118	FUEL GAS FROM TALANG JIMAR TO FUEL GAS SCRUBBER	GF-001-AA-4"	Fuel Gas	Gas	80	130	100	150	1.74	5	MMSCFD	18.57	MMSCFD	0-100 mmH_2O	-(10) - 150	MMSCFD
7	FT-F-006-001	TMBP-SP001-PR-PID-D119	FROM FUEL GAS PACKAGE TO GAS ENGINE GENERATOR	GF-003-AA-3"	Fuel Gas	Gas	80	130	1.05	1.15	100	120	MMSCFD	18.57	MMSCFD	0-100 mmH_2O	-(10) - 3000	BWPD

skkmigas PERTAMINA EP	**PERTAMINA EP REGIONAL 1 ZONA 4**	POG

DATA SHEET FOR LEVEL TRANSMITTER (D/P TYPE)	No. Dok. : TMBP-SP001-IN-DST-D107 Rev. : A Halaman : 11 dari 12

Tag Number	: See List	Service	: See List
P&ID No.	: See List	Equip./Line No.	: See List

SERVICE CONDITION	1	Fluid		See List			
	2	Fluid State		See List			
	3	Op. Pressure	Design Pressure	See List	psig	See List	psig
	4	Op. Temperature	Design Temperature	See List	degF	See List	degF
	5	Operating Density		See List	lb/ft^3		
	6	Specific Gravity					
	7	Horizontal Vessel Height		See List	feet		
	8						
GENERAL	9	Type		DP Diaphragm			
	10	Function		Level Transmitter, Indicating			
	11	Mounting		Remote, 2" Pipe Mounting Stanchion			
	12	Enclosure Class		IP65			
	13	Certification (Explosion Protective Type)		Eex"d"			
	14	Hazardous Area Classification Requirment		Zone 2, Group IIA, Class T3			
	15						
TRANSMITTER	16	Wetted Body Material		316SS			
	17	Case Material		Aluminum die cast, epoxy coating (Manufacture Standard)			
	18	Process Connection Size		2" Flange, ANSI Class 150# RF			
	19	Electrical Connection		½" NPTF			
	20	Output Signal		4-20 mA DC, HART Protocol			
	21	Power Supply		24 VDC, Two Wire Loop Powered			
	22	Scale Type		Linear			
	23	Scale Range		-(250)-250 mmH_2O			(5)
	24	Scale Indication Range		0-100%			
	25	Accuracy	Repeatability	0.1% of span			
	26	Zero-Span Adjustment		YES			
	27	Lightning Protection	Transcient Protector	YES, Built in		YES	
	28	Indication Display		LCD			
	29						
DIAPHRAGM SEAL	30	Process Connection & Rating		2" Flange, ANSI Class 150# RF			
	31	Diaphragm Material		316SS			
	32	Capillary Material		316SS			
	33	Fill Fluid		Silicon			
	34	Capillary Length		10	feet		
	35	Allowable Over Temperature					(5)
	36						
OPTION	37	Bolt & Nuts		YES			
	38	Heat Tracing		N/A			
	39	Chamber Insulation		N/A			
	40	Switch		N/A			
PURCHASE	41	Name Plate (Tagging Number)		YES, 316SS			(1)
	42	Manufacture		As per AML / PML			(2)
	43	Model No.		By VENDOR			(3)

Notes:

1. All instrument shall be tagged with 316 SS nameplate showing tag no.
2. VENDOR shall be refer to PT. PERTAMINA HULU ROKAN Approved Manufacturers List (AML)
3. VENDOR shall submit proper model number on bid proposal.
4. Process data refer to Hysys data.
5. Vendor To Advice
6. Please add Flushing ring

skkmigas PERTAMINA EP	**PERTAMINA EP** **REGIONAL 1 ZONA 4**	POG
DATA SHEET LEVEL TRANSMITTER (D/P TYPE)		No. Dok. : TMBP-SP001-IN-DST-D107 Rev. : A Halaman : 12 dari 12

LEVEL TRANSMITTER (D/P TYPE) LIST

No.	Tag Number	P&ID No.	Service	Equip./Line Number	Fluid	State	Temperature (^oF)		Pressure (Psig)		Operating Density (lb/ft^3)	Specific Gravity	Horizontal Vessel Height (Feet)
							Oper.	Design	Oper.	Design			
1	LIT-V001-001	TMBP-SP001-PR-PID-D101	PRODUCTION SEPARATOR TMB	V-001	PROCESS LIQUID (GROSS)	LIQUID	81.05	200	44.96	230	60.28	0.972	5.48
2	LIT-V001-003	TMBP-SP001-PR-PID-D101	PRODUCTION SEPARATOR TMB	V-001	PROCESS LIQUID (GROSS)	LIQUID	81.05	200	44.96	230	60.28	0.972	5.48
3	LIT-V003-001	TMBP-SP001-PR-PID-D101	TEST SEPARATOR TMB	V-003	PROCESS LIQUID (GROSS)	LIQUID	100.58	150	44.25	100	60.56	0.977	3.3
4	LIT-V003-003	TMBP-SP001-PR-PID-D101	TEST SEPARATOR TMB	V-003	PROCESS LIQUID (GROSS)	LIQUID	100.58	150	44.25	100	60.56	0.977	3.3
5	LIT-V002-001	TMBP-SP001-PR-PID-D102	PRODUCTION SEPARATOR KRG	V-002	PROCESS LIQUID (GROSS)	LIQUID	81.23	200	43.97	230	61.76	0.996	6.99
6	LIT-V002-003	TMBP-SP001-PR-PID-D102	PRODUCTION SEPARATOR KRG	V-002	PROCESS LIQUID (GROSS)	LIQUID	81.23	200	43.97	230	61.76	0.996	6.99
7	LIT-V004-001	TMBP-SP001-PR-PID-D102	TEST SEPARATOR KRG OUTLET	V-004	PROCESS LIQUID (GROSS)	LIQUID	80.88	150	40.1	100	59.16	0.954	3.5
8	LIT-V004-003	TMBP-SP001-PR-PID-D102	TEST SEPARATOR KRG OUTLET	V-004	PROCESS LIQUID (GROSS)	LIQUID	80.88	150	40.1	100	59.16	0.954	3.5
9	LIT-T005-001A	TMBP-SP001-PR-PID-D105	STORAGE TANK TMB (T-005A)	T-001	PROCESS LIQUID (GROSS)	LIQUID	81	150	0.15	Full of Water + 1	60.30	0.973	16
10	LIT-T005-001B	TMBP-SP001-PR-PID-D105	STORAGE TANK TMB (T-005A)	T-001	PROCESS LIQUID (GROSS)	LIQUID	81	150	0.15	Full of Water + 1	60.30	0.973	16
11	LIT-T005-002A	TMBP-SP001-PR-PID-D105	STORAGE TANK TMB (T-005B)	T-005B	PROCESS LIQUID (GROSS)	LIQUID	81	150	0.15	Full of Water + 1	61.77	0.996	25.3
12	LIT-T005-002B	TMBP-SP001-PR-PID-D105	STORAGE TANK TMB (T-005B)	T-005B	PROCESS LIQUID (GROSS)	LIQUID	81	150	0.15	Full of Water + 1	61.77	0.996	25.3
13	LIT-T006-001A	TMBP-SP001-PR-PID-D106	STORAGE TANK TMB (T-005A)	T-006A	PROCESS LIQUID (GROSS)	LIQUID	81.28	150	0.15	Full of Water + 1	61.77	0.996	16
14	LIT-T006-001B	TMBP-SP001-PR-PID-D106	STORAGE TANK TMB (T-005A)	T-006A	PROCESS LIQUID (GROSS)	LIQUID	81.28	150	0.15	Full of Water + 1	61.77	0.996	16
15	LIT-T006-002A	TMBP-SP001-PR-PID-D106	STORAGE TANK TMB (T-005B)	T-006B	PROCESS LIQUID (GROSS)	LIQUID	81.28	150	0.15	Full of Water + 1	62.60	1.010	16
16	LIT-T006-002B	TMBP-SP001-PR-PID-D106	STORAGE TANK TMB (T-005B)	T-006B	PROCESS LIQUID (GROSS)	LIQUID	81.28	150	0.15	Full of Water + 1	62.60	1.010	16
17	**LIT-V005-001**	TMBP-SP001-PR-PID-D114	PRODUCTION SCRUBBER	V-005	PROCESS LIQUID (GROSS)	LIQUID	79.86	150	29	100	50.83	0.820	8.5
18	**LIT-V005-002**	TMBP-SP001-PR-PID-D114	PRODUCTION SCRUBBER	V-005	PROCESS LIQUID (GROSS)	LIQUID	79.86	150	29	100	50.83	0.820	8.5
19	LIT-V006-001	TMBP-SP001-PR-PID-D115	KNOCK OUT DRUM VESSEL	V-006	PROCESS LIQUID (GROSS)	LIQUID	**253**	**23**	30	50	50	0.812	4
20	LIT-V006-002	TMBP-SP001-PR-PID-D115	KNOCK OUT DRUM VESSEL	V-006	PROCESS LIQUID (GROSS)	LIQUID	**253**	**200**	30	50	50	0.812	4
21	LIT-V007-001	TMBP-SP001-PR-PID-D116	CLOSE DRAIN VESSEL	V-007	PROCESS LIQUID (GROSS)	LIQUID	83.64	150	35	50	61.24	0.988	4.5
22	LIT-V007-002	TMBP-SP001-PR-PID-D116	CLOSE DRAIN VESSEL	V-007	PROCESS LIQUID (GROSS)	LIQUID	83.64	150	35	50	61.24	0.988	4.5