**NAMA PEMILIK PROYEK** : **PT PERTAMINA EP**

**NAMA PROYEK** : **JASA PEMBANGUNAN FASILITAS PRODUKSI STASIUN PENGUMPUL (SP) TANJUNG MIRING BARAT & KARANGAN TIMUR**

**LOKASI** : **SP TANJUNG MIRING BARAT & KARANGAN TIMUR - FIELD LIMAU**

**NO. KONTRAK** : **SA02035383B**

| REV. | TGL. | DESKRIPSI | DISIAPKAN | DIPERIKSA | DISETUJUI | DIPERIKSA | DISETUJUI |
|---|---|---|---|---|---|---|---|
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| A | 09/01/2026 | Issued For Review | MHP | AS | MR | | |
| | | | PT. PROSYMPAC OIL & GAS | | | PT. PERTAMINA EP | |

**TABEL REVISI**

| Rev. | Tanggal | Deskripsi |
|---|---|---|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

**COMMENT RESPONSE SHEET**

| No. | Page | PERUSAHAAN's Comment | Contractor's Response | Remarks |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

## DAFTAR ISI

**TABEL REVISI** ..... **2**
**COMMENT RESPONSE SHEET** ..... **3**
**DAFTAR ISI** ..... **4**
**1. DATA SHEET FOR ROTAMETER** ..... **5**
1.1 ROTAMETER LIST ..... 6

| | | |
|---|---|---|
| skkmigas PERTAMINA EP | **PERTAMINA EP**<br>**REGIONAL 1 ZONA 4** | POG |

| | |
|---|---|
| **DATA SHEET FOR ROTAMETER** | No. Dok. : TMBP-SP001-IN-DST-D112<br>Rev. : A<br>Halaman : 5 dari 6 |

| | | | |
|---|---|---|---|
| Tag Number | : See List | Service | : See List |
| P&ID No. | : See List | Equip./Line No. | : See List |

| | | | | | |
|---|---|---|---|---|---|
| **PROCESS CONDITION** | 1 | Fluid | State | Produced Water | Liquid |
| | 2 | Operating Pressure | | See List | psig |
| | 3 | Operating Temperature | | See List | degF |
| | 4 | Density | | See List | $lb/ft^3$ |
| | 5 | Viscosity | | See List | cP |
| | 6 | Operating Flowrate | | See List | BWPD |
| | 7 | Allowable dP | | See List | psig |
| | 8 | Molecular Weight | | See List | |
| | 9 | | | | |
| **MEASURING ELEMENT** | 10 | Type | | Metal Tube | |
| | 11 | Flow Direction | | Bottom to Top | |
| | 12 | Flow Range | | See List | |
| | 13 | Accuracy | | 1% Full Scale | |
| | 14 | Tube Material | | 316SS | |
| | 15 | Float Material | | 316SS | |
| | 16 | Other Wetted Parts Material | | 316SS | |
| | 17 | Flange Size | | See List | |
| | 18 | Flange Rating | | ANSI Class 150# RF | |
| | 19 | Flange Material | | 316SS | |
| | 20 | Indicator Size | | Note | (3) |
| | 21 | Output | | 4-20 mA HART | |
| | 22 | Power Supply | | 24 VDC, Loop powered | |
| | 23 | | | | |
| **CASING** | 24 | Material | | Aluminum Die Cast | |
| | 25 | Ingress Protection | | IP65 | |
| | 26 | Electrical Connection Size | | ½" NPT | |
| | 27 | | | | |
| | 28 | | | | |
| **SWITCH** | 29 | Type | | N/A | |
| | 30 | Quantity | | N/A | |
| | 31 | Form | | N/A | |
| | 32 | Action | | N/A | |
| | 33 | Contact Rating | | N/A | |
| | 34 | Contact Action | | N/A | |
| | 35 | | | | |
| **REMARKS** | 36 | Name Plate (Tagging Number) | | YES, 316SS | (1) |
| | 37 | Manufacture | | As per AML / PML | (2) |
| | 38 | Model No, | | By VENDOR | (3) |

Notes:

1. All Instrument shall be tagged with 316 SS Nameplate showing Tag No.
2. As per Manufacture standard/ Subject to PT.Pertamina HULU ROKAN approval.
3. Vendor To Advise
4. Testing during FAT refer to general specification for Instrumentation Doc. No. TMBP-01-IN-SPE-105

| | | |
|---|---|---|
| skkmigas PERTAMINA EP | **PERTAMINA EP**<br>**REGIONAL 1 ZONA 4** | POG |
| **DATA SHEET FOR ROTAMETER** | | No. Dok. : TMBP-SP001-IN-DST-D112<br>Rev. : A<br>Halaman : 6 dari 6 |

**ROTAMETER LIST**

| No. | Tag Number | P&ID No. | Service | Equip./Line Number | Operating Temperature ($^oF$) | Operating Pressure (Psig) | Density ($lb/ft^3$) | Viscosity (cP) | Flowrate (BWPD) | Allowable dP | Molecular Weight | Flow Range | Flange Size |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | FI-T-001-001 | TMBP-SP001-PR-PID-D105 | FROM WASH TANK TMB TO PRODUCE WATER TANK TMB | PW-001-CA-4" | 87.82 | 0.15 | 62.6 | 0.78 | 1755 | - | 18.02 | 0-2200 BWPD | 4" |
| 2 | FI-T-002-001 | TMBP-SP001-PR-PID-D105 | FROM WASH TANK KRG TO PRODUCE WATER TANK KRG | PW-002-AA-4" | 83.59 | 0.15 | 62.71 | 0.82 | 2252 | - | 18.02 | 0-2700 BWPD | 2' |
| 3 | FI-P-008-001A | TMBP-SP001-PR-PID-D105 | FROM DEEP WELL PUMP TO WATER POND | WR-002-AC-2" | 95 | 120 | 62.8 | 0.719 | 206 | - | 18.2 | 0-300 BPD | 2' |
| 4 | FI-P-008-001B | TMBP-SP001-PR-PID-D105 | FROM DEEP WELL PUMP TO WATER POND | WR-002-AC-2" | 95 | 120 | 62.8 | 0.719 | 206 | - | 18.2 | 0-300 BPD | 2' |