## **SenNet IoT Easy Meter Sigfox**

Energy Meter 3PH CT/Rogowski

8

Gateway for remote nodes

#### **General description**

SenNet IoT Easy Meter Sigfox is a device that monitors 3PH energy electrical circuits, with two options of current transformer, 0.33Vac or flexible Rogowski. This device has the possibility to create a local RF Network with remote nodes with different features: Pulse Counter / Temperature-Humidity / CO2 / Particulate Matter etc.., and send all this information in one Sigfox message.

The configuration of all these features is possible by three ways:


- Trough APP SenNet IoT (IOS or Android).
- Downlink message on sigfox backend.
- Micro-usb connection and console/terminal.

The end-user can select what kind of energy data and remote device wants to upload to the cloud, must select the type of message (see in the next section).

#### **Power supply**

The device uses voltage reference as the power supply (100-265VAC @ 50HZ), <u>it's important just to use Neutral</u> Line Vn and V1. There is an internal fuse to protect the device against surge damages.

Voltage power supply	100-265VAC @ 50HZ
Power	<1W



#### Basic steps to intall:

- Set the type Current Transformer: CT-0.33Vac: 50A, 100A, 150A, 400A, 800A Flexible-Rogowski: 3500A, 3700A, 5000A
- 2. Set the type of message to use and take note to parse this data on your preferred platform.
- 3. Take note ID / PAC to sign the device on Sigfox Cloud.
- Connect voltage reference (feed internal power supply) and current reference.

#### Additional steps:

- Define and install remotes devices that will join to Local Network
- Set an univoque ID at each remote device throught SenNet IoT APP.

# Easy to set with **SenNet IoT** APP iOS & Android (phones with NFC)









SenNet IoT ( Android version ) Link

# **SenNet** ion
















**Local RF Network** 

868.224MHz (EU) 2FSK / 300bps / 6.25Khz (by default)






#### **Type Message**

SenNet IoT Easy Meter is a powerful Energy Meter, the client must select what kind of data will be uploaded to the platform. For that reason, the devices have been defined by default several types of message what includes the main information from each electricity measurement.

The main interest always is the total Energy accumulated, if your interest is on another parameter you can contact with our technical department to ask for it.

Depending on the type of load to be monitored (triphasic or monofasic) you may choose these types of uplink messages:



A common point in all types of messages is the head (defined with <u>2 bytes</u>) that includes important information embedded in the message (type device/type message/errors.. etc). In the next table are defined the mean of these info-fields.

								d Info																						
Byte				Byte 1	L							В	yte 2																	
	I	ype Devi	:e	I	ype N	lessag	e	_			Туре	Remote I	Vodes	ID R	temote No	odes														
					type 0	(info)		generation	error	- h																				
	01 - Ea	sy Meter		type 1			ē	SAG	0x00 – No local Network			No Remote = 000																		
	02 – Pu	lse Count	er		typ	e 2			enc	e /	0x01 - PC LongNet			Remote	e ID = 001	<sub>b</sub> = 01 <sub>d</sub>														
	03 – No	ot defined		type 3				se in g mode	secuence	tag m	0x02 - 1	TH LongNo	et		= 010	$_{b} = 02_{d}$														
	04 – Enviroment Sensor			4 – Enviroment Sensor type 4						or type 4			ensor type 4			type 4			type 4		type 4		ge s	Overvoltage / SAG / Internal meter error	0x03 - 0	CO2-TH Lo	ongNet	= 011 <sub>b</sub> = 03 <sub>d</sub>		$_{b} = 03_{d}$
	05 - PM			type 5 (not defined)			Some Phase in mod	Ox03 - CO2-TH LongNet  0x04 - PM LongNet		let		= 100	$_{\rm b} = 04_{\rm d}$																	
	06 – GW Modbus		S	type 6 (not defined)			Š	>		0x05 -	GW Mod	bus LN		= 101	<sub>b</sub> = 05 <sub>d</sub>															
	07 – Re	peiter Sig	fox							0x06 -	Analog In	put		= 110	<sub>b</sub> = 06 <sub>d</sub>															
			type 15 (not defined)					0x07 – Not defined			ed	(6 nodes maximum)		mum)																
										ror																				
														Type M	lessage 0	(Debug)														
															= 111	$_{\rm b} = 07_{\rm d}$														
Bit	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0														
		Byte1			Ву	te1		Byte1	By	te2		Byte2			Byte2															
		Bit 7-6-5			Bit 4-	3-2-1		Bit 0	Bit	7-6		Bit 5-4-3		Bit 2-1-0																

Table 1

	Type 1 : Active + Reactive Energy + Remote Node												
Field	In	fo	Active Energy PH1+PH2+PH3 PH1+PH2+PH3 Data from Rer					emote node					
Type data	See To	able 1	f	loat 3 unit		S			32 bi kvArl		Depending on Remote node ty		
Byte	1	2	3	4	5	6	7	8	9	10	11 12		

	Type 2: Active Energy PH1 + Active Energy PH2 + Active Energy PH3												
Field	In	fo	Acti	ve Energy	PH1	Acti	ve Energy	PH2	Active Energy PH3				
Type data	Se Tab		unsign	olution=100 ed integer .6Mwh / ur	24 bits	unsign	olution=100 ed integer .6Mwh / ur	24 bits	resolution=100wh unsigned integer 24 bits Max. 1.6Mwh / unit kWh				
Byte	1	2	3	4	5	6	7	8	9 10 11				


			Тур	<b>e 3</b> : A	ctive E	nergy I	PH1 + /	Active	Energy	PH2 + R	emote Node Data			
Field	In	fo	Act	tive En	ergy P	H1	Active Energy PH2				Data from Remote Node			
Type data		See Table 1 float 32 bits / unit kWh				float 32 bits / unit kWh				Depending on Remote node type				
Byte	1	2	3 4 5 6				7	8	9	10	11	12		



Remote Node Data:										
Type of Remote Node										
	1 byte temperature Payload	1 byte humidity Payload								
TH LongNet – 868	[-10ºC60ºC] conversion function	[0-100%]								
	Temperature=Payload*0.2745-10	Humidity=Payload								
Pulse Counter LongNet – 868	2 bytes (integer type) - maximum value 65535									
Pulse Counter LongiNet - 808	Only is enabled input 1 "C1"									
	2 bytes (integer type)									
	byte 2 -High part-	byte 1 -Low part-								
CO2 LongNet - 868	7 6 5 4 3 2 1 0 7 6	5 4 3 2 1 0								
	CO2 Payload Temperature Pa (± 12ppm) (± 1°C)	yload Hum. Payload (± 6%)								
	CO2=Payload*12.6984+400 T=Payload*1.11	1-10 H= Payload*6.66								
Particulate Matter - 868	2 bytes (integer type) - under development									
Gateway Modbus – 868	2 bytes (custom) – under development									
Gateway Custom Protocol – 868	2 bytes (custom) - under development									

#### Local RF Network & types of Remotes Nodes

SenNet IoT Easy Meter can works like sigfox gateway for up to 6 remotes nodes.







#### **Debug option**

It's possible debug on remote this device, it's necessary enable with downlink message this feature. There are tree types of debug message, Debug 1 (version HW/FW), Debug 2 (internals errors), Debug 3 (instant power meter values).

If this feature is enabled one time per day or in power up will be update these messages, with this secuence:

Debug 1 (9 bytes)	Debug 2 (11 bytes)	Debug 3 (8 bytes)	
-------------------	--------------------	-------------------	--

Type 0 : Debug 1 (9 bytes)										
Field	Ir	Info HW device Version FW Revision FW Not used								
Type data	See Table 1					-				
Byte	1	2	3	4	5	6-9				

#### **Type 0**: Debug 2 (11 bytes) Wrong Reset Internal Error Error Error Field Info Voltage event 1 Voltage event 2 voltage Gen. event PH1 PH2 PH3 frequency SAG-Bit0 Bit0 PH1<50v PH1 Bit1 PH2<50v PH2 SAG-Bit2 PH3<50v Bit2 PH3 Type See Voltage OVER-Freq =!50Hz Bit3 Bit3 data Table 1 PH1 secuence Bit4 Bit4 PH2 OVER-Bit5 Bit5 PH3 Bit6 Bit6 Bit7 Bit7 9 10 11 2 Byte 1

For normal function all fields must be 0.

Type 0 : Debug 3 (8 bytes)											
Field	Ir	nfo	Active Power PH1	Active Power PH2	Active Power PH3						
Type data	See Ta	ble 1	signed integer (value*100)Watt	signed integer (value*100)Watt	signed integer (value*100)Watt						
Byte	1	2	3 - 4	5 - 6	7 - 8						

#### **Downlink Message**

It's possible to set the device in the cloud without interacting with it locally, defining this type of downlink message and CT value on the sigfox backend or in your platform. That method is optional but it's not necessary.


Byte		1	2 - 5	6	7	8
Field		Setup byte (1byte)	Set time (4bytes)	Type uplink Message (1 byte)	(2 b	alue yte) value)
	Bit 7	1 (by default)				
	Bit 6	1/0 enable/disable set Time				
	Bit 5	1/0 enable/disable set Type uplink Messsage		01		
Value	Bit 4	1/0 enable/disable set value CT	{Time-Epox}	02	High	Low
value	Bit 3	1 (by default)	(Tillie-Lpox)	03	Part	Part
	Bit 2	1/0 enable/disable Debug 1 (versión HW/FW)				
	Bit 1	1/0 enable/disable Debug 2 (internals errors)				
	Bit 0	1/0 enable/disable Debug 3 (instant power value)				

#### Example for downlink message:

**F8 {time} 01 00 32** → With this downlink message set the remote device on time, with type of message 01 and CT value 50 Amps, all debug messages disables.



With this last one debug message is possible detect wrong installation issues, for example CT with wrong orientation. Use this extra feature to analisys or debug installation.





SenNet Easy Meter works as Local Network coordinator and gateway for Remotes Nodes

Pulse Counter Node ID-01 LongNet ID=5236



**Easy Meter** 



Temperature & Humidity
Node ID-02
LongNet ID=1529



CO2 Node ID-03 LongNet ID=8552



SenNet IoT APP – Android and iOS (only phones with NFC feature)

Use APP of freely download to set and read measurement from Easy Meter.

Main screen with data about Easy Meter & Sigfox connection SenNet IoT Home Help Fields Parameters Easy Meter Type Device ID Sigfox 02BC54C7 E8500F27079F725D PAC Sigfox Network LongNet 020202 SW ver-rev 7-56 Set: CT / type of message / remote devices Read measurement SenNet IoT Back Help Help Basic Sets Console CT Value 1-Countdown to send 3 VAC: 223.0 / 223.9 / 223.7V IAC: 10.2 / 10.2 / 10.2A Advances Sets Cos:0.50 / 0.51 / 0.50 PowAct: 1143 / 1150 / 1146W Number of Remotes PowReac: 1976 / 1977 / 1978var EneTotACT: 228,9kWh ID-02 1529 EneTotREAC: 394.5kvArh ID-03 8552 EneTotAPA: 455.8kvAh

Set ID of each remote device, taking note of LongNet ID on the label and assigning it through APP phone (Android or iOS version).

For previous example, it's defined <u>Number of remotes=3</u>, and assigned each position (ID-01 / ID-02 / ID-03) at LongNet ID from label of each device, in this particulate example:

Back Basic Sets		Help
CT Value	50	~
type uplink Message	1	~
Advances Sets		
Interval to send(min.)	11	~
Number of Remotes	3	~
ID Modbus	1	~
ID-01 5236	ID-02 15	29
ID-03 8552		
3,		

Steps for install Easy Meter with remotes nodes, first must be installed Easy Meter and power supply. Later install one by one each remote device, to analyzed if link coverage is fine, set each remote device on 'RF\_prog' mode '1', sliding the switch to mini-usb connector side.


Remote device enter in beacon send mode each 5 seconds, if Easy Meter receive this beacon sound 5 beeps on Easy Meter side. After check that coverage is enough return switch of remote device to `RF prog' mode 0, and reset it.

By this way you check that link between remote device and Easy Meter works fine.




#### **Power Meter features**

These devices include advanced technology for metering power electricity loads, using a current reference and voltage reference. It's possible to use this device like a 3 single-phase meter or 1 three-phase meter, it depends on the client's goal to monitor.



Led output pulse			Current R	eference	Voltage Reference & Power Supply					
	l1+	l1-	12+	12-	13+	13-	Vn	V1	V2	V3
	(1)	(2)	(3)	(4)	(5)	(6)	(19)	(20)	(21)	(22)
Reactive Power Aparent Power	PI	11	PH	12	PI	13		Supply AC @ 50HZ		
Active Power  1 pulse/seg = 1kw	(CT – 0	Тур	e CT currer 50A, 100	nt transfo	rmer					









## Voltage reference

Range	110-220/240VAC (CAT III – 400V)		
Frequency	50-60Hz		
Electrical isolation	2.5Kv @ 60second		
Power supply requirement	0.1 VA per phase		
Accuracy	Class 0.2 (+/-0.2%)		
4	Recommend using electrical protection before connecting this reference.		

#### **Current reference**

This device can use current transformers (CT) of two types 0.33Vac and flexible type (Rogowski), depending on each type has a different type of accuracy.

Types	Range of measureament	Output type	Accuracy
CT 50 A	150 A	0.33VAC	+/-1% (5%100% ln)
CT 100 A	1100 A	0.33VAC	+/-1% (5%100% ln)
CT 150 A	1150 A	0.33VAC	+/-1% (5%100% ln)
CT 400 A	1400 A	0.33VAC	+/-1% (5%100% ln)
CT 800 A	1800 A	0.33VAC	+/-1% (5%100% ln)
Flexible 5000 A (7cm Ø) (*)	105000 A	Rogowski	+/-1% (centered)
Flexible 5000 A (12cm Ø) (*)	105000 A	Rogowski	+/-1% (centered)
Flexible 5000 A (20cm Ø) (*)	105000 A	Rogowski	+/-1% (centered)

(\*)Must use flexible SenNet Rogowski model to certificate Class 1. (Factory Calibrated)

#### Accuracy on current measurement

Easy Meter + SenNet CT 0.33Vac	Class 1	(Class 0.5 under requeriment)
Easy Meter + Flexible SenNet Rogowski	Class 1	Factory Calibrated


ectri		

Electrical isolation	
SenNet CT 0.33Vac	2.5KV / 0.5mA / 3second
Flexible SenNet Rogowski	600V CAT IV



### **Holding case**

and a second	
IP Grade	IP-60
Temperature details	
Working temperature	-20ºC+70ºC
Store temperature	-20ºC+75ºC
Holding	
Dimensions	119 x 111 x 53 mm
Type mount	Wall or din rail
Plastic Material	ABS – V0





#### Warranty

Satel Spain guarantees its products against all manufacturing defects for a period of 1 year.

No return of material will be accepted, nor will any equipment be repaired if it is not accompanied by a report (RMA) indicating the defect observed or the reasons for the return.

The warranty will be void if the equipment has suffered "misuse" or the storage, installation or maintenance instructions in this manual have not been followed. "Misuse" is defined as any use or storage situation contrary to the National Electrical Code or that exceeds the limits indicated in this manual.



Satel Spain declines all responsibility for possible damage to the equipment or to other parts of the installations and will not cover possible penalties derived from a possible breakdown, poor installation or "misuse" of the equipment. Consequently, the guarantee is not applicable to breakdowns produced in the following cases.

- Due to overvoltage and/or electrical disturbances in the supply.
- By water, if the product does not have the appropriate IP rating.
- For exposing the equipment to extreme temperatures, which exceed the operating or storage temperature limit.
- Due to a modification of the product by the client without prior notice to Satel Spain.

Faced with possible errors in this technical sheet, keep it updated in our website.