Entergy

Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
James A. FitzPatrick NPP
P.O. Box 110
Lycoming, NY 13093
Tel 315-349-6024 Fax 315-349-6480

Brian R. Sullivan
Site Vice President – JAF

JAFP-16-0123
August 3, 2016

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555-0001

Subject: LER: 2016-003, Concurrent Opening of Reactor Building Airlock Doors

James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
License No. DPR-59

Dear Sir or Madam:

This report is submitted in accordance with 10 CFR 50.73(a)(2)(v)(C).

There are no new regulatory commitments contained in this report.

Questions concerning this report may be addressed to Mr. William Drews, Regulatory Assurance Manager, at (315) 349-6562.

Sincerely,

for Sullivan (Acting)

Brian R. Sullivan
Site Vice President

BRS/WD/ds

Enclosure: JAF LER 2016-003, Concurrent Opening of Reactor Building Airlock Doors

cc: USNRC, Region I Administrator
USNRC, Project Manager
USNRC, Resident Inspector
INPO Records Center (ICES)

NRC FORM 366 (11-2015)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT (LER)

1. FACILITY NAME	2. DOCKET NUMBER	3. PAGE
James A. FitzPatrick Nuclear Power Plant	05000333	1 OF 3

4. TITLE
Concurrent Opening of Reactor Building Airlock Doors

5. EVENT DATE			6. LER NUMBER			7. REPORT DATE			8. OTHER FACILITIES INVOLVED	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REV NO.	MONTH	DAY	YEAR	FACILITY NAME	DOCKET NUMBER
06	07	2016	2016	003	00	08	03	2016	N/A	N/A
									N/A	N/A

9. OPERATING MODE: 1

10. POWER LEVEL: 100

11. THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: *(Check all that apply)*

☐ 20.2201(b)	☐ 20.2203(a)(3)(i)	☐ 50.73(a)(2)(ii)(A)	☐ 50.73(a)(2)(viii)(A)
☐ 20.2201(d)	☐ 20.2203(a)(3)(ii)	☐ 50.73(a)(2)(ii)(B)	☐ 50.73(a)(2)(viii)(B)
☐ 20.2203(a)(1)	☐ 20.2203(a)(4)	☐ 50.73(a)(2)(iii)	☐ 50.73(a)(2)(ix)(A)
☐ 20.2203(a)(2)(i)	☐ 50.36(c)(1)(i)(A)	☐ 50.73(a)(2)(iv)(A)	☐ 50.73(a)(2)(x)
☐ 20.2203(a)(2)(ii)	☐ 50.36(c)(1)(ii)(A)	☐ 50.73(a)(2)(v)(A)	☐ 73.71(a)(4)
☐ 20.2203(a)(2)(iii)	☐ 50.36(c)(2)	☐ 50.73(a)(2)(v)(B)	☐ 73.71(a)(5)
☐ 20.2203(a)(2)(iv)	☐ 50.46(a)(3)(ii)	☑ 50.73(a)(2)(v)(C)	☐ 73.77(a)(1)
☐ 20.2203(a)(2)(v)	☐ 50.73(a)(2)(i)(A)	☐ 50.73(a)(2)(v)(D)	☐ 73.77(a)(2)(i)
☐ 20.2203(a)(2)(vi)	☐ 50.73(a)(2)(i)(B)	☐ 50.73(a)(2)(vii)	☐ 73.77(a)(2)(ii)
	☐ 50.73(a)(2)(i)(C)	☐ OTHER Specify in Abstract below or in NRC Form 366A	

12. LICENSEE CONTACT FOR THIS LER

LICENSEE CONTACT	TELEPHONE NUMBER *(Include Area Code)*
Mr. William Drews, Regulatory Assurance Manager	315-349-6562

13. COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT

CAUSE	SYSTEM	COMPONENT	MANU-FACTURER	REPORTABLE TO EPIX	CAUSE	SYSTEM	COMPONENT	MANU-FACTURER	REPORTABLE TO EPIX
X	NG	N/A	N/A	N					

14. SUPPLEMENTAL REPORT EXPECTED

☐ YES *(If yes, complete 15. EXPECTED SUBMISSION DATE)* ☑ NO

15. EXPECTED SUBMISSION DATE	MONTH	DAY	YEAR

ABSTRACT *(Limit to 1400 spaces, i.e., approximately 15 single-spaced typewritten lines)*

On the morning of June 7, 2016, while operating at 100% power, workers opened doors concurrently when entering a secondary containment access airlock. The individuals involved each closed their respective doors upon encountering this unexpected condition; however, the result was a brief inoperability of secondary containment.

This resulted in an 8 hour reportable event. The Resident Inspector was notified, and an Event Notification was made pursuant to 10 CFR 50.72(b)(3)(v)(C) due to a condition at the time of discovery that prevented the fulfillment of the Secondary Containment safety function (Reference ENS 51985). Following the event, the doors functioned properly, and no deficiencies were noted with either door.

There were no radiological releases associated with this event.

NRC FORM 366A (11-2015)	U.S. NUCLEAR REGULATORY COMMISSION	APPROVED BY OMB: NO. 3150-0104 EXPIRES: 10/31/2018
	LICENSEE EVENT REPORT (LER) CONTINUATION SHEET	Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Privacy and Information Collections Branch (T-5 F53), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by internet e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME	2. DOCKET NUMBER	3. LER NUMBER		
		YEAR	SEQUENTIAL NUMBER	REV NO.
James A. FitzPatrick Nuclear Power Plant	05000 – 333	2016	– 003	– 00

NARRATIVE

Background

The Secondary Containment [EIIS identifier: NG] boundary surrounds the primary containment and refueling equipment. The boundary forms a control volume to contain, dilute, and hold up fission products. The Secondary Containment consists of four systems which include the Reactor Building, the Reactor Building Isolation and Control System, the Standby Gas Treatment System, and the Main Stack. Secondary Containment is designed to provide containment for postulated design basis accident scenarios: loss-of-coolant accident and refueling (fuel handling) accident. Since pressure may increase in Secondary Containment relative to the environmental pressure, support systems are required to maintain a differential pressure vacuum such that external atmosphere would leak into containment rather than fission products leak out.

The systems which maintain a differential pressure vacuum inside Secondary Containment include the normal Reactor Building Ventilation and Cooling (RBV) System [VA] (during normal plant operations) and the safety-related Standby Gas Treatment (SBGT) System [BH] for post-accident conditions.

Technical Specification (TS) Surveillance Requirement (SR) 3.6.4.1.3 requires one Secondary Containment access door in each access opening to remain closed. Failure to meet this SR results in the Secondary Containment Limiting Condition for Operation (LCO) not being met, and requires the Secondary Containment to be declared Inoperable.

Event Description

On June 7, 2016, with the James A. FitzPatrick Nuclear Power Plant (JAF) operating at 100 percent power, members of the Maintenance and Security departments simultaneously entered the northeast Secondary Containment airlock on Reactor Building Elevation 272'. This resulted in the concurrent opening of the airlock doors. This condition was corrected within approximately two (2) seconds. At the time of the closure of either door, secondary containment integrity was restored as the SR for one door closed was met, and no other SRs (such as negative pressure) were being exceeded.

For the condition in which Secondary Containment did not meet the Technical Specification (TS) Surveillance Requirement (SR) 3.6.4.1.3 for at least one door in secondary containment access opening being closed, the TS Limiting Condition of Operation (LCO) 3.6.4.1 required action was to restore secondary containment to Operable status in 4 hours.

An NRC notification was made via ENS 51985. This Licensing Event Report (LER) is being submitted per 10 CFR 50.73(a)(2)(v)(C) as a condition that could have prevented the fulfillment of safety function to control the release of radioactive material.

Event Analysis

Timeline of Events on 6/7/2016

1030 Personnel entered the northeast Reactor Building Elevation 272' airlock simultaneously, and the condition was corrected within approximately two (2) seconds.
1110 Condition Report (CR-JAF-2016-01996) initiated.
1307 NRC notified via ENS 51985

NRC FORM 366A (11-2015)	U.S. NUCLEAR REGULATORY COMMISSION	APPROVED BY OMB: NO. 3150-0104 EXPIRES: 10/31/2018
	LICENSEE EVENT REPORT (LER) CONTINUATION SHEET	Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Privacy and Information Collections Branch (T-5 F53), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by internet e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME	2. DOCKET NUMBER	3. LER NUMBER		
		YEAR	SEQUENTIAL NUMBER	REV NO.
James A. FitzPatrick Nuclear Power Plant	05000 – 333	2016	– 003	– 00

Cause

Secondary Containment access openings are equipped with green indicating lights that are lit when the opposing access opening door is fully shut. None of the parties involved indicated they observed the green indicating light not being lit prior to opening the airlock door. Therefore, the cause of this condition was determined to be simultaneous opening of the doors.

Similar Events

Internal Events

LER 2015-004-00, Concurrent Opening of Reactor Building Airlock Doors; Condition Report: CR-JAF-2015-04146, September 17, 2015

External events:

Quad Cities Nuclear Generating Station: LER 2015-008, Interlock Doors Opened Simultaneously Cause Loss of Secondary Containment

Duane Arnold Energy Center: LER 2015-003-01, Both Doors in Secondary Containment Airlock Opened Concurrently

Corrective Actions

Completed Actions

- Both airlock doors (24R-272-5 & -6) on the northeast Reactor Building Elevation 272' Secondary Containment airlock were closed within approximately two (2) seconds.
- Condition Report initiated (CR-JAF-2016-01996); NRC notified via ENS 51985.
- Installed cameras and monitors on both sides of the northeast Reactor Building Elevation 272' Secondary Containment airlock. This will allow verification that the opposing door will not be simultaneously opened.

Safety Consequence and Implications

<u>Actual Consequences</u>
There were no actual consequences of this event relative to nuclear, industrial, or radiological safety.

<u>Potential Consequences</u>
The Secondary Containment differential pressure remained more negative than 0.25 inches of water vacuum while this condition existed. Therefore, there are no potential consequences of this event relative to nuclear, industrial, or radiological safety.

References

- Condition Report: CR-JAF-2016-01996, June 7, 2016, Concurrent Opening of Secondary Containment Access Airlocks
- Technical Specification 3.6.4.1