



Exelon Generation®

Clinton Power Station
8401 Power Road
Clinton, IL 61727

U-604364
August 1, 2017

10CFR 50.73
SRRS 5A.108

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Clinton Power Station, Unit 1
Facility Operating License No. NPF-62
NRC Docket No. 50-461
Licensee Event Report 2017-006-00

Subject: LER 2017-006-00

Enclosed is Licensee Event Report (LER) 2017-006-00: Secondary Containment Inoperable During Mode Change Due to Doors Propped Open. This report is being submitted in accordance with the requirements of 10 CFR 50.73. There are no regulatory commitments contained in this report.

Should you have any questions concerning this report, please contact Mr. Dale Shelton, Regulatory Assurance Manager, at (217) 937-2800.

Respectfully,

Theodore R. Stoner
Site Vice President
Clinton Power Station

KP/bsz

Attachment: Licensee Event Report 2017-006-00

cc:
Regional Administrator- NRC Region III
NRC Senior Resident Inspector - Clinton Power Station
Office of Nuclear Facility Safety - Illinois Emergency Management Agency

TEZZ
NRR

**LICENSEE EVENT REPORT (LER)**

(See Page 2 for required number of digits/characters for each block)

(See NUREG-1022, R.3 for instruction and guidance for completing this form
<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1022/r3/>)

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the Information Services Branch (T-2 F43), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME

Clinton Power Station, Unit 1

2. DOCKET NUMBER

05000461

3. PAGE

1 OF 3

4. TITLE

Secondary Containment Inoperable During Mode Change Due to Doors Propped Open

5. EVENT DATE			6. LER NUMBER			7. REPORT DATE			8. OTHER FACILITIES INVOLVED	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REV NO.	MONTH	DAY	YEAR	FACILITY NAME	DOCKET NUMBER
06	02	2017	2017	- 006	- 00	08	01	2017	FACILITY NAME	DOCKET NUMBER
										05000

9. OPERATING MODE	11. THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check all that apply)			
2	☐ 20.2201(b)	☐ 20.2203(a)(3)(i)	☐ 50.73(a)(2)(ii)(A)	☐ 50.73(a)(2)(viii)(A)
	☐ 20.2201(d)	☐ 20.2203(a)(3)(ii)	☐ 50.73(a)(2)(ii)(B)	☐ 50.73(a)(2)(viii)(B)
	☐ 20.2203(a)(1)	☐ 20.2203(a)(4)	☐ 50.73(a)(2)(iii)	☐ 50.73(a)(2)(ix)(A)
	☐ 20.2203(a)(2)(i)	☐ 50.36(c)(1)(i)(A)	☐ 50.73(a)(2)(iv)(A)	☐ 50.73(a)(2)(x)
10. POWER LEVEL	☐ 20.2203(a)(2)(ii)	☐ 50.36(c)(1)(ii)(A)	☐ 50.73(a)(2)(v)(A)	☐ 73.71(a)(4)
	☐ 20.2203(a)(2)(iii)	☐ 50.36(c)(2)	☐ 50.73(a)(2)(v)(B)	☐ 73.71(a)(5)
	☐ 20.2203(a)(2)(iv)	☐ 50.46(a)(3)(ii)	☐ 50.73(a)(2)(v)(C)	☐ 73.77(a)(1)
	☐ 20.2203(a)(2)(v)	☐ 50.73(a)(2)(i)(A)	☐ 50.73(a)(2)(v)(D)	☐ 73.77(a)(2)(i)
	☐ 20.2203(a)(2)(vi)	☒ 50.73(a)(2)(i)(B)	☐ 50.73(a)(2)(vii)	☐ 73.77(a)(2)(ii)
	☐ 50.73(a)(2)(i)(C)	☐ OTHER	Specify in Abstract below or in NRC Form 366A	

12. LICENSEE CONTACT FOR THIS LER

LICENSEE CONTACT	TELEPHONE NUMBER (Include Area Code)
Dale A. Shelton, Regulatory Assurance Manager	(217) 937-2800

13. COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT

CAUSE	SYSTEM	COMPONENT	MANU-FACTURER	REPORTABLE TO EPIX	CAUSE	SYSTEM	COMPONENT	MANU-FACTURER	REPORTABLE TO EPIX

14. SUPPLEMENTAL REPORT EXPECTED☐ YES (If yes, complete 15. EXPECTED SUBMISSION DATE) ☒ NO**15. EXPECTED SUBMISSION DATE**

MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately 15 single-spaced typewritten lines)

On June 2, 2017, plant personnel were performing welding activities on the 'B' Reactor Water Cleanup System (RT) pump while the plant was in operating Mode 4. The Operations Work Control Supervisor (WCS) had given maintenance personnel authorization to prop both 'B' RT pump room doors open so that welding cables could extend through both doors in support of maintenance activities. The doors are part of the plant secondary containment boundary. Authorization granted by the WCS was executed without utilizing the plant barrier impairment process (PBI) per plant procedures. Prior to the plant's transition to operating Mode 2, Operations personnel made a plant announcement requiring the establishment of primary and secondary containment. The plant then transitioned to operating Mode 2 at 0241. However, both RT Pump 'B' doors remained propped open during the plant mode change. This condition was discovered by shift personnel at 0300 (CDT) and secondary containment was declared inoperable. The loss of secondary containment was caused by personnel not following the PBI per plant procedure. Secondary containment was subsequently restored twenty four minutes after discovery of the open 'B' RT doors. Corrective actions taken and planned include implementing management action response checklist (MARC) principles for the responsible supervisor and completing a read and sign for planners and schedulers associated with the PBI process.

**LICENSEE EVENT REPORT (LER)
CONTINUATION SHEET**

(See NUREG-1022, R.3 for instruction and guidance for completing this form
<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1022/r3/>)

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the Information Services Branch (T-2 F43), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME

Clinton Power Station, Unit 1

2. DOCKET NUMBER

05000461

3. LER NUMBER

YEAR

SEQUENTIAL
NUMBERREV
NO.

2017

- 006

- 00

NARRATIVE**PLANT AND SYSTEM IDENTIFICATION**

General Electric—Boiling Water Reactor, 3473 Megawatts Thermal Rated Core Power
Energy Industry Identification System (EIS) codes are identified in the text as [XX]

EVENT IDENTIFICATION

Secondary Containment Inoperable During Mode Change

A. Plant Operating Conditions before the Event

Unit: 1

Event Date: June 2, 2017

Event Time: 0241

Mode: 2

Mode Name: Power Operation

Reactor Power: 000 percent

B. DESCRIPTION OF EVENT

On June 2, 2017, while the plant was in Mode 4, maintenance personnel were performing welding activities associated with the 'B' Reactor Water Cleanup System (RT) [CE] pump. In support of these activities, an Operations Work Control Supervisor (WCS) provided authorization to prop open both RT 'B' pump room doors (a Secondary Containment (SC) boundary) to allow welding cables to extend through the doors. The authorization was granted, however, without utilizing the plant barrier impairment process (PBI) per plant procedures. This process provides guidance on actions necessary to evaluate and compensate for an impaired barrier. As the plant prepared for startup and the transition to operating Mode 2 commenced, Operations personnel made a plant announcement requiring that primary and secondary containment be established. The announcement was not heard by personnel working on the 'B' RT pump. The plant entered Mode 2 at 0241. The doors were found propped open at 0300 shortly after the plant entered Mode 2 by Operations shift personnel. Technical Specification (TS) 3.6.4.1, Secondary Containment, actions were then entered to restore SC. Both 'B' RT doors were later closed and SC was restored twenty four minutes following discovery of the open RT doors.

**LICENSEE EVENT REPORT (LER)
CONTINUATION SHEET**

(See NUREG-1022, R.3 for instruction and guidance for completing this form
<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1022/r3/>)

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the Information Services Branch (T-2 F43), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME	2. DOCKET NUMBER	3. LER NUMBER		
		YEAR	SEQUENTIAL NUMBER	REV NO.
Clinton Power Station, Unit 1	05000461	2017	- 006	- 00

NARRATIVE**C. CAUSE OF EVENT**

The cause of the event was that the PBI process was not followed per plant procedures. Maintenance personnel did not follow the PBI process by asking the WCS if a PBI was needed and the WCS was focused on restoration of RT Pump 'B' and failed to consider the need to review the PBI procedure and allowed the work to be performed without a PBI.

D. SAFETY ANALYSIS

There were no safety consequences associated with inoperability of SC as described in this report. Secondary Containment differential pressure remained negative throughout this event.

The SC vacuum is kept slightly negative relative to the atmospheric pressure to prevent leakage to the atmosphere. The Standby Gas Treatment (VG) [BH] is the safety-related system which is relied upon to perform this function following an accident. During the event the VG system was available during this event. The open RT 'B' doors were later closed and TS actions were subsequently exited. Therefore, the ability of the station to maintain secondary containment in an accident scenario was never jeopardized or challenged by the loss of secondary containment.

This event is reportable under the provisions of 10 CFR 50.73(a)(2)(i)(B) as operation prohibited by Technical Specifications.

This event report does not identify any safety system functional failures.

E. CORRECTIVE ACTIONS

Corrective actions planned or taken following the event included implementing the management action response checklist (MARC) principles for the responsible supervisor and conducting a read and sign of the PBI procedure and its interaction with the work process for schedulers and planners.

F. PREVIOUS SIMILAR OCCURENCES

This are no previous similar occurrences involving a mode change with an inoperable secondary containment.

G. COMPONENT FAILURE DATA

There was no component failure data associated with this event.