Portotherm / Review evidence

Synthetic demo data - not measured customer results

2026-01-01 to 2026-09-30 / monthly-nnls-1.0

Generated UTC: 2026-10-15T11:11:42.117272+00:00

SYN-003 / Building 03 / investigate
Observed 237,567 kWh; expected 164,920 kWh
Quality: usable; review priority: 64/100
4 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-001 / Building 01 / within reference
Observed 127,473 kWh; expected 127,570 kWh
Quality: usable; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-002 / Building 02 / within reference
Observed 146,322 kWh; expected 146,606 kWh
Quality: usable; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-004 / Building 04 / data review
Observed 160,695 kWh; expected 161,389 kWh
Quality: review required; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

Portotherm / Review evidence

Synthetic demo data - not measured customer results

2026-01-01 to 2026-09-30 / monthly-nnls-1.0

Generated UTC: 2026-10-15T11:11:42.117272+00:00

SYN-005 / Building 05 / data review
Observed 200,922 kWh; expected 202,635 kWh
Quality: review required; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-006 / Building 06 / insufficient data
Observed 251,792 kWh; expected insufficient data
Quality: review required; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. At least 18 valid training months with season coverage required.
Training: Insufficient history
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-007 / Building 07 / within reference
Observed 229,010 kWh; expected 238,822 kWh
Quality: usable; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-008 / Building 08 / within reference
Observed 258,638 kWh; expected 258,568 kWh
Quality: usable; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

Portotherm / Review evidence

Synthetic demo data - not measured customer results

2026-01-01 to 2026-09-30 / monthly-nnls-1.0

Generated UTC: 2026-10-15T11:11:42.117272+00:00

SYN-009 / Building 09 / within reference
Observed 277,513 kWh; expected 277,048 kWh
Quality: usable; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-010 / Building 10 / within reference
Observed 295,649 kWh; expected 294,626 kWh
Quality: usable; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-011 / Building 11 / within reference
Observed 312,170 kWh; expected 315,801 kWh
Quality: usable; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

SYN-012 / Building 12 / within reference
Observed 331,087 kWh; expected 332,501 kWh
Quality: usable; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. A review priority, not a fault diagnosis.
Training: 2024-01-01 to 2025-12-31
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.

Portotherm / Review evidence

Synthetic demo data - not measured customer results

2026-01-01 to 2026-09-30 / monthly-nnls-1.0

Generated UTC: 2026-10-15T11:11:42.117272+00:00

SYN-IMPORT / SYN-IMPORT / insufficient data
Observed 0 kWh; expected insufficient data
Quality: review required; review priority: 0/100
0 evaluation months exceed 20% and 3,000 kWh; persistence required. At least 18 valid training months with season coverage required.
Training: Insufficient history
Limitations: Monthly data only; no equipment diagnosis or verified savings. Synthetic weather, HDD base 15.5°C; no station match for customer data. Domestic hot water is not separated. Occupancy and meter changes can confound results.
Human review: check invoices, use changes, meter history and maintenance records.