U-VALUE

MATERIAL/PRODUCT	Thickness Millimeters	Lamba λ Conductivity W/Km²	Resistance R Resistivity m^2K/W
Convective heat transfer coefficient Set value outside			0.13
Lime render (Oekobau)	20	3.50	0.005
Hempcrete block (Hempblock, IsoHemp)	300	0.07	4.20
Rammed earth (Oekobau)	600	0.64	0.93
Clay render (Oekobau)	20	0.80	0.02
Convective heat transfer coefficient Set value inside			0.13
Sum Resistance R Resistivity m^2K/W			5.41

U-VALUE wall assembly
W/m^2K **0,18 W/m^2K**

U-VALUE calculation for the wall assembly has been conducted to verify compliance with the current Norwegian building code (TEK17) regarding new office construction (<0.18 W/m^2K). In comparisons with alternative wall assemblies, the U-value serves as a key metric that ensures a balanced focus between energy consumption during the building's operational phase (B6) and the embedded emissions of the materials used.