U-VALUE

MATERIAL/PRODUCT	Thickness Millimeters	Lamba λ Conductivity W/Km²	Resistance R Resistivity m²K/W
Convective heat transfer coefficient Set value outside			0.13
Facade panel	120	0.12	1.00
Air gap			
Wood fibre (Steico)	150	0.038	3.90
CEB (Tapialblock, Fetdeterra)	400	0.77	0.51
Clay render	20	0.80	0.02
Convective heat transfer coefficient Set value inside			0.13
Sum Resistance R Resistivity m²K/W			5.69

U-VALUE wall assembly W/m²K **0,17 W/m²K**

U-VALUE calculation for the wall assembly has been conducted to verify compliance with the current Norwegian building code (TEK17) regarding new office construction (<0.18 W/m²K). In comparisons with alternative wall assemblies, the U-value serves as a key metric that ensures a balanced focus between energy consumption during the building's operational phase (B6) and the embedded emissions of the materials used.