

German Power Fair Value — Day-Ahead Forecasting Pipeline

Seya Makin | seyamakin04@gmail.com | github.com/seya-makin/cobblestone-power
Market: DE-LU Day-Ahead | Submission: July 2026

The German DA market in 2024 is defined by two opposing forces: renewable cannibalization driving 457 negative-price hours (5.2% of the year) as solar penetration hit 17% of generation, and Dunkelflaute events in November and December 2024 that drove German power prices to intraday peaks of €820/MWh and €900/MWh, with day-ahead prices reaching €145/MWh and €175/MWh respectively — the highest in 18 years. Any credible fair-value system must model both regimes. This pipeline does.

1. Data Ingestion and Quality

Source: SMARD (smard.de) — Bundesnetzagentur electricity market platform. Data retrieved from ENTSO-E under EU Regulation 543/2013. Equivalent data quality, no API key required, fully public.

Programmatic API endpoints:

Series	Filter ID	Endpoint Pattern	Unit
DA Price DE-LU	4169	/chart_data/4169/DE-LU/	EUR/MWh
Total Load	410	/chart_data/410/DE/	MW
Wind Onshore	123	/chart_data/123/DE/	MW
Wind Offshore	3791	/chart_data/3791/DE/	MW
Solar PV	125	/chart_data/125/DE/	MW

Base URL: `https://www.smard.de/app/chart_data/{filter}/{region}/{filter}_{region}_hour_{ts}.json`
Response: `[[unix_ms, value], ...]` arrays converted to UTC-indexed hourly Series.

Dataset: 26,304 hours, 2022-01-01 to 2024-12-31.
Timezone: UTC internal storage; CET/CEST for display. Spring-forward gap interpolated; autumn duplicate averaged. Assert: exactly 8,784 rows for 2024 — passes.

Structural breaks: `post_ukraine_war` (2022-02-24); `post_nuclear_phaseout` (2023-04-15, DE nuclear = 0 MW).

LLM Data QA (Gemini 2.0 Flash): 20 electricity-market-specific validation rules proposed programmatically and executed as Python boolean conditions (solar zero 20:00–05:00 CET, load 20–100 GW, price –500 to 3,000 EUR/MWh, nuclear = 0 after phase-out, Dunkelflaute logic). QA score: 97.1/100 — PASS. This reduces manual rule authoring from hours to seconds while producing domain-specific rules a generalist engineer would miss.

2024 verified facts: Mean DA price €78.51/MWh; negative hours 457 (5.2%); Dunkelflaute detected: Nov 2–7 2024 (111 Dunkelflaute hours within 144h window), Dec 12–14 2024 (45

Dunkelflaute hours within 72h window).

2. Forecasting and Model Validation

Target: Hourly DA prices for delivery day + 1. Delivery-period aggregates derived from the hourly distribution.

Fundamental insight: German prices are driven by residual load = load – wind – solar. High residual load → gas marginal → prices spike. Low or negative → renewables marginal → prices collapse. Features capture this at multiple timescales.

67 features across 8 groups: fundamental supply/demand (11, led by residual_load), fuel/carbon (7, including clean spark spread), calendar with cyclic encoding (16), lag features shifted minimum 24h (8, price_lag_168h is strongest predictor at $r=0.71$), rolling statistics (10), interaction terms (6), regime features (8, including dunkelflaute_severity), and structural break dummies (3). Leakage assertion: no feature shows correlation above 0.95 with future target.

Results:

Model	2024 MAE	Skill vs Naive
Seasonal Naive	~32 EUR/MWh	baseline
Ridge Regression	37.91 EUR/MWh	-15.5%
XGBoost + Two-Stage	25.37 EUR/MWh (RMSE: 40.0)	+ 22.7%

Ridge underperforms naive because L2 penalty shrinks price_lag_168h toward zero — it serves as a linear interpretability benchmark only.

MAE by year (walk-forward 2022–2024):

Year	MAE	Context
2022	80.18	Ukraine crisis — prices €200–400/MWh
2023	52.54	Transition year
2024	25.37	Primary benchmark year

Post-crisis evaluation (2023-2024 training, excluding Ukraine gas crisis): MAE 24.98 EUR/MWh, directional accuracy 84.6% — mid-year calm windows achieve 9-18 EUR/MWh; Nov/Dec Dunkelflaute tails dominate the annual average regardless of training window.

Directional accuracy: **82.9%**. Two-stage architecture: binary classifier routes 17.2% of hours to an extreme-event regressor trained with price-proportional sample weights; a dedicated negative-price classifier (scale_pos_weight = 18.2, summer recall 91.1%, full-year 88.0%) feeds probability as a feature into the main model.

Validation: 52-window expanding walk-forward; min train 365 days; step 7 days; test full 2024 (8,784 hours); zero shuffling, zero future leakage.

Conformal Prediction (O'Connor et al., 2025): Regime-conditioned split conformal prediction with distribution-free coverage — no Gaussian assumptions. Empirical 90% coverage: **91.0%**.

Full 2024 out-of-sample predictions in submission.csv (8,784 rows): point forecast, 7 quantiles, conformal intervals, regime label, and Dunkelflaute risk score per hour.

3. Prompt Curve Translation

Horizon	Definition	Instrument
Prompt Day Baseload	Mean 24h	DE DA base block
Prompt Day Peak	Mean hours 08–20 Mon–Fri	DE DA peak block
Prompt Week Base	7-day mean	EEX Week Base Future
Prompt Month Base	Calendar month mean	EEX Month Base Future

All with 80% and 95% conformal prediction intervals.

Signal: LONG if fair-value estimate (FV) > reference + 0.5 × CP80_width; SHORT if FV < reference − 0.5 × CP80_width; NEUTRAL otherwise. HIGH conviction if CP80 width < 80% of 7-day mean.

Regime 3 (Dunkelflaute, residual load above 55GW and wind below 5GW): LONG prompt peak. Nov 2024 event drove DA prices to €145/MWh — gas peakers earned a disproportionate share of annual wholesale revenue over 111 hours. Regime 0 (renewable glut, penetration above 80% on summer weekends): SHORT prompt baseload, long battery charge/discharge spread.

Invalidation: wind revision > 20%; TTF move > €3/MWh overnight; French nuclear drop > 2,000 MW; DA clearing > 2σ from forecast; residual load change > 15%; unplanned outage > 1,000 MW; regime flip pre-delivery; conformal band expands > 50% vs 7-day mean.

4. AI-Accelerated Workflow

Three Gemini 2.0 Flash integrations — all programmatic, logged to JSONL, auditable.

Component 1 — LLM Data QA: Gemini receives schema plus 10 sample rows plus statistics and proposes 20 electricity-market-specific validation rules executed programmatically as Python boolean conditions. Component 2 — Market Commentary: 150–180 word Bloomberg-style note generated from 24 pipeline metrics only, with anti-hallucination guard cross-checking every number at ±0.5 tolerance. Component 3 — Ingestion Config: field documentation converted to structured JSON ingestion config, eliminating manual field mapping hardcoding. All prompts, responses, and outputs logged to JSONL under outputs/logs/.

Component	Logged	Hallucination Check	On Failure
QA Rules	Yes — JSONL	N/A	Log + continue
Commentary	Yes — JSONL	Yes — ±0.5 tolerance	Flag + log
Config Gen	Yes — JSONL	N/A	Fallback defaults

References: O'Connor et al. (2025) Energy and AI; Marcjasz et al. (2023) Energy Economics; Weron (2014) IJF; Wood Mackenzie (2025); Timera Energy (2025); FfE (2026).