

STORE INCIDENT REPORT

Severity: HIGH -- refrigeration failure with \$3,200 product loss

Location: Store #4421 -- Maple Grove, MN

Date/Time: September 18, 2026, 11:30 PM

Incident Type: Equipment Failure -- Refrigeration

Reported By: Night Crew Lead -- Alex Kim

Incident Description

Frozen food cases doors 20-24 found at 28F during overnight stocking. Product partially thawed. Compressor rack #2 alarming -- high discharge pressure fault. 200+ units of frozen product affected.

Root Cause

Condenser fan motor failure on compressor rack #2. Fan motor bearings seized. Backup unit offline for scheduled maintenance.

Corrective Actions

1) Emergency fan motor replacement completed at 3:15 AM. 2) Cases restored to -5F by 6:00 AM. 3) \$3,200 in product discarded. 4) PM schedule under review -- two refrigeration failures in 30 days at this store.