

STORE INCIDENT REPORT

Severity: HIGH

Location: Store #4590 -- Plymouth, MN

Date/Time: July 25, 2026, 12:15 PM

Incident Type: Equipment Failure -- Refrigeration

Reported By: Store Manager

Incident Description

Frozen food cases doors 14-23 found at 26F during overnight stocking. Product partially thawed. Compressor rack #2 alarming -- high discharge pressure fault.

Root Cause

Condenser fan motor failure. Same rack services doors 18-24 and backup unit was offline for scheduled maintenance.

Corrective Actions

- 1) All affected product pulled to walk-in freezer. 2) Emergency maintenance call placed. 3) \$4589 in product discarded.
- 4) PM schedule under review.