

STORE INCIDENT REPORT

Severity: HIGH

Location: Store #6010 -- Eagan, MN

Date/Time: July 12, 2026, 6:30 AM

Incident Type: Equipment Failure -- Refrigeration

Reported By: Front End Supervisor

Incident Description

Frozen food cases doors 20-27 found at 22F during overnight stocking. Product partially thawed. Compressor rack #1 alarming -- high discharge pressure fault.

Root Cause

Condenser fan motor failure. Same rack services doors 22-27 and backup unit was offline for scheduled maintenance.

Corrective Actions

- 1) All affected product pulled to walk-in freezer.
- 2) Emergency maintenance call placed.
- 3) \$2655 in product discarded.
- 4) PM schedule under review.