

STORE INCIDENT REPORT

Severity: LOW

Location: Store #8419 -- Brooklyn Park, MN

Date/Time: March 22, 2026, 7:45 AM

Incident Type: Equipment Failure -- Power Outage

Reported By: Loss Prevention Associate

Incident Description

Power outage affecting aisles 4-10. Backup generator activated for walk-ins. Floor cases on utility power lost cooling for 4 hours.

Root Cause

Utility transformer failure. Not within store control. Backup generator scope does not include floor-level cases.

Corrective Actions

1) Filed claim with utility provider. 2) Capital request submitted for expanded generator capacity. 3) Emergency SOP updated.