

MAINTENANCE WORK ORDER

WO-78245 | Priority: HIGH | Status: OPEN

Location: Store #5234 -- Minnetonka, MN

Date Opened: April 25, 2026

Date Closed: OPEN

Category: HVAC

Equipment: Rooftop Unit #3 (Carrier 48TM) -- serves bakery/deli

Assigned To: Trane Commercial -- Tech: Chris L.

Problem Description

Exhaust fan belt snapped. Smoke smell in bakery.

Resolution

PENDING -- Vendor site visit scheduled. Interim mitigation in place.

Cost

TBD