

MAINTENANCE WORK ORDER

WO-78448 | Priority: HIGH | Status: CLOSED

Location: Store #5102 -- Eden Prairie, MN

Date Opened: August 16, 2026

Date Closed: August 18, 2026

Category: Plumbing

Equipment: Grease trap -- deli

Assigned To: Roto-Rooter Commercial -- Tech: Alex R.

Problem Description

Hot water at prep sink measured 79F. Minimum required 110F.

Resolution

Diagnosed and repaired on-site. Verified operational.

Cost

\$522.00