

MAINTENANCE WORK ORDER

WO-78604 | Priority: LOW | Status: OPEN

Location: Store #5102 -- Eden Prairie, MN

Date Opened: June 19, 2026

Date Closed: OPEN

Category: Plumbing

Equipment: Restroom fixtures -- customer

Assigned To: Pipeworks LLC -- Tech: Chris L.

Problem Description

Hot water at prep sink measured 75F. Minimum required 110F.

Resolution

PENDING -- Vendor site visit scheduled. Interim mitigation in place.

Cost

TBD