

MAINTENANCE WORK ORDER

WO-79079 | Priority: MEDIUM | Status: CLOSED

Location: Store #5234 -- Minnetonka, MN

Date Opened: June 04, 2026

Date Closed: June 05, 2026

Category: Plumbing

Equipment: Grease trap -- deli

Assigned To: Pipeworks LLC -- Tech: Tom N.

Problem Description

Hot water at prep sink measured 87F. Minimum required 110F.

Resolution

Diagnosed and repaired on-site. Verified operational.

Cost

\$262.00